

CITY OF MILTON-FREEWATER, OREGON

WATER SYSTEM MASTER PLAN

2009



Anderson-Perry & Associates, Inc.

Civil Engineers

La Grande, Oregon
Walla Walla, Washington

TABLE OF CONTENTS

| | <u>Page</u> |
|---|-------------|
| EXECUTIVE SUMMARY | |
| Existing Water Supply and Water Rights | ES-1 |
| Existing Water Storage | ES-3 |
| Existing Distribution System | ES-3 |
| Existing Pressure Zones | ES-4 |
| Summary of System Needs | ES-5 |
| Priority of Improvements | ES-5 |
| Current Financial Status | ES-6 |
| Conclusions | ES-7 |
| | |
| CHAPTER 1 - BACKGROUND INFORMATION | |
| Purpose of Study | 1-1 |
| Description of Community | 1-2 |
| Environment | 1-3 |
| Water System History | 1-4 |
| Previous Studies | 1-6 |
| | |
| Figure 1-1 Location Map | |
| Figure 1-2 Reservoir and Well Locations | |
| | |
| CHAPTER 2 - WATER SYSTEM REQUIREMENTS | |
| Introduction | 2-1 |
| Service Area | 2-1 |
| Service Population and Planning Period | 2-1 |
| Land Use | 2-2 |
| Regulatory Requirements | 2-4 |
| Sanitary Survey | 2-7 |
| Water Demand | 2-8 |
| Fire Demand | 2-10 |
| Design Criteria | 2-12 |
| | |
| Table 2-1 Comparison Water Usage | |
| Table 2-2 ISO Fire Flow Tests | |
| Table 2-3 Summary of Design Criteria Water Supply | |
| Table 2-4 Summary of Design Criteria Storage Reservoirs | |
| | |
| Figure 2-1 Historical and Projected Population | |
| Figure 2-2 Well No. 1 Monthly Production | |
| Figure 2-3 Well No. 2 Monthly Production | |
| Figure 2-4 Well No. 3 Monthly Production | |
| Figure 2-5 Well No. 5 Monthly Production | |
| Figure 2-6 Well No. 6 Monthly Production | |
| Figure 2-7 Well No. 8 Monthly Production | |
| Figure 2-8 Well No. 9 Monthly Production | |
| Figure 2-9 Total Monthly Production | |
| Figure 2-10 Summary of Annual Water Production | |

CHAPTER 3 - WATER SUPPLY AND TREATMENT

| | |
|--------------------------------------|------|
| Introduction | 3-1 |
| Present Water Supply | 3-1 |
| Water Rights | 3-4 |
| Water Supply Analytical Testing | 3-4 |
| Water Supply Design Criteria | 3-5 |
| Air Entrainment | 3-7 |
| Area Wells | 3-8 |
| Static Water Level Trends | 3-9 |
| Groundwater Supply Sources | 3-10 |
| Surface Water Sources | 3-12 |
| Surface Water Treatment Alternatives | 3-15 |
| Comparison of Water Supply Options | 3-23 |
| Summary and Recommendations | 3-25 |

| | |
|-----------|---------------------------------|
| Table 3-1 | Well Summary |
| Table 3-2 | Milton-Freewater Area Well Data |

| | |
|------------|---------------------|
| Figure 3-1 | Area Well Locations |
| Figure 3-2 | Static Water Levels |

CHAPTER 4 - WATER STORAGE

| | |
|--|-----|
| Introduction | 4-1 |
| General | 4-1 |
| Existing Facilities | 4-2 |
| Existing Pressure Zones | 4-2 |
| Storage Requirements | 4-3 |
| Recommended Storage Reservoir Improvements | 4-7 |

| | |
|------------|----------------|
| Figure 4-1 | Pressure Zones |
|------------|----------------|

CHAPTER 5 - DISTRIBUTION SYSTEM

| | |
|---|-----|
| Introduction | 5-1 |
| Existing System | 5-1 |
| Distribution System Water Quality | 5-1 |
| Existing Pressure Zones | 5-2 |
| Fire Protection | 5-3 |
| Distribution System Piping Improvements | 5-5 |
| Water Loss | 5-5 |
| Maintenance Records | 5-6 |
| Water Management and Conservation Plan | 5-7 |
| Summary and Recommendations | 5-7 |

| | |
|-----------|----------------------------------|
| Table 5-1 | Distribution System Improvements |
|-----------|----------------------------------|

CHAPTER 6 - RECOMMENDED SYSTEM IMPROVEMENTS

| | |
|---|-----|
| Introduction | 6-1 |
| Summary of Proposed System Improvements | 6-1 |
| Priority of Improvements | 6-2 |
| Cost Summary | 6-3 |

Table 6-1 Estimated Cost - Supply System Improvements

CHAPTER 7 - PROJECT FINANCING

| | |
|--|------|
| Introduction | 7-1 |
| Current Water Use Rates and Revenue | 7-1 |
| Current Financial Status | 7-3 |
| Water System Improvements Funding | 7-4 |
| Summary of State and Federal Grant and Loan Programs | 7-5 |
| Preliminary Equivalent Swelling Unit Analysis | 7-10 |
| Debt Capacity | 7-11 |
| Project Funding | 7-12 |
| Local Financing Options | 7-12 |
| Project Implementation | 7-12 |
| Proposed Project Implementation Plan | 7-13 |

Table 7-1 Water Department Revenues

Table 7-2 Water Department Expenditures

Table 7-3 Preliminary Water Rate Analysis for Bonding Capacity

Figure 7-1 Historical and Projected City Water Budget

Appendices

- Appendix A - Drinking Water Program Water Quality Testing Summary
- Appendix B - Drinking Water Program Sanitary Survey Information
- Appendix C - ISO Fire Protection Report
- Appendix D - City Well Log and Pump Data
- Appendix E - Water Right Data
- Appendix F - Area Well Logs
- Appendix G - Walla Walla River Water Quality Data
- Appendix H - Reservoir Inspection Information
- Appendix I - Umatilla Basin Program - OAR 690-507

EXECUTIVE SUMMARY

This Executive Summary briefly summarizes the results of the Water System Master Plan prepared for the City of Milton-Freewater by Anderson-Perry & Associates, Inc. The recommendations outlined hereafter have been developed in cooperation with the Milton-Freewater City staff. The focus of this study has been on the overall water system, including the water supply, storage, and distribution systems. The study includes an analysis of the existing system and its performance, evaluation of system needs, evaluation of improvement alternatives, and prioritization of improvements. Included in this Executive Summary is a brief discussion of the existing water system, recommendations to meet future demands on the water system, and an evaluation of the current financial status of the water department. For a more detailed discussion of the information presented in this Executive Summary, please refer to the individual chapters of this Master Plan.

EXISTING WATER SUPPLY AND WATER RIGHTS

Water Supply Facilities. The City of Milton-Freewater draws water from basalt aquifers using seven wells ranging in depth from 502 feet to 1,051 feet. Generally, the City's wells provide good quality water; however, the City has experienced an entrained air problem with some of the wells. The total capacity of all seven of the City's wells is approximately 7,520 gallons per minute (gpm). A brief summary of information for each of the City's wells, and their current status, is summarized hereafter.

Well No. 1. Well No. 1 was rehabilitated in 1971 and extended 15 feet to a depth of 651 feet. The well is one of the oldest in the City and is currently not regularly operated to meet City demands due to an air entrainment problem. Well No. 1 has a capacity of 830 gpm (11 percent of the total available supply).

Well No. 2. Well No. 2 was rehabilitated in May of 1988. The well was shut down in 1993 due to aeration problems developing in the water. This well has been continually monitored by the City since it developed air entrainment in 1990. A separate discharge line was routed from Well No. 2 to the Middle Reservoir in 2001 to facilitate removal of entrained air. Well No. 2 has a capacity of 750 gpm (10 percent of the total available supply) and is currently used to provide 15 to 23 percent of the City's water supply.

Well No. 3. Well No. 3 was rehabilitated in January of 1991 and shut down in March of 1993 due to aerated water problems. An attempt to seal the aquifer and set the pump column to a greater depth was undertaken after the well was taken off line. However, the sealing effort failed to stop the aeration problem and a new transmission line was constructed in 1999 to allow the well to discharge to the North Reservoir. Well No. 3 has a capacity of 1,150 (15 percent of the total available supply) and is currently used to provide 20 to 22 percent of the City's water supply.

Well No. 5. Well No. 5 was deepened 10 feet in 1980. The well was rehabilitated in 2000. It is believed that the principal aquifer is located in the bottom 30 feet of the hole (below 470 feet depth). This is the oldest well in the City and saw increased production in 1998 and 1999, accounting for approximately 30 percent of the City's annual water production during that period. This well developed air entrainment problems in September 2000 and a separate discharge into the North Reservoir was constructed in 2001. Well No. 5 has a capacity of 1,100 gpm (15 percent of the total available supply) and is currently used to provide about 14 to 17 percent of the City's water supply.

Well No. 6. Well No. 6 was rehabilitated in 1992. The hole is crooked and placing the original column was difficult. Well No. 6 also developed air problems and a separate discharge into the North Reservoir was constructed in 1999. Well No. 6 has a capacity of 1,400 gpm (19 percent of the total available supply), and is currently used to provide about 21 to 25 percent of the City's water supply.

Well No. 8. Well No. 8 was originally 888 feet deep and was deepened to 1,051 feet in 1970, becoming the City's deepest well. The well was rehabilitated in 1969 and 1970. This well is the most recently drilled well in the City and currently provides very little supply because it is the least efficient well to operate. Well No. 8 has a capacity of 1,490 gpm (20 percent of the total available supply).

Well No. 9. Well No. 9 was acquired by the City in 1993 after previously being owned and operated by the Umatilla Canning Company. The last rehabilitation of the well was completed in 1997. This well serves both the Middle and South Pressure Zones through separate control systems for the primary pump and a separate set of booster pumps. The primary pump is controlled by system controls at the Middle Reservoir while the booster pumps are controlled by system controls at the South Reservoir. Well No. 9 has a capacity of 800 gpm (11 percent of the total available supply) and is currently used to provide about 20 to 23 percent of the City's water supply.

Water Rights. The City of Milton-Freewater holds groundwater and surface water rights issued by the State of Oregon for each of its supply sources. All of the City's wells are utilized at a rate less than the allowed flow volume under the associated water rights. A summary of the water rights information is listed in the following table.

WATER RIGHTS

| Water Source | Application Number | Permit Number | Certification Number | Allowed Flow Volume (cfs/gpm)* | Priority Date |
|-------------------|--------------------|-----------------|----------------------|--------------------------------|-------------------|
| Well No. 1 | U-109 G-5389 | U-102 G-4924 | 12070 | 1.5 / 673 2.0 / 898 | 1/18/37 1/4/71 |
| Well No. 2 | U-159 | U-150 | 15548 | 3.0 / 1,346 | 2/28/44 |
| Well No. 3 | U-191 | U-172 | 16998 | 3.5 / 1,571 | 1/10/46 |
| Well No. 5 | U-809 | U-718 | 23533 | 2.7 / 1,212 | 4/13/55 |
| Well No. 6 | U-511 | U-462 | 23519 | 3.5 / 1,571 | 7/16/52 |
| Well No. 8 | G-2502 | G-2312 | 41011 | 3.9 / 1,750 | 12/13/62 |
| Well No. 9 | G-13494 | G-12582 | 20806 | 3.3 / 1,481 | 8/16/93 |
| Walla Walla River | -- | D-12920 | 12920 | 7.24 / 3,245 | 1890 |

* cfs = cubic feet per second

Gpm = gallons per minute

EXISTING WATER STORAGE

The City of Milton-Freewater currently has three water storage reservoirs, one for each pressure zone. The North Reservoir is a 2 million-gallon steel storage reservoir that was constructed in 1960. The base elevation of the reservoir is 1,145 feet above MSL, and the reservoir is approximately 40 feet tall. The reservoir serves the north pressure zone of Milton-Freewater by gravity flow.

The Middle Reservoir is a 1 million-gallon steel reservoir that was constructed in 1956. The base elevation of this reservoir is approximately 1,210 feet above MSL, and the reservoir is approximately 30 feet tall. The Middle Reservoir serves the middle pressure zone of Milton-Freewater by gravity flow.

The South Reservoir is a 2 million-gallon steel storage reservoir constructed in 1999. The base elevation of this reservoir is approximately 1,444 feet above MSL, and the reservoir is approximately 24 feet tall. The South Reservoir serves the south pressure zone of Milton-Freewater by gravity flow.

EXISTING DISTRIBUTION SYSTEM

The City of Milton-Freewater's water distribution system consists of approximately 45 miles of pipe, with 20 percent of the system having been installed in the 1940s or earlier. The water mains range from 2 inches to 20 inches in diameter with

materials including asbestos concrete, cast iron, ductile iron, galvanized iron, polyvinyl chloride (PVC), reinforced concrete pressure pipe (RCPP), and steel pipe. The few areas in the City served by 2-inch lines were developed in the 1940s. Over the last few decades, replacement and installations have been made with C900 PVC pipe.

In general, the distribution system is reported to have good hydraulic performance, is well looped (providing supply to developed portions of the City from two or more directions), and has relatively large diameter water distribution mains spread throughout the service area. The City indicated that the water main lines are generally in good condition. The City has an annual water main replacement program in place in order to alleviate local problems that may arise in the system.

EXISTING PRESSURE ZONES

The City of Milton-Freewater currently operates three pressure zones in their distribution system. The North Pressure Zone serves the north area of the City of Milton-Freewater to a southerly limit of Broadway Avenue. The Middle Pressure Zone covers an area extending from Broadway Avenue to the south end of the City Limits, excluding a small area in the southwest portion of town. The third zone is relatively new and is called the South Pressure Zone. It serves the higher ground in the southeast areas of the City and further south along U.S. Highway 11 within the Urban Growth Boundary.

The North Pressure Zone has static pressures ranging from 65 psi at the south end of the zone up to 98 psi at the extreme north end of the City near Powell Road. The North Pressure Zone can be supplied by the Middle Pressure Zone through a pressure reducing valve (PRV) located at the intersection of DeHaven Street and East Broadway Avenue. This PRV is normally closed but it is set to open when the North Pressure Zone system falls 20 psi below the Middle Pressure Zone. A separate isolation valve between these two zones is located at N.E. 1st Avenue and U.S. Highway 11. This valve is closed during normal system operation but can be opened in emergency conditions.

The Middle Pressure Zone creates static pressures of 100 psi near Broadway Avenue down to 40 psi at the higher elevations along the bluffs in the southwest area of the City. The lowest pressures are seen on Jacquelyn Street, which is located at the highest point in the service area on the southwest hillside.

Static pressures in the South Pressure Zone range from 50 psi near the Sykes Corporation to 126 psi at Well No. 9. Operation of the South Pressure Zone is tied to the Middle Pressure Zone in two critical ways. First, booster pumps located at the Well No. 9 pump house are controlled by a pressure transducer at the South Reservoir, which activates the booster pumps when the reservoir level is low. Water is then drawn from the Middle Pressure Zone and pumped up to fill the South Reservoir. Second, water being fed out of the South Reservoir is then cycled back into the Middle Pressure Zone through a PRV located in the Well No. 9 pump house. This PRV is set to allow a constant 40 gallons per minute (gpm) flow from the South Pressure Zone to the Middle

Pressure Zone (to help circulation of water in the South Reservoir) and increase this flow when pressures drop in the Middle Pressure Zone.

SUMMARY OF SYSTEM NEEDS

The improvements identified during preparation of this Water System Master Plan are briefly outlined hereafter. Because of the nature of the City's needs, some of the improvements are considered to be of higher priority than others.

Water Supply Improvements. Water supply improvements are recommended in order to connect City Well No. 1 to the Middle Reservoir. This transmission line is intended to deliver water with entrained air from the well directly to the reservoir where the entrained air can dissipate under atmospheric conditions.

Water Storage Improvements. Recommended water storage improvements are related to maintenance of the City's existing reservoirs. They include cleaning, sandblasting, and painting the interior of the Middle Reservoir and the interior and exterior of the North Reservoir.

Water Distribution System Improvements. Several distribution system improvements are outlined in detail in Chapter 5 of this Water System Master Plan. The City has developed a detailed distribution system improvements project list as presented in Chapter 5. The distribution system improvements project list was developed to list all main lines that should be replaced due to being undersized, to eliminate dead end lines where possible, and to replace main lines that have deteriorated to the point they must be replaced to remain in reliable service. The City periodically replaces distribution system main lines using City crews.

PRIORITY OF IMPROVEMENTS

The water system improvements summarized in this Water System Master Plan are important to help meet the City's year 2028 water system needs. Because some needs may be of higher priority, the City may wish to complete the improvements in a phased approach. If a phased approach is selected, prioritizing the improvements becomes important to help ensure the City's most important water system needs are addressed first. Outlined in the following table is the recommended priority for the water system improvements described in this Master Plan.

PRIORITY OF WATER SYSTEM IMPROVEMENTS

| Priority | Improvement | Reason for Priority Ranking |
|----------|---|--|
| A | Connecting Well No. 1 to the Middle Reservoir | Allows all water supply sources to be used on a daily basis and reduces the burden on other City wells. |
| B | Painting of Middle and North Reservoirs | Prevents further deterioration of existing reservoir coating and the potential damage to reservoir components. |
| C | Distribution System Improvements | Replaces aging main lines, provides looping for dead-end lines, improves water quality, and provides improved fire protection. |

CURRENT FINANCIAL STATUS

Existing Debt. The City of Milton-Freewater currently has two outstanding general obligation bonds on the water system. These bonds are summarized in the following table:

OUTSTANDING GENERAL OBLIGATION BONDS

| Original Amount | Year Issued | Year Debt Expires |
|-----------------|-------------|-------------------|
| \$465,000 | 1994 | 2013 |
| \$1,815,000 | 1997 | 2018 |

The annual principal and interest payments remaining for both loans are approximately \$183,840 per year through 2013, then approximately \$145,697 per year until the year 2018.

Annual Water System Costs. The annual cost of operating, maintaining, and making improvements to Milton-Freewater's water system is summarized in the following table. The costs presented include all costs for the water system. The City's annual expenditures have been increasing over the last five years at an annual rate of approximately 5.3 percent.

In order to simplify the complex array of revenue sources and expenditures, the annual revenue from water system sources (services, water meter sales, system development charges, merchandising, and interest income) has been compared with annual total operation and maintenance (O&M) costs, debt service costs, and inter-fund transfers. The table below presents this information.

ANNUAL WATER SYSTEM REVENUE VS. EXPENDITURES

| Fiscal Year | Revenue from Water System Sources ¹ | O&M, Debt, and Transfer Expenditures | Balance |
|----------------------|--|--------------------------------------|------------|
| 2003-04 | \$919,268 | \$922,727 | (\$3,459) |
| 2004-05 | \$945,447 | \$969,421 | (\$23,974) |
| 2005-06 | \$976,176 | \$957,799 | \$18,377 |
| 2006-07 | \$1,045,292 | \$1,071,916 | \$26,624 |
| 2007-08 | \$1,092,455 | \$1,073,769 | \$18,686 |
| 2008-09 ² | \$1,228,100 | \$1,196,335 | \$31,765 |

- ¹ Includes revenue from water user fees (services), water service installations (water meter sales), and system development charges.
- ² 2008-09 data are derived from the City's budget.

The positive balances since 2005-06 show that operation of the City's water system has been adequately funded over this period. The surplus of revenues from water system sources over O&M, debt service, and transfer expenditures has averaged approximately \$23,863 annually over the last four years. The above data shows that O&M, debt, and inter-fund transfer expenditures will likely exceed \$1,200,000 in fiscal year 2009-10.

CONCLUSIONS

The specific chapters of this Water System Master Plan contain a detailed analysis of the water supply, storage, and distribution system components of the City's water system. Based on the results of this Water System Master Plan, the City of Milton-Freewater has an excellent water system that is currently meeting existing system demands. The water department has sufficient revenue to operate and maintain the water system. The City's water supply sources and storage reservoirs appear to have adequate capacity to meet current and future needs for the 20-year planning period of this Plan, assuming growth occurs as outlined in Chapter 2. The water system is also in compliance with the Drinking Water Program.

To help ensure the water system continues to provide reliable operation and is able to meet future anticipated needs, the City should consider completing some system improvements as outlined in this Water System Master Plan. These improvements include a separate discharge line to the middle reservoir for Well No. 1 (to remove entrained air), painting the middle and north reservoirs, and distribution system improvements as outlined in Chapter 5.

CHAPTER 1

BACKGROUND INFORMATION

PURPOSE OF STUDY

This study presents the results of a Water System Master Plan authorized by agreement between the City of Milton-Freewater, Oregon, and Anderson-Perry & Associates, Inc., dated September 2, 1999. The purpose of the Master Plan is to develop water system design criteria for the planning period; evaluate the adequacy of the existing water supply, storage, and distribution systems; evaluate alternatives for improving the City's water system; and develop a financial plan for implementing the recommended improvements, should the City desire to complete major improvements. This Water System Master Plan is intended to satisfy the criteria of the Oregon Department of Human Services - Drinking Water Program (DWP) (formerly the Oregon Health Division) and Oregon Administrative Rule (OAR) 333-061-0060. Specifically, the Plan includes the following:

1. **General:** The Plan provides a general description of the community and history of the existing water system. A summary of the planning objectives and goals is outlined.
2. **Existing System:** The Plan outlines the status of the existing water system and describes its current operation, system strengths, and system deficiencies.
3. **Design Criteria:** Planning and design criteria are established and include establishment of a service area; population growth projections; past, present and future water usage patterns; fire flow requirements; federal and state standards; system pressures; and service goals. A growth rate for the City of Milton-Freewater is projected and a year 2028 design population has been selected by the City.
4. **Water Supply Facilities:** The individual components of the existing water supply system are analyzed considering capacity, compliance with current water quality standards, water rights, condition of components, operational dependability, and cost of operation. The water supply needs for the planning period have been developed and cost-effective alternatives for meeting long-term water supply needs are identified, including alternatives for correcting existing system deficiencies. Estimated costs for the preferred alternatives are presented, and general operation and maintenance requirements for the water supply system are outlined.
5. **Water Storage Facilities:** The existing water storage facilities are analyzed considering capacity, condition of reservoirs, distribution system pressures, etc. Recommended storage capacity is analyzed considering emergency storage, operational storage, equalization storage, and fire

reserve storage. Alternatives for meeting the storage requirements of the water system for the planning period are identified.

6. **Distribution System/System Mapping:** Utilizing existing distribution system maps and City records, a general review of the condition and adequacy of the distribution system piping is made. General system deficiencies are identified and alternatives for meeting current, as well as future, system deficiencies are outlined with estimated costs for implementation. General operation and maintenance requirements of the distribution system are also outlined. The City's electronically produced map of the distribution system is contained in a pocket at the end of this Plan.
7. **Water System Financing:** The status of the existing Water Department's financial condition is reviewed considering historical water system revenues, operational and maintenance costs, and debt service including the adequacy of existing water user fees. The future cost of operation and maintenance, capital improvement investments, and debt service for the water system is projected. Information is provided on potential state and federal grant and loan programs that may be available to assist the City in implementing water system improvements. A strategy for implementation of the recommended water system improvements is developed.
8. **Planning and Implementation Recommendations:** A summary is prepared identifying current and future water system needs with their associated estimated cost. Recommendations are made for meeting the water system needs for the planning period, and an Implementation Plan outlines project schedules, financing alternatives, and improvements to be made, should the City elect to complete water system improvements.

DESCRIPTION OF COMMUNITY

The City of Milton-Freewater is located along Oregon State Highway 11, adjacent to the Walla Walla River in Umatilla County. It is about 10 miles south of the City of Walla Walla, Washington. Figures 1-1 and 1-2 show a location map and general layout of the City of Milton-Freewater. The population, as reported by the Population Research Center at Portland State University, was 6,550 as of July 1, 2007. The primary economic base for the community is agriculture with some related food processing industry. The City of Milton-Freewater has also evolved into a "bedroom" community of the larger City of Walla Walla.

The City of Milton-Freewater was originally settled as two separate towns in the 1800s. Milton incorporated in 1889 and Freewater in 1892. Milton was named by pioneer W.J. Frazier for the poet, Milton. Freewater was named for the offering of free water by the City's forefathers. In 1950 the towns were merged and today bear the name Milton-Freewater, Oregon. The combined cities enjoy a long growing season similar to that of the Willamette Valley that results in the exportation of a variety of foods. Milton-Freewater hosts major fruit and vegetable packing, canning, and freezing

industries. The City also continues to maintain its own electric power company, which provides local residences and businesses with some of the lowest power rates in the Northwest.

ENVIRONMENT

General. Umatilla County is bounded on the north by the Columbia River and the State of Washington, on the east by Union and Wallowa Counties, on the south by Grant County, and on the west by Morrow County. Umatilla County is divided into three watersheds that eventually drain into the Columbia River. The Umatilla River basin drains approximately 75 percent of the County, while the southern portion of the County is drained by the North Fork John Day River and the northern portion is drained by the Walla Walla River.

Topography and Drainage. The general slope of the County is to the north and west, with major drainage flowing to the west and northwest. Elevations gradually rise, as one travels south and east from the Columbia River, to approximately 5,200 feet at the southeast end of the County.

The elevation within the City of Milton-Freewater's Urban Growth Boundary (UGB) ranges from about 930 to 1,480 feet above mean sea level (MSL) and encompasses approximately 2,695 acres. The City has an average elevation of approximately 1,050 feet. In general, the area in the vicinity of the City slopes downward to the northwest. The principle stream draining the area within and near Milton-Freewater is the Walla Walla River located on the eastern edge of the City. The Little Walla Walla River runs through the City and provides drainage on a smaller scale.

Climate. In general the climate in the Milton-Freewater area is mild. The area experiences a four-season climate with cold winters, hot summers, and mild weather during spring and fall. Ordinarily, about 70 percent of the precipitation in the region occurs in the six-month period from October to March. The average annual precipitation for Milton-Freewater is about 14.33 inches. Approximately 12 percent of the precipitation falls in the form of snow and seldom does more than a few inches of snow accumulate at any one time. The average annual snowfall for Milton-Freewater is about 20 inches.

According to National Weather Service records, the average annual temperature is 53.5°F. The highest temperature recorded each year is rarely higher than 100°F and the lowest temperature seldom reaches 0°F.

Soils. The Soil Survey of Umatilla County Area, Oregon (U.S. Department of Agriculture, Soil Conservation Service, 1984) identifies seven general soil categories in the Milton-Freewater area: Walla Walla Silt Loam, Freewater-Urban Land Complex, Freewater Very Cobbly Loam, Nansene Silt Loam, Lickskillet Very Stoney Loam, Oliphant Silt Loam, and Riverwash.

The predominant soil within the City of Milton-Freewater is almost entirely the Freewater-Urban Land Complex. This soil is deep and somewhat excessively drained.

Runoff is slow, and the hazard of water erosion is slight. The permeability of this soil is moderate to a depth of 20 inches and very rapid below this depth.

Air Quality. Air quality within the study area is generally good. The prevailing wind is from the south with good air movement through the Walla Walla Valley. Monthly average wind velocity is 6.4 miles per hour. During the fall, air quality is often reduced by dust from agricultural activities, rangeland and forest fires, and burning of ditches and fields.

Transportation. Transportation to the City of Milton-Freewater is provided by state highways, rail lines, and nearby airports. Milton-Freewater is located on Oregon State Highway 11, ten miles south of Walla Walla, Washington, and about 28 miles northeast of Pendleton, Oregon. U.S. Highway 12 runs through Walla Walla, Washington, and serves as a major east/west corridor across Washington. Rail service in the area is provided by the Union Pacific Railroad through a branch line with sidings located in the City. Air service via regularly scheduled common carrier for passengers and freight is available in Walla Walla and Pendleton. Bus service is available in the City.

WATER SYSTEM HISTORY

Distribution System. Historical information for the City of Milton-Freewater's water distribution system is readily available and includes an electronically produced map of the distribution system. A majority of the historical water system information was obtained from City records and conversations with Howard Moss, former Public Works Superintendent. The system consists of approximately 45 miles of pipe, with 20 percent of the system having been installed in the 1940s or earlier. Water mains range from 2 inches to 20 inches in diameter with materials including asbestos concrete, cast iron, ductile iron, galvanized iron, polyvinyl chloride (PVC), Reinforced Concrete Pressure Pipe (RCPP), and steel pipe. The few areas in the City still served by 2-inch lines were developed in the 1940s. Over the last decade or so, replacement and installations have been completed using C900 PVC pipe.

Prior to the merger of Milton-Freewater, both the Cities of Milton and Freewater operated their own water systems. Shortly after consolidation, the decision was made to operate the systems at separate pressure levels. This decision was made on the belief that the Freewater system would not withstand the higher operating pressures provided by Milton. The pressure difference results from an approximate 65-foot base elevation difference between the north (Freewater) and middle (Milton) reservoirs.

The City of Milton-Freewater currently operates three pressure zones in their distribution system. The north zone serves the north area of the City of Milton-Freewater down to Broadway Avenue. The middle pressure zone covers an area from Broadway Avenue to the south end of the City. The third pressure zone is relatively new and is called the south zone. It serves an area from the southern extent of the City limits to the southern portion of the UGB. The pressure zone layout is shown in Figure 4-1 at the end of Chapter 4. The pressure zones and distribution system are discussed

in greater detail in Chapters 4 and 5. The layout of the existing distribution system is shown on the Water System Map, contained in a pocket at the end of this report.

Water Supply. Prior to 1959, the City obtained its drinking water from a combination of wells and surface water from the Walla Walla River. Currently, the City obtains its water supply from seven groundwater wells (Wells No. 1, 2, 3, 5, 6, 8, and 9). Well No. 1, located at S.E. 9th and Mill, was constructed in 1937 and improved in 1971. It was drilled to a depth of 651 feet and supplies the middle distribution system. Well No. 2, constructed in 1944, is located on S.W. 8th and Columbia and extends to a depth of 902 feet. It also supplies the middle distribution system. In 1946, Well No. 3 was constructed and drilled to a depth of 575 feet. It was refurbished in 1969 and supplies the north distribution system from the intersection of N.E. 1st and Russell Streets. Well No. 3 can also serve the middle distribution system by the opening and closing of specific valves. Well No. 5, constructed in 1936 to a depth of 502 feet, is located on N.E. 5th near Peabody Street and supplies the north system. Well No. 6 is located on N.W. 4th near Lamb Street and was constructed in 1950 to a depth of 952 feet. It also supplies the north distribution system. On Couse Creek Road, near the Walla Walla River, Well No. 8 was constructed in 1965 and improved in 1970. It was drilled to a depth of 1,051 feet and supplies the middle water distribution system. Well No. 9 was drilled in 1951 and improved in 1972. The City of Milton-Freewater acquired this well in 1993 and completed improvements in 1999 to fill a new south-end reservoir. However, Well No. 9 can also pump into the middle distribution system as needed. Well No. 9 is located near S.E. 16th Avenue west of Basket Mountain Road and was drilled to a depth of 913 feet. Locations of the wells are shown in Figure 1-2.

Water Storage Reservoirs. The City of Milton-Freewater currently has three water storage reservoirs, one for each pressure zone. The north reservoir is a 2-million-gallon steel storage reservoir that was constructed in 1960. The base elevation of the reservoir is 1,145 feet above MSL, and the reservoir is approximately 40 feet tall. The full water surface elevation in this reservoir is approximately 1,183 feet above MSL. The reservoir serves the north pressure zone of Milton-Freewater by gravity flow.

The middle reservoir is a 1-million-gallon steel reservoir that was constructed in 1956. The base elevation of this reservoir is approximately 1,210 feet above MSL, and the reservoir is approximately 30 feet tall. The full water surface elevation in this reservoir is approximately 1,238 feet above MSL. The middle reservoir serves the middle pressure zone of Milton-Freewater by gravity flow.


The south reservoir is a 2-million-gallon steel storage reservoir constructed in 1999. The base elevation of this reservoir is approximately 1,444 feet above MSL, and the reservoir is approximately 24 feet tall. The full water surface elevation in this reservoir is approximately 1,466 feet above MSL and serves the south pressure zone of the City of Milton-Freewater by gravity flow. The locations of the City's reservoirs are shown in Figure 1-2.

Booster Pump Station. The City currently has two booster pumps in their distribution system. Both booster pumps are located in the Well No. 9 well house and are used to transfer water from the middle distribution system to the south distribution

system, filling the south reservoir. These pumps are controlled by the water level in the south reservoir. The location of the booster pump station and the Well No. 9 well house is shown on the Water System Map contained in a pocket at the end of this report.

PREVIOUS STUDIES


Two previous studies related to expansion of the City's infrastructure systems, including water, have been developed. The Southside Infrastructure Planning Study (Anderson-Perry & Associates, Inc., 1996) addressed infrastructure needs related to a proposed 50-acre industrial park on the south side of the City. Development of the booster pump station at Well No. 9 and south reservoir was completed to serve this industrial park. A second study, the North Milton-Freewater Utility Study (Anderson-Perry & Associates, Inc., 1999) was developed for Umatilla County in cooperation with the City of Milton-Freewater. This study included options and estimated costs to provide water service to customers north of Milton-Freewater. If the City of Milton-Freewater considers delivering water to this area in the future, the analysis, recommendations, and cost estimates provided in this previous study should be reviewed, modified, and updated as required. Because this previous study was completed for the area north of Milton-Freewater, analysis of water delivery to the areas north of the current City Limits is not addressed in this Water System Master Plan.



CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
LOCATION MAP

FIGURE
1-1

T.5-6 N., R.35-36 E., W.M.
1" = 2000'



| | | |
|--|---|-----------------------|
| | <p>CITY OF MILTON-FREEWATER, OREGON WATER SYSTEM MASTER PLAN RESERVOIR AND WELL LOCATIONS</p> | <p>FIGURE 1-2</p> |
|--|---|-----------------------|

165151

CHAPTER 2

WATER SYSTEM REQUIREMENTS

INTRODUCTION

This chapter presents basic information from which criteria has been developed for evaluating the City's existing water system and for defining and sizing the required components of the system. Information concerning the service area, population projections, water use, and state and federal requirements is presented.

SERVICE AREA

The term "service area" refers to the area being served with water from the City's water system. This study focuses primarily on the existing water service area. The present service area consists of the developed lands within the boundaries of the City Limits and some areas outside the City Limits within the Urban Growth Boundary (UGB) (i.e., south pressure zone). For the purpose of this study, the future service area consists of the present service area and the areas inside the UGB currently served by the water system.

The present UGB of Milton-Freewater encompasses a considerable area that is not likely to be fully developed within the planning period of this study. This includes areas adjacent to State Highway 11 both north and south of town and the upper hills on the east side of the City. If development occurs in these areas, significant water system improvements may be needed similar to improvements completed in 1999 for the south industrial park. Because of the unknown timeframe of such a development, it would be wise to complete a study specific to the development similar to the Southside Infrastructure Planning Study completed in 1999. Such a study could focus in a more detailed manner on the improvements needed to serve the particular area to be developed.

SERVICE POPULATION AND PLANNING PERIOD

In order to estimate the demands that may be placed upon a municipal water system, a determination of the population to be served must be made. Population estimates must be made with reference to time. Projections are usually made on the basis of an annual percentage increase estimated from past growth rates, tempered by future expectations. It is very difficult to accurately predict the population of a community over any extended period of time. The addition or deletion of a major business, industry, or recreation use in the area could significantly affect the population and the overall water system needs.

The period of time over which the population is to be projected usually depends on the type of improvements to be considered. Improvements that will require long-term financing should be designed for no less than the term of the financing. Facilities that are readily expanded or modified are normally designed for a period of 10 to 20 years. Facilities that are not easily modified or expanded, such as buried pipelines and storage

reservoirs, may be designed for their expected life, which is usually 40 to 50 years, or more.

The 2007 population of the City of Milton-Freewater is estimated to be 6,550. Past population trends for the City of Milton-Freewater, comparing data from 1960 through the present, have shown steady growth with a decline in the late 1980s. The 1990s showed steady and continual growth, although the 2000 Census numbers decreased the population count slightly. These historical population trends are shown in Figure 2-1.

The historical population data shown on Figure 2-1 was provided by the Population Research Center at Portland State University. This agency is the official source of population data in Oregon between the official census data generated at the beginning of each decade. The University does not project population increases for individual cities within the state. Therefore, no official projection is available for Milton-Freewater. However, a population projection for Umatilla County through the year 2040 has been prepared by the Oregon Department of Administrative Services, Office of Economic Analysis. They have projected an average annual growth rate for Umatilla County of 0.7 percent.

The population projections for Milton-Freewater shown on Figure 2-1 are at 1.0, 1.5, and 2.0 percent. These growth rates are above the County projections but are likely representative because most of the growth in the County is anticipated to occur in the larger cities. The Wastewater System Study performed in 1998 used a 2.0 percent growth rate. The City of Milton-Freewater has indicated the same growth rate of 2.0 percent should be used for the period of this study. This results in a population in the year 2028 of 9,928 (rounded down to 9,750). It should be recognized, however, that over the planning period of this study, actual growth could exceed or fall well below the figures presented in Figure 2-1.

LAND USE

The City of Milton-Freewater began work on a Comprehensive Plan in 1975, and it was adopted in March of 1980. The first periodic review began on December 2, 1985, and was completed in May of 1987. Amendments to the Comprehensive Plan began in 1987, with the most recent being in August of 1998.

The table below provides descriptions of the zoning classifications established with the latest update to the Comprehensive Plan and that are shown on the Zoning Map contained in a pocket at the end of this Plan.

ZONING CLASSIFICATIONS

| Zoning Code | Description |
|-------------|--|
| R-1 | Low Density Residential (< 4 units per acre) |
| R-2 | Medium Density (up to 16 units per acre) |
| R-3 | High Density Residential (up to 26 units per acre) |
| MSR | Main Street Residential |
| DB | Downtown Business |
| C-1 | Retail and Service Commercial |
| C-2 | General Commercial |
| I-M | Industrial Manufacturing |
| PL | Public Lands |
| CO | Civic Overlay |
| BP | Business Park |
| RM | Residential Mixed Use |
| EFU | Exclusive Farm Use |
| F-1 | Farm Use |
| RSC | Retain Service Commercial |

Commercial areas are primarily located along Highway 11, running north and south through the City, and along the Main Street/Broadway areas of old Freewater. Residential areas are to the outside of the north/south corridor of Highway 11 and surround the City Center area of old Freewater. Industrial areas are located to the south end of the City of Milton-Freewater, with the majority located along the railroad tracks through the old Freewater section of town.

Undeveloped areas are present within the City of Milton-Freewater, primarily to the south and north. Undeveloped area within the City Limits west of town will likely remain undeveloped due to the steep slope of the terrain. Large, undeveloped areas to the south and northeast are also present within the current UGB. The City anticipates that there is adequate land available within the UGB for all projected growth to and possibly beyond the year 2028.

As stated earlier, some of these undeveloped areas, especially the steeper hillsides on the east side and extreme south side of the City, would likely require significant water system improvements and other infrastructure improvements if these areas are to be adequately served. Potential demands on infrastructure are a very important factor to consider when analyzing infrastructure capacity to meet current and future needs. If these areas are to be developed, information in this Water System Master Plan should be reviewed and updated, as required, to consider the demands placed on the water system. It would also be prudent to complete a more detailed infrastructure study specific to the area to be developed to better assess infrastructure needs.

REGULATORY REQUIREMENTS

The City of Milton-Freewater's water system comes under the jurisdiction of two water quality regulating agencies. The first is the U.S. Environmental Protection Agency (EPA) and the second is the Oregon Department of Human Services - Drinking Water Program (DWP). The State of Oregon assumed primacy (responsibility) in February 1986 for enforcement of the federal Safe Drinking Water Act (SDWA). Therefore, the City of Milton-Freewater is currently and will be dealing principally with the DWP as the regulating agency for their water system.

Regulatory History. The federal "Interim Primary Drinking Water Regulations" went into effect in 1977 as a result of the Safe Drinking Water Act of 1974 (Public Law No. 93-523). The primary regulations address requirements concerning elements, trace minerals, compounds, and micro-organisms that may affect the health of water consumers. The Act provides for monitoring, testing requirements, reporting, recordkeeping, and public notification procedures in the event of non-compliance. These regulations have necessitated the revision and upgrading of many water systems to meet the requirements of the Act.

1986 Amendments to the Safe Drinking Water Act. The United States Congress first enacted the Safe Drinking Water Act in 1974. In 1986, amendments became effective that required the EPA to develop additional rules for drinking water with which water purveyors must comply. As the new rules were developed, the Drinking Water Program has been adopting them. The following describe the impacts of the EPA Administrative Rules:

1. Considerably increased the number of samples and tests the City will have to perform for regulated and unregulated contaminants.
2. Required continuous disinfection of surface water supplies and groundwater supplies when used in conjunction with surface water.
3. Required filtration of most surface water sources.
4. Initiated expanded monitoring for all systems.
5. Changed current public notification requirements.
6. Ensured more aggressive enforcement on the part of the EPA.

Prior to the 1986 amendments, maximum contaminant levels (MCLs) had been set by the EPA for 22 regulated contaminants. The 1986 amendments contain a list of 83 contaminants to be regulated. These include volatile organic compounds (VOCs), synthetic organic chemicals (SOCs), trihalomethanes (THMs), 6 contaminants related to microbiology and turbidity forms, 18 inorganic contaminants, 40 organic contaminants, and 5 radionuclides. A majority of these contaminants were regulated by the EPA as of June 1989 and the state adopted the regulations in 1991.

In the 1986 amendments, congress directed the EPA to add 25 contaminants to the list every three years. The 1996 reform bill (discussed later in this section) changed this requirement, allowing the EPA to consider adding only five contaminants to the list every five years. Therefore, the list of contaminants the City will have to test for may not expand as rapidly as before, but will likely continue to expand in the future. Additionally, amendments for disinfection requirements will be adopted in the future. With the growing list of regulated contaminants, communities will be faced with the responsibility of more sampling and testing in order to remain in compliance.

The EPA has developed regulations that will provide for different types and frequency of public notification of violations based on the frequency and severity of the violation. The revised public notification requirements included in the 1986 amendments, which took effect in April 1989, require water systems to notify the persons they serve when the following instances occur:

1. When a violation of a National Primary Drinking Water Regulation or its monitoring requirements occurs.
2. When variances or exemptions are in effect.
3. When the water system does not comply with any schedule associated with a variance or exemption.

The DWP has responsibility for administering the public notification system for public water systems in Oregon. They work closely with public water systems to make sure public notification is made in accordance with regulatory guidelines, when required.

The 1986 amendments also forbid the use of pipe, solder, or flux that is not "lead-free" in public water systems or any plumbing connected to a public water system after June 1988. Lead-free is defined as 8 percent or less lead for pipes and fittings and 0.2 percent or less lead for solder and fluxes. This requirement is not intended to affect any pipe, fittings, etc., already in place. However, those systems with lead materials in their distribution systems must provide notice to "persons that may be affected by lead contamination of their drinking water." This notice must be provided even if lead concentrations in the water do not violate allowable concentrations. This provision does not apply to leaded joints necessary for the repair of cast iron pipes.

Safe Drinking Water Act Reform Bill. On August 6, 1996, the Safe Drinking Water Act reform bill was signed. The SDWA amendments of 1996 gave the EPA new ranking orders for developing rules to ensure the safety of public water supplies. The law emphasizes controlling the greatest risks at the best price, preventing contamination of source water, informing consumers annually of contaminant levels and health effects, and providing states with new flexibility to implement regulations and small systems compliance relief and assistance. Some of the key items of the reform bill that have already been passed into law are summarized below.

1. **Operator Certification**, which requires every water supplier to employ an operator to supervise the water system. The operator is required to be

certified at a grade equal to the classification of the water system. Milton-Freewater has several certified operators with the primary operator being Dave Bradshaw, Public Works Superintendent.

2. **Consumer Confidence Report (CCR)**, which requires community water systems serving 15 or more year-round customers to prepare an annual CCR to provide customers with information about the quality of their drinking water. Annual CCR reports were first due in October 1999 and the City has distributed reports annually, as required.
3. **The Arsenic Rule**, which became effective in March 2001, lowers the MCL for arsenic allowed in a community water system from 50 parts per billion (ppb) to 10 ppb. Testing in 2003 and 2005 resulted in no detection of arsenic.
4. **The Disinfectants/Disinfection By-product Rule (D/DBPR)**, which reduces levels of disinfectants and DBPs in drinking water supplies to provide public health protection from exposure to trihalomethanes, haloacetic acids, chlorite, and bromate. This rule applies to community water systems that treat their water with a chemical disinfectant, such as chlorine, for either primary or residual treatment. Required sampling was completed in 2007 and submitted to the DWP.
5. **The Groundwater Rule**, which specifies the appropriate use of disinfection while addressing other components of groundwater systems to ensure public health protection. This rule became a law in October 2006. The law requires groundwater systems to be evaluated on a case-by-case basis to determine if the system is susceptible to fecal contamination and whether or not disinfection is necessary. Source water monitoring may be required if coliform test results indicate a presence of coliforms.
6. **Radionuclides Rule**. Regulations for radionuclides in drinking water were first discussed in 1976 as interim regulations under the authority of the 1974 SDWA. The 1986 and 1996 SWDA amendments revised the rule, and the revised Radionuclides Rule was published on December 7, 2000. The Radionuclides Rule sets standards for beta and photon emitters, radium (radium-226 and radium-228), gross alpha radiation, and uranium.

The DWP accepted radionuclide data collected prior to December 8, 2003, to substitute for the Initial Compliance Monitoring required by the rule. Water systems had to monitor once at each supply point to the water system for gross alpha, combined radium-226/228, and uranium by December 8, 2003, in order to avoid the four consecutive quarterly samples. The City of Milton-Freewater most recently sampled for radionuclides in May 1996. Radionuclides were detected in four of nine samples at concentrations well below the MCL.

Another key item of the 1996 reform bill that is not yet law, but is anticipated to be law in the near future, is the following:

The Radon in Drinking Water Rule, which attempts to reduce airborne and waterborne radon concentrations to limit exposure levels. This rule will apply to community water systems serving 25 or more people that use groundwater or mixed ground and surface water.

Public Health Security and Bioterrorism Preparedness and Response Act of 2002. The Safe Water Drinking Act requires that communities with water systems serving greater than 3,300 people conduct assessments of the vulnerability of their systems to terrorist attacks or other intentional acts to disrupt water delivery to the community. In addition to the vulnerability assessments, the Act addresses Emergency Response Plans. Oregon Administrative Rule (OAR) 333-061-0064 has been developed by the DWP to implement the measures prescribed in the federal act. This rule required all public water systems to develop Emergency Response Plans by June 30, 2005. The City of Milton-Freewater has completed an Emergency Response Plan and notified the DWP of its completion in June 2004. The Emergency Response Plan should be reviewed and updated at least every five years.

Regulatory Violations. The City of Milton-Freewater has good water quality with a well run water system operation meeting federal and state water quality criteria. The DWP has issued nine violations against the City in the past seven years related to two coliform events (not enough reported) and late chemical/non-reporting (seven events). Corrective action was taken in each case and the City is in compliance. These violations are documented in the DWP's Water Quality Summaries presented in Appendix A.

Regulatory Requirements Summary. In summary, many regulations affect operation of the City of Milton-Freewater's water system. The information presented herein is intended to provide the City with a brief summary of the regulations and possible future regulations that will likely affect operation of the City's water system. In general, it appears the City is keeping up to date with water testing and reporting requirements. Water system regulations continue to expand and will require careful attention to maintain future compliance. It is recommended that the City of Milton-Freewater consult with the DWP in Pendleton, Oregon, if any regulatory questions or issues arise.

SANITARY SURVEY

The DWP conducts sanitary surveys of communities to assist in identifying potential contamination sources that may impact water quality. These surveys are generally scheduled to occur every five years.

The City of Milton-Freewater's latest Sanitary Survey was conducted on January 16, 2009. The primary findings of the survey are summarized below:

- All deficiencies noted in the April 20, 2004, Sanitary Survey have been corrected.
- The City needs to submit to DWP a completed Water System Master Plan. This deficiency was addressed in March 2009.

A copy of the full Sanitary Surveys for 2004 and 2009 are included in Appendix B.

The DWP has also published a checklist of Sanitary Survey significant deficiencies (included in Appendix B) for City staff to periodically review and address any deficiencies found. This allows the City to take a proactive approach to these surveys.

WATER DEMAND

For the purpose of identifying needed future water system improvements, future water demands can be estimated from past water use characteristics and future population projections. Water use characteristics are usually expressed in terms of various rates of water used for various periods of time. This allows components of the water system to be sized for the maximum demands that will be placed on them. The rates of water use that are important in evaluating a water supply system are:

- **Average Daily Demand (ADD)** – The ADD is the total amount of water used in a year divided by 365 days. ADD is presented as gallons per person per day, or gallons per capita day. This is the average amount of water used by each person each day of the year.
- **Peak Daily Demand (PDD)** – The PDD is the maximum total amount of water used during any 24-hour period. PDD is presented as gallons per person per day, or gallons per capita day. This is the peak daily amount of water used by each person on the highest water use day of the year. The highest water use day of the year normally occurs during the warmer summer months when irrigation uses are at their highest.
- **Peak Hour or Peak Instantaneous Demand (PHD)** – The PHD is a measure of the maximum flow of water at any given time, often over a 1-hour period. The peak hour demand normally occurs during the warmer summer months of the year.

Water supply facilities are normally designed for peak daily demands. A well or wells would normally be sized for supplying the needed water during the peak day, without continuous 24-hour operation. For example, if the water usage during high use summer months was high enough to require wells to pump 18 hours or more per day to keep up with the peak daily demand, the situation may warrant the addition of another well or other water supply source in order to provide some backup capability. Booster pumps and distribution pipelines are typically sized to deliver peak instantaneous demands. Because peak instantaneous demands often exceed the available supply,

storage reservoirs are sized to include a storage amount to make up the difference between water supply capacity and peak water use rates.

To be utilized for projecting future water demands, past water use characteristics must be converted to a per capita (per person) rate of use. This is done by dividing the average day, maximum day, and peak instantaneous water use rates by the number of people being served by the water system. These water demand rates would then be expressed as gallons per capita day (gpcd). This value multiplied by a population projected for some future year gives the estimated total demand rates for that year.

In order to determine current water demand, City well pumping records from October 2000 through September 2007 were reviewed. Monthly well production for each City well for the period October 2000 through September 2007 is shown in Figures 2-2 to 2-8. These records show typical patterns of high summer demand and low fall, winter, and spring demand. Figure 2-9 shows monthly well production for all wells from October 2000 through September 2007. Figure 2-10 summarizes water production for all wells for each water year (October through September). Figure 2-10 shows the City is more recently relying primarily on Wells No. 2, 3, 5, 6, and 9 to meet demands while Wells No. 1 and 8 are rarely used.

Based on the data presented in these figures and shown below, determination of the City's average water use is as follows:

AVERAGE WATER USE

| Year (October to September) | Total Water Pumped (gallons) | City Population* | Calculated Average Water Use (gpcd) |
|-----------------------------------|------------------------------------|------------------|---|
| 2000-01 | 834,043,000 | 6,560 | 348 |
| 2001-02 | 885,720,000 | 6,450 | 376 |
| 2002-03 | 916,211,000 | 6,500 | 386 |
| 2003-04 | 907,584,000 | 6,500 | 381 |
| 2004-05 | 825,250,000 | 6,540 | 346 |
| 2005-06 | 679,488,000 | 6,585 | 283 |
| 2006-07 | 704,993,000 | 6,550 | 295 |

* Data provided by Population Research Center at Portland State University.

Based on the data for water years 2000-01 through 2006-07, the City's average "gallons per capita day" water use has varied from a low of 283 gpcd to a high of 386 gpcd. The average of the six values shown in the table is 345 gpcd. The City indicated the recent last two years of water use data are the most representative of future expected use amounts. Therefore, an average daily flow of 300 gpcd was selected for design purposes. The City of Milton-Freewater's 300 gpcd average water demand is in

the upper range of demands when compared to other cities in Eastern Oregon and Washington, as shown in Table 2-1.

To estimate the peak daily demand for the City's water system, a peak factor of 2.5 was utilized. The peak factor is a ratio of the average daily demand to the peak daily demand. Analysis of water use characteristics of several other Eastern Oregon and Washington cities during preparation of their master plans has shown that the average peak factor is 2.5. Utilizing this peak factor, the City of Milton-Freewater's peak daily demand would be 2.5 times 300 gpcd, or 750 gpcd. A peak daily demand of 750 gpcd, assuming a population of 6,550, equates to a peak daily demand flow rate of 3,411 gallons per minute. A peak daily demand of 750 gpcd will be used for planning purposes in this Master Plan.

FIRE DEMAND

Fire flow tests were performed on some of the City's fire hydrants on April 8, 1987, by ISO Commercial Risk Services, Inc. (ISO). The results of the hydrant tests are summarized in Table 2-2, and presented in Appendix C. The observed and calculated fire flow discharges available from the hydrants tested are shown. The observed test results indicate that the City of Milton-Freewater's water system can deliver fire flows ranging from approximately 580 to 2,090 gpm, with residual pressures remaining well above the minimum required 20 pounds per square inch (psi).

The fire flow test results also utilize a theoretical formula to estimate available fire flows, which are much higher, as shown on Table 2-2. It should be noted that these theoretical fire flow rate projections by ISO were determined assuming a 20 psi residual pressure. The formula assumes the 20 psi residual pressure will occur in the immediate vicinity of the fire hydrant. In reality, there may be other connections in the distribution system, such as higher elevation users in the City, that would fall below 20 psi sooner than the formula predicts due to their elevation. Therefore, the actual available fire flows are most likely less than those shown as "available" on Table 2-2. It should also be noted that individual fire hydrants are generally only capable of providing flows of 1,500 to 2,000 gpm, and multiple hydrants would need to be used to achieve higher flow rates. Further discussion of these fire flow constraints is presented in Chapter 5, Distribution System.

Flow rates for fire suppression in residential, commercial, and industrial areas within developed communities are usually determined from the size, density, and occupancy of buildings, type of construction materials, and the desired fire insurance rating. Incorporated cities and some rural areas are given a fire suppression rating by ISO. The rating is often used by insurance companies to determine the cost for providing fire insurance to home and business owners. ISO's fire suppression rating schedule is used to review those features of available public fire protection that have a significant influence on minimizing damage once a fire has occurred. These features include the receiving and handling of fire alarms, the fire district's manpower, equipment and training, and the capability of the water system to provide the needed fire flows.

ISO periodically evaluates fire suppression capabilities of incorporated cities and rural fire districts. The numerical ratings range from Class 1 down to Class 10, with a Class 1 indicating the highest fire suppression capability and Class 10, the lowest. A Class 10 rating is reserved for unprotected areas that have no fire department and no water supply system. Most protected areas outside of cities have a Class 9 rating, and most small rural cities with municipal water systems are rated Class 8, 7, or 6, depending on the strength of their water system and fire department. The ISO rating for Milton-Freewater, based on the April 8, 1987, tests, is Class 4, which is a good rating for a rural community the size of Milton-Freewater. Again, the ISO rating information is presented in Appendix C.

ISO's fire suppression rating schedule evaluates the City's capability and the domestic water supply on an approximately equal basis (50 percent and 40 percent of the rating schedule, respectively). In order to reduce the cost of fire insurance in a community, improvements usually must be made to the fire department, the water system, or both, depending on their present condition. It is difficult to determine possible fire insurance savings on commercial buildings, because the insurance costs are determined by many other factors related to the type of occupancy and the type of building construction. When implemented, the proposed improvements outlined in this study could reduce water system deficiencies and possibly improve the City's ISO fire protection rating. However, the City of Milton-Freewater already has a good rating, and improving the rating may be difficult.

ISO also recommends fire flows for various conditions in both residential and commercial settings. Recommended fire flows for residential areas are set forth in the 1980 ISO Schedule as shown below.

| Distance Between Buildings | Required Fire Flows |
|-----------------------------------|----------------------------|
| Over 500 feet | 500 gpm |
| 31 to 100 feet | 750 gpm |
| 11 to 30 feet | 1,000 gpm |
| 10 feet or less | 1,500 gpm |

Recommended fire flows for commercial buildings are based on many factors including building size, construction materials used, and what is housed in the building.

The Uniform Fire Code (UFC) requires a flow of 1,000 gpm in residential areas and 1,500 gpm for 2 hours minimum in all other occupancies. These requirements increase with square footage of the building and can be quite large for commercial and institutional buildings (i.e., schools). These fire flows must be maintained with a system-wide minimum of 20 psi residual pressure. Based on the fire flow tests shown in Table 2-2, it appears the City is meeting the elevated fire flow requirements of the commercial and institutional buildings where tests were performed. However, attaining the required fire flows for areas on the outskirts of town with high flow requirements may require substantial improvements to the water system in Milton-Freewater. The City is encouraged to evaluate the existing water system with any new commercial, industrial, or institutional buildings being developed in the City to identify distribution system improvements that may be required to facilitate the new development. The UFC does

have an allowance for decreases in fire flows for small communities (if approved by the local fire chief), where development of full fire flow is impractical.

As shown by the ISO tests, the minimum fire flow protection recommended by ISO is 750 gpm for residential areas. ISO recommends a maximum fire flow requirement of 3,500 gpm. The fire flow design criteria for this Water System Master Plan are based on the maximum fire flow recommended by ISO, which is a 3,500 gpm fire flow for a two-hour duration.

DESIGN CRITERIA

In establishing design standards for a water system, primary consideration must be given to state and federal rules and regulations governing water quality and construction standards for water systems. As stated previously, these regulations are set by both the EPA and the DWP. In addition to these public health and safety requirements, many other factors control the design parameters for municipal water systems. The City must evaluate factors such as financial feasibility, philosophy and policies of the City Council, past system performance and service, and expectations of the water users. All of these factors are important and can influence the standards by which water system improvements are made.

Tables 2-3 and 2-4 present a summary of the water system design criteria for evaluating the existing water system and developing improvements to satisfy present and future needs. The application of these criteria is discussed further in the specific chapters that address the water supply, storage, and distribution system facilities. The tables present design criteria based on the present service population of 6,550, present estimated average and maximum daily demands, and present the year 2028 design criteria based on a 2.0 percent growth per year in the area. The storage volumes presented in Table 2-4 are explained and developed in Chapter 4.

COMPARATIVE WATER USAGE
TYPICAL FOR SMALL CITIES IN
EASTERN WASHINGTON AND EASTERN OREGON

METERED SYSTEMS

| City | Average Daily Flow (gpcd) | Peak Daily Flow (gpcd) | Peak Factor (peak daily) | Population |
|---------------------------------|--|---------------------------------------|-------------------------------------|-------------------|
| Hermiston, Oregon | 170 | 410 | 2.4 | 12,165 |
| Island City, Oregon | 190 | 550 | 2.9 | 925 |
| Adams, Oregon | 195 | 625 | 3.2 | 265 |
| Irrigon, Oregon | 200 | 600 | 3.0 | 900 |
| Baker City, Oregon | 215 | 660 | 3.1 | 10,155 |
| Stanfield, Oregon | 217 | 705 | 3.2 | 1,620 |
| Prairie City, Oregon | 234 | 549 | 2.3 | 1,195 |
| Mt. Vernon, Oregon | 240 | 585 | 2.4 | 617 |
| Prescott, Washington | 240 | 1,032 | 4.3 | 300 |
| Athena, Oregon | 250 | 810 | 3.2 | 1,120 |
| La Grande, Oregon | 266 | 735 | 2.8 | 12,885 |
| John Day, Oregon | 270 | 864 | 3.2 | 2,010 |
| Milton-Freewater, Oregon | 300 | 750 | 2.5 | 6,550 |
| Helix, Oregon | 323 | 1,130 | 3.5 | 155 |
| Vale, Oregon | 328 | 820 | 2.5 | 1,500 |
| Arlington, Oregon | 360 | 1,200 | 3.3 | 500 |
| Ione, Oregon | 461 | 1,865 | 4.0 | 250 |
| Ontario, Oregon | 530 | 1,015 | 1.9 | 10,910 |

ISO FIRE FLOW TESTS

April 8, 1987

| Test No. | Location (Intersection) | Pressure (psi) | | Discharge (gpm) | | | Remarks |
|----------|---|----------------|-----------------------|-----------------|--------------------|-------------------|--------------------------------|
| | | Static | Residual ¹ | Observed | Available @ 20 psi | Required @ 20 psi | |
| 1. | S.E. 15th Avenue and S. Main Street | 89 | 53 | 1,590 | 4,400 | 2,500 | 12-inch Main, Middle Reservoir |
| 2. | S.W. 13th Avenue and Davis Street | 42 | 37 | 1,030 | 2,300 | 1,000 | 6-inch Main, Middle Reservoir |
| 3. | S.W. 6th Avenue and S. Main Street | 77 | 70 | 1,820 | 5,600 | 1,750 | 12-inch Main, Middle Reservoir |
| 4. | S.W. 2nd Avenue and DeHaven Street | 89 | 80 | 2,040 | 6,100 | 3,000 | 12-inch Main, Middle Reservoir |
| 5. | E. Broadway Avenue east of S. Main Street | 68 | 60 | 1,690 | 4,400 | 2,250 | 8-inch Main, North Reservoir |
| 6. | N.W. 6th Avenue and Evans Street | 80 | 78 | 2,090 | 13,100 | 3,000 | 8-inch Main, North Reservoir |
| 7. | N.W. 7th Avenue and Lamb Street | 80 | 75 | 2,000 | 7,700 | 2,500 | 12-inch Main, North Reservoir |
| 8. | Lamb Street south of Powell Road | 89 | 74 | 1,870 | 4,300 | 1,250 | 6-inch Main, North Reservoir |
| 9. | N.W. 8th Avenue and Main Street | 83 | 79 | 1,090 | 4,800 | 3,000 | 12-inch Main, North Reservoir |
| 10. | N.E. 5th Avenue and Russell Street | 73 | 70 | 1,400 | 6,600 | 1,750 | 12-inch Main, North Reservoir |
| 11. | N. Elizabeth Street south of N.E. 6th Court | 76 | 71 | 2,050 | 7,600 | 1,000 | 12-inch Main, North Reservoir |
| 12. | N.E. 10th Street and N. Elizabeth Street | 81 | 78 | 580 | 3,000 | 2,500 | 12-inch Main, North Reservoir |
| 13. | N. Columbia Street north of N.E. 1st Avenue | 65 | 58 | 1,640 | 4,500 | 2,500 | 8-inch Main, North Reservoir |

Footnotes: ¹ Residual pressures of 20 psi are required by ISO and by the DWP.

ISO = ISO Commercial Risk Services, Inc.

DWP = Oregon Department of Human Services - Drinking Water Program

G:\Clients\Milton-Freewater\Water\200-53\Reports\WSMP\Table 2-2.wpd

**SUMMARY OF DESIGN CRITERIA
WATER SUPPLY**

| | Year 2008 | Year 2028 |
|---|------------------------------|------------------------------|
| Design Population ¹ | 6,550 | 9,750 |
| SUPPLY | | |
| Average Daily Demand | 300 gpcd | 300 gpcd |
| Average Daily Flow | 1,965,000 gpd (1,364 gpm) | 2,925,000 gpd (2,031 gpm) |
| Peak Daily Demand ² | 750 gpcd | 750 gpcd |
| Peak Daily Flow ² | 4,912,500 gpd (3,411 gpm) | 7,312,500 gpd (5,078 gpm) |
| Peak Hourly Flow ³ | 8,528gpm | 12,695 gpm |
| Supply Flow Required ⁴ | 4,548gpm | 6,771 gpm |
| Available Supply Flow ⁵ | 7,520 gpm | 7,520 gpm |
| Fire Demand | | |
| Residential | 750 gpm | 750 gpm |
| Commercial/Public/Industrial | 2,000 - 3,500 gpm | 2,000 - 3,500 gpm |
| Duration | 2 hrs | 2 hrs |
| Minimum Residual Line Pressure Under Peak Demands Plus Fire Flow | | |
| | 20 psi | 20 psi |

Abbreviations:

gpd = gallons per day
gpcd = gallons per capita per day
psi = pounds per square inch
gpm = gallons per minute
hrs = hours

Notes:

¹ Year 2008 population is July 1, 2007, projection by Portland State University Population Research Center
² Based on peak daily flow records for 2007
³ 2.5 times peak daily demand (hourly records not available)
⁴ Assumes 18-hour maximum well operation per day to meet peak daily flow demand
⁵ Sum of all City wells' production capacities

**SUMMARY OF DESIGN CRITERIA
FOR STORAGE RESERVOIRS¹**

| | <u>Year 2028</u> |
|---|---------------------------|
| Design Population | 9,750 |
| NORTH SYSTEM STORAGE REQUIREMENTS | |
| Equalization Storage | 404,700 gal. ² |
| Operating Storage | 190,400 gal. |
| Fire Reserve (3,500 gpm, 2-hour duration) | 420,000 gal. |
| Emergency Reserve | <u>1,413,000 gal.</u> |
| Total, North | 2,428,100 gal. |
| MIDDLE SYSTEM STORAGE REQUIREMENTS | |
| Equalization Storage | 371,700 gal. |
| Operating Storage | 128,700 gal. |
| Fire Reserve (3,500 gpm, 2-hour duration) | 420,000 gal. |
| Emergency Reserve | <u>1,413,000 gal.</u> |
| Total, Middle | 2,333,400 gal. |
| SOUTH SYSTEM STORAGE REQUIREMENTS | |
| Equalization Storage | 0 gal. |
| Operating Storage | 338,400 gal. |
| Fire Reserve (3,500 gpm, 2-hour duration) | 420,000 gal. |
| Emergency Reserve | <u>99,000 gal.</u> |
| Total, South | 857,400 gal. |
| TOTAL STORAGE REQUIREMENTS | |
| Equalization Storage | 776,400 gal. |
| Operating Storage | 657,500 gal. |
| Fire Reserve | 1,260,000 gal. |
| Emergency Reserve | <u>2,925,000 gal.</u> |
| TOTAL | 5,618,900 gal. |

Notes:

¹ Storage requirements are explained and developed in Chapter 4, Water Storage

² gal. = gallons

City of Milton-Freewater, Oregon Historical and Projected Population





FIGURE 2-1

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
HISTORICAL AND PROJECTED
POPULATION



**City of Milton-Freewater, Oregon
Well No. 1 Monthly Production**



**FIGURE
2-2**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 1
MONTHLY PRODUCTION



City of Milton-Freewater, Oregon
Well No. 2 Monthly Production





FIGURE
2-3

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 2
MONTHLY PRODUCTION



**City of Milton-Freewater, Oregon
Well No. 3 Monthly Production**




**FIGURE
2-4**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 3
MONTHLY PRODUCTION



**City of Milton-Freewater, Oregon
Well No. 5 Monthly Production**




**FIGURE
2-5**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 5
MONTHLY PRODUCTION



**City of Milton-Freewater, Oregon
Well No. 6 Monthly Production**




**FIGURE
2-6**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 6
MONTHLY PRODUCTION



**City of Milton-Freewater, Oregon
Well No. 8 Monthly Production**




**FIGURE
2-7**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 8
MONTHLY PRODUCTION



**City of Milton-Freewater, Oregon
Well No. 9 Monthly Production**



**FIGURE
2-8**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WELL NO. 9
MONTHLY PRODUCTION



City of Milton-Freewater, Oregon
Total Monthly Production





FIGURE
2-9

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
TOTAL MONTHLY PRODUCTION



**City of Milton-Freewater, Oregon
Summary of Annual Water Production**



**FIGURE
2-10**

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
SUMMARY OF ANNUAL
WATER PRODUCTION



CHAPTER 3

WATER SUPPLY AND TREATMENT

INTRODUCTION

This chapter includes a description of the City's present water supply system and a discussion of its capacity to meet present and future needs. Recommendations to address needs of the present system and for meeting future needs are outlined. Cost estimates for the recommendations are presented in Chapter 6, Recommended System Improvements.

PRESENT WATER SUPPLY

The City of Milton-Freewater draws water from basalt aquifers using seven wells ranging in depth from 502 feet to 1,051 feet. Generally, the City's wells provide good quality water; however, the City has experienced an entrained air problem with some of the wells. The City also has a surface water right to the Walla Walla River with a priority date of 1887 that has not been used for almost 50 years. In the past, the City used a sand filter treatment facility to provide treatment of Walla Walla River water prior to supplying the water to City users. The treatment plant was abandoned because of rising operating costs.

Additional detail and a history of the improvements made to the City's water sources is outlined hereafter.

City Wells. General information related to the City's wells is provided on Table 3-1, and the location of each well is presented on Figure 1-2 in Chapter 1. Appendix D also contains well logs for each of the City's wells. The following information is provided in order to summarize maintenance that has been completed and problems that have arisen with each of the City's wells, and their current status.

Well No. 1. Well No. 1 was extended 15 feet in 1971 to a depth of 651 feet and rehabilitated by the Layne Bowler Pump Company. The well is one of the oldest in town and is currently not regularly operated to meet City demands due to an air entrainment problem.

Well No. 2. Well No. 2 was rehabilitated in May of 1988 by the Layne Pump Company. The well was shut down in 1993 due to aeration problems developing in the water. This well has been continually monitored by the City since it developed air entrainment in 1990. It has been videotaped several times in order to determine the source of the air entrainment. A separate discharge line was routed from Well No. 2 to the Middle Reservoir in 2001 to facilitate removal of entrained air. Well No. 2 is currently used to provide 15 to 23 percent of the City's water supply.

Well No. 3. Well No. 3 was rehabilitated in January of 1991 and shut down in March of 1993 due to aerated water problems. An attempt to seal the aquifer

and set the pump column to a greater depth was undertaken after the well was taken off line. However, the sealing effort failed to stop the aeration problem and a new transmission line was constructed in 1999 to allow the well to discharge to the North Reservoir, as discussed in the Air Entrainment section later in this chapter. Well No. 3 is currently used to provide 20 to 22 percent of the City's water supply.

Well No. 5. Well No. 5 was deepened 10 feet in 1980. The well was rehabilitated in 2000. It is believed that the principal aquifer is located in the bottom 30 feet of the hole (below 470 feet depth). This is the oldest well in the City and saw increased production in 1998 and 1999, accounting for approximately 30 percent of the City's annual water production during that period. This well developed air entrainment problems in September 2000 and a separate discharge into the North Reservoir was constructed in 2001. Well No. 5 is currently used to provide about 14 to 17 percent of the City's water supply.

Well No. 6. Well No. 6 was rehabilitated in 1992. The hole is crooked and placing the original column was difficult. Well No. 6 also developed air problems and a separate discharge into the North Reservoir was constructed in 1999. This well is currently used to provide about 21 to 25 percent of the City's water supply.

Well No. 8. Well No. 8 was originally 888 feet deep and was deepened to 1,051 feet in 1970, becoming the City's deepest well. The well was rehabilitated in 1969 and 1970. This well is the most recently drilled well in the City and currently provides very little supply because it is the least efficient well to operate.

Well No. 9. Well No. 9 was acquired by the City in 1993 after previously being owned and operated by the Umatilla Canning Company. The last rehabilitation of the well was completed in 1997. This well serves both the Middle and South Pressure Zones through separate control systems for the primary pump and a separate set of booster pumps. The primary pump is controlled by system controls at the Middle Reservoir while the booster pumps are controlled by system controls at the South Reservoir. Well No. 9 is currently used to provide about 20 to 23 percent of the City's water supply.

Surface Water. The City's surface water diversion and treatment system on the Walla Walla River was last used in 1959. When it was used, the water was treated via a slow sand filter plant with a 1,200 gallon per minute (gpm) capacity. The plant was shut down due to comparatively high water production costs and water quality limitations. The plant continues to be inoperative at this time.

Treatment. Currently, the City has chlorine treatment facilities in place for all active supply wells. All of the City's seven wells (Wells No. 1, 2, 3, 5, 6, 8, and 9) have hypochlorite disinfection systems.

Controls. Operation of each of the wells is controlled by pressure transducers located in the respective pressure zone reservoirs. The transducer systems of each reservoir are routed to a transmitter via dedicated overhead phone lines. The City has

indicated that it is pursuing replacement of the existing telephone-based telemetry system with a radio system.

The North Pressure Zone wells, consisting of Wells No. 3, 5, and 6, are controlled by water levels in the North Reservoir. The primary well (Well No. 3) is activated when the reservoir water level drops 7 feet below full. If the level continues to drop to 13 feet below full, the secondary well pump (Well No. 6) is activated. If the reservoir water level drops to 20 feet below full, the pump of Well No. 5 is activated. As the reservoir is filled, pumps are deactivated until the primary pump is the only one pumping, which turns off when the water level reaches within 3 feet of the reservoir's full capacity.

The Middle Pressure Zone wells, consisting of Wells No. 1, 2, 8, and 9, are controlled by water levels in the Middle Reservoir. The primary well (Well No. 2) is activated when the reservoir water level drops 4.5 feet below full. If the water level continues to drop to 7.5 feet below full, the Well No. 8 or 9 pump is activated. The final pump (either Well No. 8 or 9) is activated when the water level drops 10.5 feet below full. As the reservoir is filled, pumps are deactivated until the primary pump is the only one pumping, which turns off when the water level reaches within 1.5 feet of the reservoir's full capacity. Well No. 3 can also be used to provide water supply to the Middle Pressure Zone.

The South Pressure Zone supply, consisting of two booster pumps located in the Well No. 9 well house, is controlled by water levels in the South Reservoir. The pumps are alternately activated when the reservoir water level drops 17.5 feet below full. If the level continues to drop to 18.5 feet below full, the second booster pump is activated. As the reservoir is filled, the booster pumps are deactivated until the water level reaches 13.5 feet below the full reservoir capacity and both pumps are turned off. The reservoir is currently operated in this fashion to ensure high water quality, and operation levels will be adjusted as demand increases in the South Pressure Zone. In order to adequately exchange water in the South Reservoir, a constant 40 gpm flow passes through a pressure reducing valve from the higher elevation South Pressure Zone to the Middle Pressure Zone.

Water Supply Taste/Odor Issues. Generally, the City of Milton-Freewater has a good water supply without significant taste or odor problems. Occasionally a complaint of stagnant water is received, which is resolved by City crews flushing lines in areas with inadequate looping. The City also receives approximately 20 complaints per year of chlorine odor in areas of dead-end distribution lines. These complaints are similarly resolved by flushing lines.

Though not a taste or odor problem, the City has had complaints of water with a "milky" appearance. This began when wells first started pumping air-entrained water into the distribution system during periods of heavy pumping. Water transmission lines have been constructed from Wells No. 2, 3, 5, and 6 to feed directly to the reservoirs, allowing the air to dissipate at atmospheric pressure in the reservoirs.

WATER RIGHTS

The City of Milton-Freewater holds groundwater and surface water rights issued by the State of Oregon for each of its supply sources. Copies of these water rights are included in Appendix E. All of the City's wells are utilized at a rate less than the allowed flow volume under the associated water rights. A summary of the water rights information is listed in the following table.

WATER RIGHTS

| Water Source | Application Number | Permit Number | Certification Number | Allowed Flow Volume (cfs/gpm)* | Priority Date |
|-------------------|--------------------|-----------------|----------------------|--------------------------------|-------------------|
| Well No. 1 | U-109 G-5389 | U-102 G-4924 | 12070 | 1.5 / 673 2.0 / 898 | 1/18/37 1/4/71 |
| Well No. 2 | U-159 | U-150 | 15548 | 3.0 / 1,346 | 2/28/44 |
| Well No. 3 | U-191 | U-172 | 16998 | 3.5 / 1,571 | 1/10/46 |
| Well No. 5 | U-809 | U-718 | 23533 | 2.7 / 1,212 | 4/13/55 |
| Well No. 6 | U-511 | U-462 | 23519 | 3.5 / 1,571 | 7/16/52 |
| Well No. 8 | G-2502 | G-2312 | 41011 | 3.9 / 1,750 | 12/13/62 |
| Well No. 9 | G-13494 | G-12582 | 20806 | 3.3 / 1,481 | 8/16/93 |
| Walla Walla River | -- | D-12920 | 12920 | 7.24 / 3,245 | 1890 |

* cfs = cubic feet per second

WATER SUPPLY ANALYTICAL TESTING

Water quality analytical results for the City's wells were obtained from the Drinking Water Program (DWP) website database. Since the majority of the wells have isolated discharge lines into the reservoirs, the City of Milton-Freewater is able to obtain water quality samples from a single sampling point that is representative of water quality from several wells. This has allowed the City to reduce the number of sampling points for their seven wells to four locations, as summarized hereafter. The entry points into the water system, or EPs, are identified in the DWP database as A, B, C, and D.

- Wells No. 1 and 2 entry point (EP-A)
- Wells No. 3, 5, and 6 entry point (EP-B)
- Well No. 8 entry point (EP-C)
- Well No. 9 entry point (EP-D)

The wells, or entry points, have been sampled for the constituents required by the DWP, including total and fecal coliform, volatile organic compounds (VOCs), synthetic organic compounds (SOCs), seven pesticides, gross alpha, nitrate, nitrite, nitrate-nitrite, sulfate, cyanide, fluoride, and metals. Only those constituents detected in the samples at low concentrations are included in the following table along with the corresponding Maximum Contaminant Level (MCL). The period reviewed for the analytical results is from 2002 through currently available data.

**WATER SUPPLY ANALYTICAL TESTING SUMMARY DATA
2002 THROUGH PRESENT**

| Contaminant (MCL, mg/L unless otherwise noted) | Levels of Contaminants Detected (mg/L unless otherwise noted) | | | |
|--|--|------------------------------------|----------------------|----------------------|
| | EP-A (Wells No. 1 and 2) | EP-B (Wells No. 3, 5, and 6) | EP-C (Well No. 8) | EP-D (Well No. 9) |
| Nitrate (10) | 0.70 | 0.20 to 1.6 | 0.30 | -- |
| Radium (5 pCi) | 0.86 | 0.88 | -- | -- |
| Uranium (0.30) | 0.00011 to 0.00012 | -- | -- | -- |
| Barium (2.0) | 0.019 | 0.0088 | 0.012 to 0.013 | 0.022 to 0.024 |
| Fluoride (4.0) | 0.20 | -- | 0.40 | 0.20 |
| Sodium (NA) | 14 | 12 | 14 to 15 | 14 |

pCi = Pico curries
NA = Not applicable

Based on the sample analytical results, the groundwater of the wells that were sampled does not contain bacteriological or chemical constituents at concentrations greater than the corresponding EPA Primary Drinking Water MCLs. The water quality testing summaries were obtained from the DWP website and are presented in Appendix A.

Distribution System Testing. Although the distribution system is discussed in greater detail in Chapter 5, a brief discussion of distribution system sample analytical testing is presented herein for completeness. The City randomly obtains eight routine samples each month from the distribution system for analysis of total and fecal coliform. For the period from July 5, 2001, through November 24, 2008, total and fecal coliform have not been detected in the routine samples. The City also biannually obtains random samples from the distribution system for chemical analysis of total lead and total copper. From 1993 through 2007, all detected concentrations of lead and copper were less than their corresponding EPA Action Levels.

WATER SUPPLY DESIGN CRITERIA

General. As presented in Chapter 2, the planning period for this Water System Master Plan extends to the year 2028. The estimated population of Milton-Freewater,

as of July 1, 2007, was 6,550, and the projected population for the year 2028 is 9,750. The peak daily water demand is estimated to be 5,078 gpm in the year 2028, while the current peak daily demand is estimated to be 3,411 gpm.

Generally, water supply facilities are designed to meet peak daily demands. These facilities should normally be sized to supply the peak daily demand without 24-hour service. If these facilities are wells, it is preferred that well pumps operate a maximum of 18 hours per day, if possible.

Well Operation. Many communities in Eastern Oregon rely upon wells as their primary water source, and wells have proven to be dependable and reliable in meeting the water supply needs of these communities. The City of Milton-Freewater has developed a system of wells that effectively serves the City's current water needs. The total production available from all of the City's wells is approximately 7,520 gpm. Discounting the capacity of Well No. 1 due to minimal use of the well because of entrained air problems, the total production reduces to 6,690 gpm. This current production rate meets the current estimated peak daily demand of 3,411 gpm by operating just under 12 hours per day. The projected peak daily demand of 5,078 gpm in the year 2028 with the same set of wells operating requires just over 18 hours of operation per day. Any extended shutdowns of the actively used wells will also require the use of the entrained air water source (Well No. 1) to meet projected peak daily demands.

Bringing the City's existing Well No. 1 back into regular service by constructing a transmission line from the well to the existing line from Well No. 2 to the North Reservoir would help to reduce the projected 2028 pump operation time. A transmission line connecting the subject well to the reservoir and spilling the water into the reservoir would allow the entrained air to dissipate (as discussed in the Air Entrainment section below). The City has implemented this strategy on other wells with good results. Bringing Well No. 1 back online would alleviate potential high operation hours for the other system wells, reducing pump operation time to meet year 2028 peak daily demands to just over 16 hours. With Well No. 1 back in operation in the City's supply system, it is anticipated that year 2028 peak day demands would be met and operational flexibility would be improved.

Reliability. The reliability of the water supply is one of the most important functions of any water system. Because the health and safety of the community depends upon a reliable water source, high priority should be given to ensure a municipal water system has the ability always to meet the water needs of its customers. A number of factors, such as mechanical failures, power outages, primary water transmission line failures, etc., can affect the reliability of a water supply. It is nearly impossible to ensure 100 percent reliability of any system. However, having proper system components can help ensure long-term reliability. Currently, the City has standby power available at Well No. 2. This provides some reliability for the Middle Pressure Zone in the event of a power outage. Through the pressure reducing valve (PRV) at DeHaven and Broadway, and opening a few normally closed valves, the Middle Pressure Zone can supply water to the North Pressure Zone, providing a level of backup reliability to that zone also. The higher elevation South Pressure Zone does not

have standby power or backup water supply sources available, but it does have a large capacity reservoir with fewer uses.

It should be noted that future changes in the City's projected population, water use characteristics, and/or available supply could affect these assumptions. The City should periodically review this information to ensure additional water supply beyond that recommended in this Water System Master Plan is not needed sooner than anticipated to meet the City's demands.

AIR ENTRAINMENT

One problem of concern with the City's water supply is the presence of air in the water. The entrained air readily comes out of solution when brought to atmospheric conditions such as in a reservoir or out of a water tap. However, pumping the water with entrained air directly into the distribution system results in air-related problems and appearance complaints (the water appears milky). Air can also increase other potential water quality problems associated with iron and manganese.

Prior to 1991 the problem was evident in Well No. 2 during periods of high pumping rates. During the summer of 1993 the problem grew worse and could not be eliminated by reducing pumping rates. At that time the well was shut down. Well No. 3 also developed an air entrainment problem in 1992. A video inspection performed at that time revealed that the air was entering the well at a depth of between 251 to 264 feet. A packer was installed to seal off this portion of the well; however, subsequent pump testing showed that there was also an air entrainment problem in the lower aquifer. After testing methods to remove the air from the water at the well site, it was determined that a transmission pipeline connecting Well No. 3 to the North Reservoir should be constructed. This project was completed in 1999. This new line enables the air-entrained water to be discharged to the reservoir and the air to dissipate under the open atmospheric conditions inside the reservoir prior to being conveyed to the distribution system. A separate discharge line into the Middle Reservoir for Well No. 2 was constructed in 2001.

Well No. 6 developed an air entrainment problem and a transmission pipeline connecting this well to the North Reservoir was installed in 1999. The water from Well No. 6 is discharged against a plate before mixing with the reservoir water in an attempt to increase the air dissipation rate. This discharge configuration is working well for the City. The City has also found that Well No. 5 has developed an air entrainment problem. The City has identified that the problem has moved in a northwesterly direction through its well system, which may indicate that Well No. 5 would be the last City well to be affected by the problem. However, additional wells may develop this problem, requiring future action to be taken in order to continue their use. A separate discharge line into the North Reservoir was constructed for Well No. 5 in 2001.

Currently, five wells (No. 1, 2, 3, 5, and 6) are experiencing air entrainment problems. All of these wells (except Well No. 1) have separate discharge lines into their applicable reservoirs.

AREA WELLS

Although the City is not projected to have deficiencies in the water supply system through the year 2028, it is recommended that the City continues to proactively pursue other supply sources as the opportunities arise. With this goal in mind, available copies of well logs from the Oregon Water Resources Department (OWRD) for the Milton-Freewater area were obtained and reviewed for potential City use. The well logs were reviewed considering well location, yield, and depth. Only wells located in Township 5 North, Range 35 East, Sections 1, 2, 11, and 12; Township 6 North, Range 35 East, Sections 35 and 36; and Township 5 North, Range 36 East, Sections 7 and 18 with yields greater than 400 gpm or depths greater than 500 feet were included for discussion in this chapter. The sections reviewed for well logs are located within the City's Urban Growth Boundary (UGB) or immediately adjacent to the UGB. Copies of the well logs for wells in the Milton-Freewater area meeting the assumed criteria are presented in Appendix F.

Information obtained from the well logs was used to complete a very preliminary evaluation of wells in the Milton-Freewater area for planning purposes. Interviews with well owners were not completed to verify the accuracy of the well log information presented herein. In some cases, well logs may not be available or significant alterations may have been completed to a well that are not shown on the well log or not reported to the Oregon Water Resources Department. If well log information is used as a basis for evaluating possible sites for a new well, a more detailed informational search, with personal interviews, should be completed to help verify well log information.

Based on the well log information obtained from the OWRD, ten wells are present in the Milton-Freewater area, outside of the City's wells, that have yields in the neighborhood of 400 gpm or more. Two additional wells with depths greater than 500 feet are present in the area, which have been included in this discussion due to lacking or questionable reported yields. A summary of the well log information is presented in Table 3-2. The estimated well locations are presented on Figure 3-1. It should be noted that the well locations were estimated based on legal descriptions on each log that are to the nearest 40 acres. Therefore, the locations shown on Figure 3-1 should be considered approximate.

The three most promising wells, as far as current yield (Wells A, B, and C), are located in Township 5 North, Range 35 East, Sections 1 and 12. These wells appear to have been used for canning-related operations. The City has acquired Well A and has control of the operation of Well B. Wells A, B, and C range in depth from 528 to 702 feet and provided yields ranging from 1,000 to 1,350 gpm upon completion of drilling. Based on the well log information, well yields of between 500 and 1,000 gpm appear to be attainable by drilling to depths ranging from approximately 300 to 1,000 feet in Sections 1 and 12. Wells drilled at appropriate locations in either of these sections would be very close to the existing distribution system, eliminating the need for a long pipeline from a new well to the distribution system.

STATIC WATER LEVEL TRENDS

Over time, static water levels of a well can be the best indicator of the status of the underlying aquifer. Historically, the City's basalt wells have demonstrated a decline in static water levels. This indicates that groundwater is likely being pumped from the aquifers at a faster rate than recharge can occur. This is probably due in part to the City's use and probably mostly due to significant irrigation use in the area and heavy cannery use in the past. A graphical representation of the decline using available static water level data for each of the wells is shown in Figure 3-2.

The data presented in Figure 3-2 comes from various sources without specific dates of measurement identified. Seasonal fluctuations in static water level impact water level readings throughout the year and, therefore, may have some effect on the presented data. Based on the extended period of time covered by the data and the consistency between wells, the general decline in static levels can be interpreted as being representative of the aquifer's water level.

Indications are that the aquifer is declining over the long term at an average linear rate of 2.5 to 3.4 feet per year. Focusing upon the more recent rates since the mid 1970s, the decline appears to be around 1.5 feet per year. This is probably due to significant reductions of heavy cannery use of water from the aquifer since the 1970s. Static water levels appear to be recovering some since the mid-1990s. This is a positive trend; however, the wells will need to recover significantly more to reach static water levels of the 1930s to 1940s.

It is very important to observe any trends in static and pumping water levels in the City wells. It would be wise for the City to start recording at least weekly, and preferably daily, static and pumping water level data for each well. This data can then be plotted over a several year period to observe current data trends. This data will be invaluable to the City in predicting the long-term usability of the City wells.

The lowering trend for static water levels in the City's wells, if it continues as past trends have shown in Figure 3-2, will likely require future modifications to the existing pumping equipment so the current yields can continue to be obtained from the wells. The lowering of static water levels may eventually result in the desired well yield being unattainable. If this occurs, the City will need to have alternate sources of water available to meet needs, such as utilizing the existing Walla Walla River surface water right.

The Milton-Freewater area, because of the lowering water levels, could eventually be designated by OWRD as a critical groundwater use area. This type of designation in other areas has resulted in restricted use of some existing wells and no new water rights being allowed for wells in these areas. Since wells currently appear to be the most cost-effective source of drinking water for the City of Milton-Freewater, the City could be faced with a water shortage or increased water treatment costs if the use of surface water were required to meet future demands.

The City should continue monitoring static and pumping water levels throughout the year to observe both seasonal and annual variation in the data. If static water levels are continually declining on an annual basis, it would be wise for the City to begin investigating ways to protect the City's water rights and possibly acquire water rights with old priority dates. Declining groundwater levels may very well become a major issue for the City of Milton-Freewater in the future.

GROUNDWATER SUPPLY RESOURCES

As stated previously, the City appears to have adequate water supply through the year 2028 and possibly beyond. The following comparison of water supply resources is provided for the City's reference should further water sources be sought during the planning period. There are generally four options available to the City for obtaining additional water supply capacity. The options are outlined hereafter, followed by a discussion of the advantages and disadvantages of each option.

- Drill a new well.
- Purchase an existing well with a known capacity.
- Increase the pumping rate of the existing wells.
- Bring the existing Walla Walla River treatment plant back into operation and supplement the well supply sources with treated surface water.

New Well. A new well would be operationally advantageous to the City because an additional supply would be available, allowing existing Well No. 2 to remain as a backup and emergency well. The disadvantage of a new well, as compared to the other two supply options, is the high initial expense. Assuming a new well is desired by the City, the well could either pump directly into the distribution system or to one of the existing reservoirs. Prior to selecting a site for a new well, it is recommended that a geological study be completed to help evaluate possible sites.

Estimating the required depth of a new well to obtain a desired yield on the order of 1,000 gpm is very difficult. The ultimate yield from a well can be determined only after drilling is completed and well testing has been conducted. Assuming the City would drill a new well to a depth of 900 feet, the estimated cost to drill this well is anticipated to be \$300,000 to \$350,000, which includes land acquisition, drilling, casing, inspecting, and testing the new well. The control building, pump, and miscellaneous appurtenances are anticipated to cost approximately \$250,000, bringing the maximum anticipated cost for a new well to about \$550,000 to \$600,000.

Secure Use of an Existing Well. The well logs presented in Appendix F indicate that at least three wells exist on the east side of the City that would provide a desired yield of approximately 1,000 gpm. Assuming a willing seller is available, securing the use of an existing well would be a desirable option for the City to pursue because the well yield is already known. The existing well logs reviewed in this chapter

were all for wells primarily used for irrigation or industrial purposes. In each case, the wells are private, serving an individual owner or company. Water quality testing in accordance with the DWP requirements for municipal wells has likely not been completed for some of these wells. In addition, the DWP municipal well construction requirements may not have been adhered to during construction of these wells. Prior to the City considering acquiring the use of an existing well, considerable information about the well should be obtained, as outlined hereafter.

- Well construction details should be obtained, specifically casing intervals and the depth of the surface seal. Some of this information may not be attainable from existing logs and records. It is recommended that a detailed down-hole inspection of the well be completed to document its condition as best as reasonably possible. At a minimum, the well should be television inspected to check the condition of the well seal, casing, and borehole, cave-ins, etc.
- Water quality parameters should be obtained, specifically testing parameters meeting the requirements of the DWP. Any well considered for municipal use should be thoroughly tested to determine if the water quality is acceptable to the DWP prior to purchase of the well. Other tests not normally required by the DWP that could lead to precipitation of solids in the distribution system, such as water chemistry tests to determine the iron, manganese, and silica content, etc., should also be performed.
- Water rights should be clearly defined, specifically the type of water right (irrigation, domestic, industrial, etc.), whether it is transferrable to the City for municipal use, and whether additional municipal water rights can be obtained for the existing well and aquifer.
- Property ownership of the well site should be understood, specifically if the City could obtain enough land surrounding the well site to construct an adequate well house and fence to protect the site. Typically, a 100-foot radius around the well is desirable.

Estimating the cost associated with securing an existing well is difficult because of the unknown purchasing terms of the seller. It is typically less expensive to secure the use of an existing well when compared to drilling a new well.

Increase Pumping Rate from Existing Wells. The City's existing wells have a known capacity that has been relatively stable since the wells were drilled, although static water levels have generally declined as discussed earlier in this chapter. There may be additional capacity available from the City's wells, depending on each well's specific capacity. Currently, the City has the ability to measure drawdown in their wells (minor modifications may be necessary) during pumping conditions. To adequately evaluate the specific capacity of each well, a detailed pump test would need to be performed while accurately measuring the drawdown of the water level in the casing. Such tests would provide an estimate of the yield of each well for each foot of water

level drawdown. Estimates could then be made of how much water each well would be expected to provide and the size of pump required to obtain the desired yield.

To complete a pump test on an existing well, the existing pump can likely be used. However, appropriate measures must be in place to deal with the relatively high discharge rates from the pumps. The means for obtaining accurate water level measurements must also be available. The City would need to test one well at a time so the other wells would be available to meet City demands. Pump tests should be completed during a lower demand time of the year, such as in the early spring or late fall.

Costs associated with a thorough and detailed pump test using existing equipment and assuming the well head is accessible for water level measurements are estimated to be in the range of \$10,000 to \$15,000 per well. Increasing the yield from existing wells appears to be the least expensive option for additional water supply for the City, if such yield is available. It should be noted that additional water rights may need to be obtained for any increase in use of the existing wells should this option be pursued.

SURFACE WATER SOURCES

The City relied on the Walla Walla River to supply its water in the past and the river still represents a potential source of surface water that could be developed. The following section discusses the issues and options available to the City should surface water treatment be considered in the future.

Regulatory Overview. In December 1991, the Surface Water Treatment Rule (SWTR) of the Safe Drinking Water Act (SDWA) was implemented. Unless the public water system could meet certain stringent water quality and system operational conditions, the SWTR required that surface water sources and groundwater under the influence of surface water be treated to remove bacteria, viruses, turbidity, and inorganic and organic compounds if harmful to human health. The SDWA was amended in August 1996. However, the amendments to the SDWA did not change the regulations set forth in the SWTR.

Walla Walla River Overview. The headwaters of the Walla Walla River are east of Milton-Freewater in the Blue Mountains. The river flows out of the Blue Mountains in both the north and south forks, merges into the main river channel approximately four miles southeast of Milton-Freewater, then flows through the City and Walla Walla Valley, and eventually into the Columbia River near Wallula, Washington. If water from the Walla Walla River is once again utilized as a water supply source for the City of Milton-Freewater, the system would include a river intake structure upstream from the City, a transmission line to a treatment plant located down-gradient from the intake structure, a transmission line from the treatment plant to a new storage reservoir, and a transmission line connecting the new reservoir to the City's primary distribution mains. The storage reservoir would provide equalization storage as well as chlorine contact time for proper disinfection. It is not anticipated that the City's old water treatment plant

can be updated to meet current treatment requirements, but the existing site can be used to accommodate a new plant and associated facilities.

Walla Walla River Water Quality. Walla Walla River water was preliminarily evaluated to determine if it has the necessary quality to provide the City with a reliable water source. The Washington Department of Ecology (DOE) maintains a water quality monitoring station on the Walla Walla River and monitors and records important water quality parameters at these stations. The testing station is located near Touchet on the Walla Walla River, which is approximately 18 miles northwest and downstream of Milton-Freewater. See Appendix G for a listing of water quality data obtained at this station. The water quality at Touchet is generally representative of what the City would be withdrawing from the river, but may tend to have slightly higher contaminate levels and temperature readings due to the relatively flat agricultural land that the river passes through between Milton-Freewater and Touchet.

Monthly water quality data from the Touchet station for a period from 1959 through 2000 were obtained from the DOE to determine if turbidity levels in the river are low enough to allow for efficient treatment of the water. The average turbidity for the period from 1959 through 2000 (about 407 months of data) was 90 Nephelometric Turbidity Units (NTU) and the peak monthly turbidity was estimated to be about 9,600 NTU. However, if the three peak turbidity readings from July 1997, December 1994, and March 1996 (2,700, 3,900, and 9,600 NTU, respectively) are not considered, the average turbidity decreases to 51 NTU. Considering that the data taken by the DOE reflects only a point in time each month, the peak daily turbidity levels will likely be significantly higher than 51 NTU. It is also likely that the river would reach levels higher than 100 NTU at least once a year (based on the monthly turbidity data), which may limit the treatment options available to the City or create an unreliable water source if conventional treatment methods are pursued. Furthermore, it appears that color and pH levels have been reported at levels above the recommended secondary maximum contaminant levels set by the SDWA. Consequently, the water quality of the Walla Walla River at Touchet does not appear to be ideal, but should be adequate to allow for efficient treatment with some, but not all, of the water treatment technologies available. These technologies are summarized later in this chapter.

Water Rights. The City owns water rights under Certificate No. 12920 (1890 priority date) to the Walla Walla River that allow for a withdrawal rate of 7.24 cfs (3,245 gpm) for domestic water use. Prior to 1959, the City used a sand filter treatment facility to treat Walla Walla River water prior to supplying the water to City users. The reported treatment capacity of the plant was 1,200 gpm, which represents approximately 37 percent of the City's full water right.

If the City were interested in developing the river as a source of domestic water, its current water right should be adequate to meet future needs as long as some of the City's existing wells remain in operation. However, the flows available in the river vary from year to year and according to the time of year. The amount of water that could be removed from the Walla Walla River, based on existing water rights, is unknown. In-stream water rights have also been established for the river to protect in-stream aquatic

life. These in-stream water rights do not necessarily take precedence over the City's water right, but considering the current regulatory environment, may prove to be a limiting factor should the City decide to exercise its water right.

Water Treatment Plant Design Flow. If the City should decide that water treatment to treat a surface water source is a viable option, it appears that the most reasonable method of meeting the water system demands would be to use the water treatment plant to provide the primary supply of water to the City and augment the surface water with the existing wells when needed. This would reduce the demand placed on the wells and would provide additional capacity to the system. Therefore, for purposes of comparison and cost estimating, a design flow rate of 3.3 million gallons per day (MGD), or 2,300 gpm will be used to evaluate the alternative treatment facilities. This design flow represents the average daily demand projected for the year 2028 with a small amount of additional capacity. The design flow rate was not increased to match the full water right flow of 3,245 gpm (4.7 MGD) because it is not anticipated that the City can draw the full flow specified in its water right without significantly impacting river water levels during lower flow periods. The 3.3 MGD should be a conservative flow rate to use, considering the City currently has adequate water supply from its wells available to meet projected year 2028 peak day demands.

Water Treatment Operator Requirements. Prior to discussing specific water treatment technologies, an explanation of the DWP requirements of operators for different treatment processes will be presented. The rules are set forth in Oregon Administrative Rules (OAR) 333-61-220.

OAR 333-61-220 provides a method of determining the required classification of operators based upon an accumulated point system. A specific number of points are assigned to different items within the treatment plant. The points are assigned as follows:

WATER TREATMENT PLANTS ITEMS FOR CLASSIFICATION

| Item | Points |
|---|------------------------|
| Treatment System Size (Either Population or Flow) | |
| Population Served | 1 per 10,000 (max. 25) |
| Average Daily Flow | 1 per 1 MGD (max. 25) |
| Treatment System Water Source | |
| Groundwater | 3 |
| Surface Water | 5 |
| Treatment | |
| Aeration for CO ₂ | 2 |
| pH Adjustment or Corrosion Control | 4 |
| Taste and Odor Control | 1 to 8 |
| Color Adjustment | 4 |
| Iron and Manganese | 1 to 10 |
| Softening | |
| Ion-Exchange | 10 |
| Chemical Precipitation (Lime and Soda Ash) | 20 |

| Item | Points |
|--|----------------|
| Coagulation Process | |
| Rapid Mix | 5 |
| Flocculation | 5 |
| Sedimentation | 5 |
| Filtration | |
| Conventional Rapid Sand | 10 |
| Direct Rapid Sand | 7 |
| Diatomaceous Earth | 7 |
| Slow Sand Filtration | 5 |
| Sludge Treatment | 1 to 6 |
| Other Treatment | As Appropriate |
| Fluoridation | 5 |
| Chlorination or Equal | 5 |
| Bacteriological or Chemical Laboratory | 1 to 10 |

The appropriate points for the treatment system are added and, based upon the cumulative point total, the following classifications are assigned:

CLASSIFICATION OF WATER TREATMENT PLANTS

| Class | Points |
|--------------------|---------------|
| Class I (WT I) | 30 or less |
| Class II (WT II) | 31 to 55 |
| Class III (WT III) | 56 to 75 |
| Class IV (WT IV) | 76 or greater |

These classifications are used by the DWP to determine the certification grade required for plant operators. Should the City decide to pursue a surface water treatment plant, plant operators will have to become appropriately certified.

SURFACE WATER TREATMENT ALTERNATIVES

Introduction. This section discusses in detail several options available to the City for treating surface water from the Walla Walla River. The estimated costs to develop each treatment alternative assume the existing treatment plant facilities are inoperable and cannot be upgraded to meet current standards. However, the land on which the existing treatment plant is located is assumed to be utilized. Therefore, the cost estimates include the treatment plant capital cost, costs to construct an intake structure, influent pumping and piping, booster pumping station, reservoir and associated transmission and distribution piping, and the operation and maintenance costs. The treatment alternatives discussed include slow sand filters, membrane filtration, custom designed mechanical treatment plants, and prefabricated packaged mechanical treatment plants. Each treatment alternative will be evaluated based on a design flow rate of 3.3 MGD.

Slow Sand Filters. The slow sand filter was developed in England in the early 19th Century. The slow sand filter is a filter operated at very low filtration rates without

the use of coagulation chemicals in pretreatment. The sand grain size used is small and this, plus the low filtration rate, results in very high removals of coliform, Giardia, cryptosporidium, and other organic materials. The removal takes place almost entirely in a thin layer on top of the sand bed. This layer, referred to as the schmutzdecke or "dirty skin," is composed of dirt and living and dead micro- and macro-organisms from the water. It becomes the dominant filter medium as the filter cycle progresses. When head loss becomes excessive, the filter is cleaned by draining it below the sand surface and physically removing the schmutzdecke along with a small layer of sand. Typical cycle lengths may vary from 1 to 6 months, depending on the source water quality and the filtration rate. Slow sand filters are not effective in treating clay-bearing water because the clay penetrates too deeply into the filter and cannot be removed by the normal surface-scraping operation inherent with maintaining the filter.

Removal mechanisms in slow sand filters are both physical and biological. Living organisms in the filter cause reductions in organic matter and chemical transformations. The effectiveness of the filter improves over the first few cycles as the organisms develop and usually continues to remain high thereafter. An initial improvement period (or ripening period) occurs at the beginning of each cycle after the schmutzdecke has been removed. The initial improvement period observed in operating slow sand filter plants varies from 6 hours to 2 weeks with most improvement periods less than 2 days. A filter-to-waste cycle of about two days is recommended after the filter is scraped.

Slow sand filter systems use a low filtration rate that can range from 25 to 230 gallons per day per square foot; however, most common slow sand filters are designed for rates of about 100 gallons per day per square foot.

The regulation governing effluent water quality from different water treatment processes indicates, for slow sand filtration processes, the turbidity level in the effluent must be less than or equal to 1 NTU in at least 95 percent of the measurements taken each month, and the maximum allowable turbidity level shall at no time exceed 5 NTU. According to the DWP, in certain cases where a municipality can effectively demonstrate that disinfection efficiency is not reduced by high effluent turbidity levels (the main health concern), and the water clarity is such that customers will not complain about "dirty water," the municipality may be granted a waiver from the 1 NTU rule. It will be nearly impossible to keep the Walla Walla River source below 1 NTU with a slow sand filter. A waiver would be required allowing finished water to be 5 NTU or less. The DWP is the agency responsible for granting such a waiver. Obtaining a waiver is a possibility; however, it is beyond the scope of this Master Plan to determine whether or not a waiver can be obtained. If a waiver can be obtained, there would still be a significant period of the year, perhaps months, when river water would not be available for the City if a slow sand filter treatment plant were to be constructed. If a slow sand filter is selected as a treatment option, further analysis of this issue will be needed.

The general components of a slow sand filter would include a raw water inlet/flow distribution structure, a filter gallery consisting of at least two filters to allow for filter cleaning, a disinfection system and controls, a backup electrical generator, water quality and flow monitoring equipment, and a building to house control equipment. The slow sand filter plant would be located at the existing treatment plant site southeast of the

City. This may allow the plant to gravity feed into the lower Middle and North Reservoirs and eliminate the need for pumps and pumping costs. Additional development of the existing site is anticipated to accommodate the desired capacity of the plant.

Some of the advantages and disadvantages of the slow sand filter plant alternative are as follows:

Advantages

- Easy to operate; minimal operator attention and training required to operate the plant (requires only a Class I water treatment plant operator).
- High coliform, Giardia, cryptosporidium, and solids removal potential without complex chemical feeders and controls.
- No process pumping and controls are necessary.
- No chemical sludges are produced; only required to dispose of dirty sand or hydraulically wash the sand for reuse.
- Low operation and maintenance (O&M) costs.

Disadvantages

- High quality raw water source required; typically raw water turbidity levels of no more than 5 NTU are required to meet water quality standards.
- Highly sensitive to fluctuations in water quality.
- Turbidity and color removal efficiencies are usually low.
- Relatively high capital cost.

For preliminary sizing purposes and cost comparison, a filtration rate of 100 gallons per day per square foot of filter surface area will be utilized. Based upon the preliminary estimated flow rate of 3.3 MGD, a minimum of 33,000 square feet of filter area would be required. Conceptually, four filter basins of 8,250 square feet each would be the minimum recommended basin size.

For a planning level cost estimate, a reasonable unit cost for a slow sand filtration plant is \$200 per square foot of filter area, or \$6.62 million for a 33,000 square foot plant. Additionally, the O&M costs including labor, equipment replacements, materials, and energy costs are estimated to range from \$300 to \$375 per million gallons of water treated, or \$362,000 to \$452,000 per year, depending on the water quality of the source.

Membrane Filtration. An emerging water treatment technology that may have application for the City of Milton-Freewater is membrane filtration. Membrane filtration is a physical straining process used for removing turbidity and micro-organisms from the source water. Water is pushed through a porous fiber material. The membranes have a nominal opening size of 0.01 to 0.2 microns, 10 to 300 times smaller than the size of the target organisms such as Giardia or cryptosporidium. The removed particles and organisms remain on the raw water side of the membrane and are flushed away using compressed air and backwash water.

Membrane filtration relies solely on physical processes. To provide a comparison, slow sand filtration is a biological/physical process and rapid rate filtration (discussed in subsequent sections) is a chemical/physical process. Similar to slow sand filtration, membrane filtration requires no coagulation chemicals. It requires only limited operator process control and has been found very reliable in producing safe drinking water. In addition, like slow sand filtration, its use is limited to source waters with relatively low levels of turbidity. As with slow sand filtration, membrane filtration could be limited by high turbidity levels in the Walla Walla River and may not be available for use for extended periods of time.

Because water must be pushed through the membrane, membrane filtration has certain pressure requirements associated with it. The required operating head is 30 to 50 psi. Typically, raw water pumps are required, but it is likely that a membrane filtration plant could be constructed in such a way as to take advantage of gravity pressure from the Walla Walla River source. This could be achieved by moving the intake structure up higher on the river. This would eliminate the energy cost for providing the driving pressure with pumps. A detailed evaluation of the plant site and the surrounding area would need to be undertaken to confirm this.

Membrane filtration is effective on many different surface water supplies. However, like slow sand filtration, pilot tests should be conducted to confirm its applicability on a specific waterway prior to constructing a membrane filtration treatment facility. Pilot testing also allows the operators to gain first-hand experience with the equipment to aid in the decision-making process, which can be a critical component when selecting a supply system. In general, membrane filtration is better able to handle adverse water quality conditions than slow sand filtration, but is not as flexible as conventional or direct filtration.

Pilot testing of membrane filtration ideally includes parallel testing of equipment from two or more equipment suppliers. The suppliers will often provide their equipment and some startup services at a relatively low cost, but the overall program with engineering, supply connections, and lab costs might total from \$50,000 to \$70,000. If the City decided to further investigate membrane filtration, it would be advisable to discuss the City of Pendleton's pilot program with their staff. Pendleton completed such a program and has a membrane filtration plant that has been operational since 2004.

The general components of a membrane filtration water treatment plant would consist of a raw water inlet/flow distribution structure, raw water pumps (which may not be required if gravity pressure can be provided), a bank(s) of membrane cartridges,

process and yard piping, clear well, plant controls and electrical equipment, disinfection system, plant building(s), a backup electrical generator, water quality and flow monitoring equipment, effluent disposal system, and miscellaneous mechanical equipment.

Some of the advantages and disadvantages of the membrane filtration treatment plant alternative are as follows:

Advantages

- Easy to operate; minimal operator attention and training required to operate the plant.
- Reliability of treatment.
- High coliform, Giardia, cryptosporidium, and solids removal without complex chemical feeders and controls (no chemical addition needed).
- No chemical sludges are produced; only required to dispose of natural materials physically removed from the source water.
- Consistent high quality water produced.
- Small footprint, which is easily expandable in the future since the equipment is modular in design.

Disadvantages

- Relatively high capital and O&M costs.
- Membranes have a relatively short life span (4 to 10 years). Membrane replacement is one of the major O&M costs.
- A high quality raw water source is required to ensure efficient operation of the plant.

Membrane filtration costs have dropped significantly. Until the mid-1990s, it was generally considered too expensive for systems larger than about 1 MGD. This has changed and many systems with capacities from 5 to 30 MGD are being installed in the United States. It is expected that this trend will continue.

As a matter of reference, in Oregon, Warrenton and Pendleton have installed membrane filtration plants with capacities of 6 MGD. The cost of the membrane package equipment for Warrenton's 6 MGD plant was approximately \$2.3 million in 2004 construction costs. When other project components are included (chlorination facilities, plant building, clear well, site work, piping, and other mechanical aspects), the overall plant construction cost was about \$6.5 to \$7.5 million in 2004. This represents a

cost range of \$1.08 to \$1.25 per gallon of installed capacity. The actual cost of a plant for Milton-Freewater will vary from this range depending on site-specific factors. It would likely be somewhat higher because the City would be constructing a smaller plant and, consequently, the cost per gallon of capacity would be higher (i.e., the smaller the plant, the higher the cost per gallon of installed capacity). The estimated costs also need to be adjusted about 25 percent for inflation. For this master planning effort, a reasonable cost estimate is \$1.90 per gallon of installed capacity, or \$6.27 million for a 3.3 MGD plant. O&M costs are anticipated to range from \$420 to \$550 per million gallons of water treated, or \$506,000 to \$662,000 per year, based on a plant design flow of 3.3 MGD.

Custom Designed Direct Filtration Treatment Plant. The basic treatment process of a direct filtration water treatment system consists of coagulation, flocculation, and filtration. Coagulation is a physical/chemical process that occurs by use of chemicals or polymers (coagulant) whereby a reaction between the particulates in the water and the coagulant neutralizes the electrical charges on the particles and causes small particles to agglomerate (coagulate) into larger particles. Flocculation is agitation of the chemically treated water to induce coagulation by bringing the particles in contact with each other. Flocculation is the principal mechanism in removing turbidity from water. The larger particles created through the coagulation/flocculation process are more easily removed by the filtration process.

Typical flocculators consist of a mechanically driven shaft that supports reels. Paddles are attached to the reel. The flocculators would be constructed in a concrete basin containing paddles and baffles. The flocculation tank would be located upstream of the filters. The filters would operate by gravity and would consist of a concrete basin containing an underdrain system, an air scour system, a media backwash system, a backwash water drain system and single, dual, or mixed media. Common materials used in filters are sand, crushed anthracite coal, and garnet. Single-media filters use sand alone. Dual-media filters typically use a combination of coal and sand. Mixed-media filters use a combination of all three materials. The choice of whether to use single, dual, or mixed media depends on the raw water quality and is determined through pilot testing.

Direct filtration processes typically use rapid filtration. Rapid filtration consists of passage of coagulated water through a granular bed at rates from 2 to 10 gpm/ft² with a typical filtration rate of 5 gpm/ft². Flow is usually downward through the bed. During operation, solids are removed from the water and accumulate within the voids and on the top surface of the filter medium. This clogging results in a gradual increase in head loss across the filter if the flow rate is to be sustained. Once a maximum head loss is obtained, the filter is backwashed to clean the medium and ready the filter for continued operation. Backwash rates are usually about 15 gpm/ft². Typical filter cycles range from about 12 to 96 hours, depending on the raw water quality.

In order to accomplish the treatment processes described above, the plant would require chemical feed equipment (coagulation, pH control, disinfection), at least two flocculation basins, at least two filters, a standby electrical generator, a plant control system, and process piping and valves. In addition to providing these items, the plant

would require an effluent clear well, backwash water recovery basin, backwash pumps, and air blowers.

Some of the advantages and disadvantages of the custom designed direct filtration water treatment plant alternative are as follows:

Advantages

- Proven reliable process.
- High process flexibility.
- Capable of treating highly variable water quality conditions and continuing to produce a high quality effluent.

Disadvantages

- Chemical sludges are produced that require sludge handling and disposal.
- Complex system to operate; requires high operator attention and knowledge of process control and water treatment (would require a Class II or Class III operator depending on the ultimate process scheme).
- High capital cost.
- High O&M costs.

The construction cost per unit of water treatment capacity varies widely with the size of the plant. Usually, the construction cost per unit of water treatment capacity becomes less with larger plants. However, based on other direct filtration plants of sizes similar to what Milton-Freewater would be installing, the construction cost is about \$1.80 per gallon of water. Therefore, considering the City would require a 3.3 MGD plant, the plant construction cost alone would be approximately \$5.94 million. Additionally, the O&M costs including labor, power, equipment maintenance, chemicals, and sludge handling and disposal, based on other operating plants in the region, are about \$275 to \$425 per million gallons of water treated, depending mainly on raw water quality. This equates to \$330,000 to \$512,000 per year based on an average annual flow through the plant of 3.3 MGD.

Packaged Water Treatment Systems. The water treatment industry has many different established manufacturers of packaged water treatment systems that offer a wide variety of different treatment options and process configurations. However, virtually all of the systems operate on the same principles of coagulation, flocculation, and filtration with some of the systems including sedimentation as a process step prior to filtration. Coagulation and filtration can remove a variety of substances including particulate matter that causes turbidity, microorganisms, color, precursors of disinfection

byproducts (organic acids), and some inorganic contaminants. The types of systems generally include:

1. Adsorption clarification with rapid dual or mixed-media filtration.
2. Modified conventional (coagulation, flocculation, and tube settling) with rapid dual or mixed-media filtration.
3. Solids contact clarification with dual or mixed-media filtration.
4. Diatomaceous earth (precoat) vacuum filtration.
5. Pressure filtration.

A detailed analysis of the existing packaged water treatment systems should be completed should the City decide to pursue surface water treatment. Costs for these systems can be considered to be in the general range of costs developed for the three previous filtration systems (\$6 to \$8 million). O&M costs are also anticipated to be in the ranges previously described, approximately \$360,000 to \$660,000 per year or more.

Water Treatment Residuals and Sludges. A discussion of water treatment alternatives would not be complete without addressing the issue of residuals and sludges generated as a byproduct of the water treatment processes. Without exception, every treatment process type will necessarily produce sludges that will have to be dewatered in some fashion and subsequently disposed of properly.

Sludge handling and disposal is a substantial portion of the annual cost of operating a water treatment facility. The sludges typically contain the filtered particulates and some contain residual chemicals used as coagulant aids. The sludges must first be dewatered (probably by pumping thickened sludges from a backwash water basin to a sludge drying bed) and then hauled to either a land application site or a sanitary landfill. The amount of sludge generated is directly related to the source water quality: the higher the turbidity levels, the more sludge is generated.

The DEQ has published guidelines for land application of industrial solid wastes. The guidelines explain the criteria for site selection, limitations, land application approval processes, solids and soils analysis protocol, monitoring, recordkeeping and reporting.

Disposing of water treatment sludges in sanitary landfills is a common practice. Typically, constituents in ordinary water treatment sludges do not exclude these solids from being disposed of in a municipal sanitary landfill. The disadvantage of this practice is that the potential benefit of recycling the wastes and minimizing waste disposal to landfills is not realized.

Summary of Surface Water Treatment. The previous section discussed several water treatment process technologies for treatment of the Walla Walla River surface water source available to the City of Milton-Freewater. The capital and O&M costs of each treatment technology were also presented.

The water quality of the Walla Walla River appears to be adequate to allow all of the technologies presented under each source alternative to effectively treat the water to high quality potable standards. However, high turbidity levels in the river may limit the use of certain technologies during these high turbidity events. Further monitoring of the water quality in the river near Milton-Freewater would allow more definitive timeframes for these high turbidity periods to be defined. Should the City choose to pursue surface water treatment as a source option, a thorough evaluation of the available technologies should be done at that time. Some of the technologies have potential advantages over others and these technologies should be targeted by the City for further evaluation. Prior to any particular treatment process design, extensive pilot testing should be completed on the viable options. Pilot testing will effectively demonstrate whether or not a particular process will work and will aid in process design decisions.

Many variables must be considered, which are beyond the scope of this Master Plan, before the best treatment method can be selected. For source alternative comparison purposes, it was assumed that the 2008 capital cost to construct a water treatment facility is reflected by the estimated average capital cost of the three primary treatment alternatives (slow sand filters, membrane filtration, and custom designed direct filtration) previously discussed. Based upon these assumptions, the estimated 2008 capital cost to construct a water treatment facility for the City of Milton-Freewater, including all additional improvements necessary for a complete and operating system, is estimated to be approximately \$6 million. The estimated 2008 annual operation and maintenance costs are between \$360,000 and \$660,000, depending on source water quality.

COMPARISON OF WATER SUPPLY OPTIONS

Four water supply options for the City of Milton-Freewater to consider for meeting their current and future water supply needs have been discussed in this chapter. For comparison purposes, the following table briefly outlines advantages and disadvantages of each option.

COMPARISON OF WATER SUPPLY OPTIONS

| Option | Advantages | Disadvantages |
|--|---|---|
| New Well | Additional supply developed. New well can be constructed as City desires. Water supply system is more reliable, allowing existing wells to be cycled in and out of service. | A new well is the most costly of the three well-related source alternatives. The capacity of the well cannot be confirmed until drilling is completed. |
| Secure an Existing Well | Same advantages as a new well. This option is likely less expensive when compared to a new well, depending on the seller's terms. | Unknown information about the well, such as construction details, water quality, etc. This information needs to be obtained prior to purchasing an existing well. The informational investigation requires an expenditure of funds for a well that may not be purchased, depending on the outcome of the investigation. |
| Obtain Additional Yield from Existing City Wells | Least expensive option. No new well is needed, assuming more yield is attainable. | The desired yield may not be attainable. Testing would be required to confirm desired yield is available. Additional draw from wells may increase air entrainment and/or declining water level problems. |
| Develop Surface Water Treatment Plant on the Walla Walla River | Additional diversified water supply is developed. Allows existing City wells to be operated less and cycled in and out of service. Allows a backup to potential air entrainment problems and declining water levels seen in many of the City's wells. | Capital cost is high. A pilot study would need to be undertaken to decide which treatment option would best serve the City. Includes potential problems with drawing water from the river during high demand periods when turbidity levels are high. |

Based on the peak demand data outlined earlier in this chapter, the City of Milton-Freewater does not appear to need a new source of water during the planning period of this study. However, it is important to determine, as accurately as possible, when a new source will be needed so adequate time can be allocated to properly complete the permit, design, and construction of the source. It is possible that a new well, from the initial permit process through final construction, can take two to three years or more before the well is ready for municipal use. The anticipated permitting, preliminary studies, design, and final construction of a surface water source could take from three to five years or more to complete. With these timeframes in mind, it is recommended the City pay close attention to water demands to ensure that the water

demand projections of this Plan are not being exceeded to help anticipate when a new water source is needed.

SUMMARY AND RECOMMENDATIONS

The City's current available total water supply capacity of 7,520 gpm (assuming the air entrainment problem in Well No. 1 is dealt with) exceeds the year 2028 design criteria of this Water System Master Plan. The City's current water supply sources are also free of contamination (outside of the inconvenience of air entrainment). If population growth and water use rates continue as projected, and the wells continue to meet water quality requirements, water supply improvements do not appear to be needed. In addition, regularly checking flowmeters for accuracy and regularly completing a water audit are important procedures that conserve water and help prolong well pump life.

It is recommended that the City construct a pipeline connecting Well No. 1 to the Middle Reservoir in order to let the entrained air from this well dissipate inside the reservoir. Based on the City's belief that the air entrainment seems to be moving in a northwesterly direction, it is not recommended that such transmission lines be constructed for City Wells No. 8 and 9 unless entrained air develops in these sources at a later date. The costs associated with the transmission line for Well No. 1 are presented in Chapter 6.

It is strongly recommended that the City pay close attention to static and pumping water levels over time for their supply wells. The static water level trends indicated in Figure 3-2 for the City wells show that static water levels in the Milton-Freewater area have declined in the past but do appear to have stabilized and possibly increased. The 7,520 gpm total capacity currently available to the City will most likely be reduced if the wells lose efficiency over time or if the static water levels continue to decline in the future. The City could be faced with a major water supply shortage before the year 2028 if declining static water level trends worsen.

WELL SUMMARY

| Well No. | Date Drilled | Depth in feet (Initial/extended) | Casing / Bore | Grout Seal into Confining Layer | Pump Motor Type | Motor Hp | Pump Type | Make Depth | Flow Capacity (estimated gpm) | Floor | Emergency Power | Treatment | Meter | Comments |
|------------|--------------|----------------------------------|---|---------------------------------|-----------------|----------|------------------|------------|-------------------------------|----------|-----------------|--------------|-------|--------------------|
| Well No. 1 | 1938 | 636/656 | 12" to 100', 12" open to depth | Yes, 40' into rock | US Electric | 200 | Vertiline | 430 | 830 | concrete | No | Hypochlorite | Yes | |
| Well No. 2 | 1944 | 902 | 16" to 99', 16" open to depth | Yes, 36' into rock | US Electric | 250 | Vertiline | 590 | 750 | concrete | yes (350 KVA) | Hypochlorite | yes | |
| Well No. 3 | 1946 | 550/596 | 20" to 43', 16" to 100', 16" open to depth | Yes, 21' into rock | US Electric | 200 | Vertiline | 452 | 1150 | concrete | No | Hypochlorite | yes | |
| Well No. 5 | 1936 | 502/512 | 18" to 40', 12" to 172', 12" open to depth | Yes, 12' into rock | GE | 150 | Peerless Turbine | 280 | 1100 | concrete | No | Hypochlorite | yes | upgrade in process |
| Well No. 6 | 1960 | 952 | 20" to 45', 16" to 61', 16" open to 210', 12" open to depth | No, casing ends at rock | US Electric | 250 | Layne Bowler | 424 | 1400 | concrete | No | Hypochlorite | yes | |
| Well No. 8 | 1965 | 888/1051 | 20" to 480', 12" open to 829', 10" open to depth | Yes, 449' into rock | GE | 400 | Layne Bowler | 497 | 1490 | concrete | No | Hypochlorite | yes | |
| Well No. 9 | 1951 | 918 | 18" to 193', 16" to 296', 16" concrete to 321', 16" rock to 695', 12" cement to 724', 12" open to depth | | US Electric | 125 | A.D. Cook | 360 | 800 | concrete | No | Hypochlorite | yes | |



CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN

WELL SUMMARY


TABLE
3-1

MILTON-FREEWATER AREA WELL DATA

| Well Identification ¹ | Well Owner | Date Drilled | Depth Drilled (feet) | Static Water Level ² (feet) | Tested Well Yield ² (gpm) | Water Level While Pumping (feet) |
|----------------------------------|---|--------------|----------------------|--|--------------------------------------|----------------------------------|
| A | City of Milton-Freewater (formerly Key Equipment Co). | 2/16/1945 | 528 | 49 | 1,350 | 81 |
| B | Rogers Canning Co. | 4/20/1944 | 702 | 117 | 1,200 | --- ³ |
| C | Rogers Canning Co. | 6/14/1951 | 560 | 125 | 1,000 | --- ³ |
| D | J. Frank Schmidt & Son Co. | 6/27/1968 | 660 | 302 | 925 | 277 |
| E | Fred Kaup | 5/30/1985 | 102 | 36 | 500 | --- ³ |
| F | Clyde Harris | 1/25/1968 | 195 | 47 | 472 | 49 |
| G | Sam Lefore | 1/29/1981 | 243 | 100 | 450 | 126 |
| H | Oland Hubbs | 1914 | 258 | 12 | 450 | 72 |
| I | Willa M. Arnoldt | 1/1/1920 | 90 | 15 | 400 | 30 |
| J | Milton Nursery Co. | 1925 | 30 | 10 | 400 | 20 |
| K | Milton-Freewater Cemetery District | 2/11/1996 | 706 | 356 | 150 | --- ³ |
| L | Dick Frye | 2/20/1961 | 706 | 10 | --- ³ | --- ³ |
| City Well No. 1 | City of Milton-Freewater | 3/1/1938 | 656 | 202 | 1,484 | 384 |
| City Well No. 2 | City of Milton-Freewater | 5/6/1944 | 902 | 105 | 1,135 | 178 |
| City Well No. 3 | City of Milton-Freewater | 6/1/1946 | 596 | 50 | 450 | 133 |
| City Well No. 5 | City of Milton-Freewater | 1936 | 502 | 120 | 750 | 167 |
| City Well No. 6 | City of Milton-Freewater | 12/22/1950 | 952 | 127 | 1,500 | 272 |
| City Well No. 8 | City of Milton-Freewater | 4/14/1965 | 1,051 | 269 | 1,529 | 466 |
| City Well No. 9 | City of Milton-Freewater | 6/22/1951 | 918 | 205 | 1,501 | 295 |

- Notes: ¹ See Figure 3-1 for approximate well locations.
² Unless otherwise noted, static and pumping water levels, tested yield, etc., were generally obtained just after drilling. Well yields were tested by air methods, bailers, or pumps and should be considered approximate. Actual yield may vary substantially under continuous prolonged pumping conditions.
³ Data unavailable.

T.5-6 N., R.35-36 E., W.M.
1"= 2000'



165151



CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
AREA WELL LOCATIONS

FIGURE
3-1

Static Water Levels




FIGURE 3-2

CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
STATIC WATER LEVELS



CHAPTER 4

WATER STORAGE

INTRODUCTION

This chapter presents information on the City of Milton-Freewater's water storage facilities. The purpose for storage in municipal water systems is discussed and the types of storage facilities available are outlined. The condition and needs of the City's existing storage facilities are detailed and recommended storage requirements are presented. Recommendations for improving the City of Milton-Freewater's storage facilities are outlined. Cost estimates for the recommended improvements are presented in Chapter 6, Recommended System Improvements.

GENERAL

Water storage facilities are constructed to achieve several purposes. First, storage reservoirs are often used to provide control for well operation. When a reservoir drops a few feet or more from the full level, the water level can be used as a control for well pump activation. The amount of storage required for this type of control is called "operating storage." Second, stored water must be available to supply water during periods in which the demand for water exceeds the available water supply. This reserve is called "equalization storage." Third, reserve storage is usually provided to supply unusually large demands such as fire flows. This is referred to as "fire reserve." Finally, storage is often provided for emergencies that may arise and interfere with production from water supply sources. Such emergencies could be created by power outages, mechanical equipment failure, or sudden water contamination. The amount of storage to be provided for an emergency depends on the likelihood and the impact of such an occurrence. The amount of emergency storage provided usually becomes a balance between what is needed and what can be afforded. This storage allowance is referred to as "emergency reserve."

Storage facilities can be located at approximately the same elevation as the entrance to the water distribution system. Storage facilities of this type require continuous operation of a booster pump system to maintain distribution system pressure. Storage facilities can also be elevated, in which case the water is stored at an elevation considerably above the distribution system in order to generate adequate system pressures. For example, a water elevation of 120 feet above a distribution system would be required to generate a distribution system static pressure of approximately 50 pounds per square inch (psi). Reservoirs may be elevated by locating them on natural ground high enough above the service area (this is the case for the City's three reservoirs) or by construction on top of a steel support frame.

Storage reservoirs are generally constructed of either steel or reinforced or prestressed concrete. The choice is usually based on an economic analysis made for the particular installation. Reservoirs may be constructed either above ground or buried, with the choice made on cost, location, and community acceptance. The remainder of this chapter reviews the City's existing storage facilities, presents a discussion of future storage needs, and provides alternatives for satisfying those needs.

EXISTING FACILITIES

The City's existing storage facilities consist of three reservoirs that represent a total of 5 million gallons of storage. Because of the locations of the existing reservoirs, the City identifies them as the North Reservoir, the Middle Reservoir, and the South Reservoir. The North Reservoir is a 2-million-gallon (MG) steel reservoir located at an elevation of approximately 1,140 feet above mean sea level (MSL). This reservoir was reportedly constructed in 1961, is about 43 feet tall, and is 93 feet in diameter. The Middle Reservoir is a 1 MG steel reservoir located at an elevation of approximately 1,215 feet above MSL. This reservoir was constructed in 1956 to a height of 31.5 feet with a diameter of 74 feet. The South Reservoir is a 2 MG steel reservoir located at an elevation of approximately 1,445 feet above MSL. This reservoir was constructed in 1999, is 23.5 feet tall, and is 120 feet in diameter.

Both the North and Middle Reservoirs were television inspected and cleaned on January 6 and 7, 1997, respectively. Video logs were completed for the interior inspections without draining the water from the reservoirs. The reservoir inspections were completed by LiquiVision, Inc. LiquiVision, Inc., did not make recommendations in their reports concerning maintenance or improvements for either reservoir. The City indicated that, to the best of their knowledge, neither reservoir had been cleaned since they were constructed. The City also indicated that a regular inspection and cleaning program would be implemented in the future for the City's reservoirs.

The North 2 MG steel reservoir was reportedly in relatively good condition at the time of the LiquiVision, Inc., survey. The survey identified an average sediment depth of 1/8 inch in the reservoir, which was approximately 3 cubic yards of sediment over the entire reservoir floor. LiquiVision, Inc., estimated that the primary components of the sediment were manganese and iron. The sediment was removed from the reservoir at the time of inspection. The reservoir inspection summarized the condition of the interior paint system as being in overall good condition with a few specific rust spots indicated at the time of the inspection.

LiquiVision, Inc., also inspected the Middle 1 MG steel reservoir. This reservoir was also reportedly in relatively good condition at the time of the survey. The survey identified an average sediment depth of one inch in the reservoir, which equated to approximately 13 cubic yards of sediment over the entire reservoir floor. The divers also found an anode from the cathodic protection system on the floor near the center of the reservoir, which apparently fell from the ceiling. The sediment and anode were removed from the reservoir. The reservoir inspection summarized the condition of the interior coal tar coating system as being in overall good condition beneath the water surface although the coating above the water line was peeling and separating from the wall. A copy of the reservoir inspection video log is included in Appendix H.

EXISTING PRESSURE ZONES

The City of Milton-Freewater has three pressure zones in their existing distribution system. Pressure zones are discussed in greater detail in Chapter 5, Distribution System, and are also discussed briefly hereafter as they relate to the existing storage reservoirs. Fire flow capabilities in each pressure zone, as well as

pressure reducing valves, booster pumps, and other distribution system issues, are also discussed in Chapter 5.

Elevations in the current City Limits of Milton-Freewater range from approximately 950 feet above MSL in the northwest area of the City to as high as 1,270 feet above MSL to the southeast. The service elevation of the City's existing water system ranges from approximately 955 to 1,150 feet above MSL, a difference of 195 feet, which represents a static water pressure range of approximately 84 psi. In systems with substantial elevation changes such as Milton-Freewater's, the system must be divided into pressure zones that are designed to keep water pressure within reasonable operating ranges. Ideally, these pressure zones would be designed to provide minimum static water pressures of 40 psi at the higher elevation areas in the zone and a maximum static water pressure of 80 psi at the lower elevation areas in the zone. Because of the large elevation difference within Milton-Freewater, the City has had to expand these pressure zones to provide minimum static water pressures at approximately 35 psi and maximum static water pressures near 100 psi. Figure 4-1 shows the existing pressure zone boundaries within the City.

As shown on Figure 4-1, the Middle and South Pressure Zones have a strip of area between the two zones (1,165 to 1,235 in elevation) that does not fit within the 35 psi to 100 psi operating pressure criteria. Most of this area is located on rock bluffs in the southwest area of the City and is not likely to be developed. However, areas in the southeast portions of the Urban Growth Boundary that develop within this band in the future will need to be supplied by the South Reservoir and will likely need to have individual pressure reducing valves (PRVs) installed on the water service lines. Alternatively, a larger area could be served by a main line PRV station.

The City of Milton-Freewater's three pressure zones have developed over the years to meet the City's expanding water service needs. The distribution system and water system components serving each existing pressure zone are depicted on the Water System Map contained in a pocket at the end of this Plan.

STORAGE REQUIREMENTS

Water storage is usually provided for several purposes as outlined at the beginning of this chapter. Various methods are used to calculate the volumes of each type of storage component required. Most involve a rational approach to estimating the volume of each storage component consisting of operational, equalization, emergency, and fire reserve. The decision can then be made as to which component controls, and what storage volumes, will actually be necessary. For example, the decision may be made to provide storage for operational, equalization, and fire reserve only, assuming any emergency storage would be available from the fire reserve. If this option were selected, there may not be adequate fire storage available if a sustained power outage occurs or if a well pump is out of service for some reason. An advantage associated with Milton-Freewater's water system is that multiple supply sources and storage reserves can be relied upon during emergency conditions, providing considerable system redundancy.

Normally, the four components of storage (operational, equalization, emergency, and fire reserve) are determined for an entire city, if the city has one pressure zone, or if the city is served from only one large reservoir through adequately sized pressure reducing valves. The City of Milton-Freewater currently has three pressure zones, each with its own storage component needs. The analysis of each of the four storage components is presented hereafter for each pressure zone.

Fire Reserve Storage. Reserve storage for fire suppression is usually determined from either the ISO Commercial Risk Services, Inc. (ISO) recommended fire flow, or the fire flow recommended by the City's fire chief. Based on the maximum ISO recommended fire flow, a 3,500 gallon per minute (gpm) fire flow with a two-hour duration has been set as the maximum design fire flow for Milton-Freewater. All three of the City's pressure zones provide water service to commercial areas. Therefore, the maximum recommended fire flow for commercial areas of 3,500 gpm has been used to determine fire reserve storage requirements for all three pressure zones. A summary of the required fire flows and corresponding fire reserve storage volume for each of the three pressure zones is as follows:

FIRE RESERVE STORAGE REQUIREMENTS

| Zone | ISO-Required Fire Flow (gpm) | Duration (hours) | Total Required Storage Volume (gallons) |
|--|------------------------------|------------------|---|
| North | 3,500 | 2 | 420,000 |
| Middle | 3,500 | 2 | 420,000 |
| South | 3,500 | 2 | 420,000 |
| Total required fire reserve storage volume | | | 1,260,000 |

Emergency Storage. Emergency storage is usually provided for a minimum of one to a maximum of three days' supply in the event of a power outage, mechanical problem, or other problems that would interrupt the supply of water. In most cases this would be the minimum amount of time to repair or replace a well pump or other equipment. Because Milton-Freewater has several well sources and has standby power available for one well, it was assumed one day of emergency storage at average use rates would be adequate for emergency reserves. To provide the minimum one-day emergency reserve at the present estimated average use rates and population, a total emergency storage volume of approximately 1,965,000 gallons would be required. This one-day emergency storage volume would be approximately 2,925,000 gallons at the projected design population of 9,750 in the year 2028. In order to estimate emergency storage volumes required for each of the three proposed zones, an estimate of the anticipated population of each zone was completed. It was assumed the North and Middle Pressure Zones would contain the majority of the existing and future residents in the City. A summary of the required emergency storage in each zone is as follows:

EMERGENCY RESERVE STORAGE REQUIREMENTS

| Zone | Average Design Flow (gpcd) | Assumed Population (year 2028) | Total Required One-Day Emergency Storage Volume (gallons) |
|--------------|-------------------------------|--------------------------------------|---|
| North | 300 | 4,713 | 1,413,900 |
| Middle | 300 | 4,713 | 1,413,900 |
| South | 300 | 324 | 97,200 |
| TOTAL | | 9,750 | 2,925,000 |

Because of redundancy in the City's water supply system and the ability of higher elevation zones to serve lower elevation zones, the emergency storage volumes allocated to each zone, as presented above, may appear excessive. However, during an emergency event, such as an extended duration power outage, all of the City's water supply sources, except Well No. 2, would be unavailable. The South Pressure Zone could not be supplied with more water, and the entire North Pressure Zone would be supplied by a single PRV connection to the Middle Pressure Zone (under normal operating conditions). Therefore, the emergency reserve allocations presented above for each zone are felt to be appropriate.

Operating Storage. Operating storage is provided to facilitate operation of the City's wells and booster pumps. All of the City's booster pump stations are controlled by reservoir water level sensing systems installed in the reservoirs they serve.

Currently, the City's wells are activated when various water depths are reached in the reservoirs and deactivate when the storage reservoir reaches its full capacity or a designated depth. Further details on these activation and deactivation levels are described in Chapter 3, Water Supply and Treatment. The City has relatively low set points for well activation to provide improved "turnover," or circulation in the storage reservoirs. However, it is operationally preferable to have as much water stored in the reservoirs as possible at all times to meet emergency needs, such as fire flow demands. For example, if the City were to have a primary supply well failure when reservoir water depths happened to be at low levels, there would be a minimum amount of storage available and the other supply wells to the reservoir may not be able to meet the demand at the time. A balance needs to be determined both to provide the desired water circulation and to keep a reasonable amount of water in storage reserve. It is recommended the City raise the primary well activation set points to within 4 feet below the reservoirs' full level and adjust the secondary well activation set points accordingly. By raising the set points to the recommended levels, 10 to 17 percent of the reservoirs' volume will be circulated during each cycle, and the water stored in reserve will increase to better accommodate emergency conditions.

For the purposes of determining the recommended operating storage reserve for each of the reservoirs, it was assumed the change in water depth between activation and deactivation of the wells would be 4 feet. The resulting operation storage in each zone is as follows:

OPERATING RESERVE STORAGE REQUIREMENTS

| Source Reservoir and Associated Service Zone | Flow Control Limits | Total Required Operational Storage Volume (gallons) |
|---|---------------------------------|---|
| North | 4 feet below full storage level | 190,400 |
| Middle | 4 feet below full storage level | 128,700 |
| South | 4 feet below full storage level | 338,400 |
| Total required operational reserve storage volume | | 657,500 |

Equalization Storage. Equalization storage must be provided to balance out the difference between peak hour demand and water supply capacity during a peak day demand period. An empirical method for estimating the volume of equalizing storage uses the difference between the peak hour flow and the peak water supply flow for a specified number of peak hours per day. To determine equalization reserve storage for each pressure zone, the estimated population for each zone used earlier to calculate emergency reserve was also used to estimate the peak daily flow in each zone. A summary of the required equalization reserve storage in the year 2028 for each zone is as follows:

EQUALIZATION RESERVE STORAGE REQUIREMENTS

| Pressure Zone | Peak Daily Flow (gpm) ¹ | Peak Instantaneous Flow (gpm) | Available Flow (gpm) | Total Required Equalization Storage Volume (gallons) for 2.5 Hours |
|--|------------------------------------|-------------------------------|----------------------|--|
| North | 2,539 | 6,348 ² | 3,650 ³ | 404,700 |
| Middle | 2,539 | 6,348 ² | 3,870 ⁴ | 371,700 |
| South | 0 | 0 | 1,330 ⁵ | 0 |
| Total required equalization reserve storage volume | | | | 776,400 |

- ¹ Assumes 4,875 people in each of the North and Middle Pressure Zones used 750 gallons per capita per day (gpcd) of water.
- ² Peak instantaneous flow is 2.5 times peak daily flow.
- ³ Assumes available supply is through City Wells No. 3, 5, and 6.
- ⁴ Assumes available supply is through City Wells No. 1, 2, 8, and 9.
- ⁵ Assumes available supply is a booster pump system of two pumps within the Well No. 9 pump house capable of supplying 450 gpm and 880 gpm, for a total supply of 1,330 gpm.

Summary of Storage Requirements. The four storage components indicate a total of approximately 5,618,900 gallons of storage is needed to meet the year 2028 design criteria (see Table 2-4). The City's current available storage total is 5,000,000


gallons. Due to the City of Milton-Freewater's multiple groundwater sources and the redundancy of the City's three-reservoir system, this 618,900-gallon deficit in storage capacity is not a significant concern for the City. This is justified because it is very unlikely that the fire reserve capacities evaluated for each reservoir will be used at the same time (a savings of 840,000 gallons of total water storage), combined with the fact that the large number of wells owned by the City provides increased flexibility in supplying water during emergency conditions. Therefore, it is not recommended that the City undertake a new reservoir project during the planning period (through the year 2028) unless water use conditions in excess of those predicted with this Plan are seen. If the City elects to begin to look at a new reservoir in the future, it is recommended that the City extend their focus beyond the planning period discussed in this Plan.

Water storage reservoirs, when properly maintained, typically remain usable for at least 40 to 100 years, or more. Because of this, should the City elect to construct a new reservoir, it may desire to select the size of the reservoir based on the projected population for the year 2048. The cost associated with construction of a larger reservoir is usually less when compared with constructing a smaller reservoir at one point and then another reservoir at a later date to meet the City's long-term storage needs. Based on the current estimated water use volumes, the selected 2.0 percent annual population growth rate, one day of emergency water storage, the design fire flow of 3,500 gpm, the City's three pressure zones, and assuming the City's total available water supply is 7,520 gpm (the total capacity of the City's wells), the City's year 2048 storage requirements are estimated to be approximately 7,952,000 gallons. This results in a storage requirement outside the City's current 5 million gallons of storage capacity of 2,952,000 gallons, which could be accommodated through a 3 MG reservoir.


The existing City reservoirs will need maintenance at some point in the future to remain in service. It is recommended that the City complete maintenance on the reservoirs to ensure they continue to remain in reliable service. Maintenance for the City's steel reservoirs would include a continued cleaning program and cleaning, sandblasting, and painting the interior and exterior of the Middle Reservoir to ensure it remains in good condition.

RECOMMENDED STORAGE RESERVOIR IMPROVEMENTS

The City should continue its current maintenance practices on the three existing reservoirs to ensure they continue to provide reliable storage. The Middle and North Reservoirs will likely need recoating during the planning period of this study. The interior and exterior of the steel Middle and North Reservoirs should be cleaned, sandblasted, and painted. A cost estimate for the recommended maintenance items on the Middle and North Reservoirs is presented in Chapter 6, Recommended System Improvements.



165151



**CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
PRESSURE ZONES**

**FIGURE
4-1**

CHAPTER 5

DISTRIBUTION SYSTEM

INTRODUCTION

This chapter discusses the existing water distribution system delivering water to the City's residential, commercial, and industrial users. Components of the distribution system include pipelines, valves, water service lines, and fire hydrants. The distribution system has been evaluated for both present and future City needs. Recommendations have been developed to address distribution system needs and provide future service to help meet both Department of Human Services - Drinking Water Program (DWP) requirements and ISO Commercial Risk Services, Inc. (ISO) fire flow requirements. Cost estimates for the recommended distribution system improvements are presented in Chapter 6, Recommended System Improvements.

EXISTING SYSTEM

Information related to the City of Milton-Freewater's water distribution system has been obtained from the City's computer-aided drafting (CAD) layout of the distribution system, City records, and conversations with Howard Moss, former Water System Superintendent. The system consists of approximately 45 miles of pipe, with 20 percent of the system having been installed in the 1940s or earlier. The water mains range from 2 inches to 20 inches in diameter with materials including asbestos concrete, cast iron, ductile iron, galvanized iron, polyvinyl chloride (PVC), Reinforced Concrete Pressure Pipe (RCP), and steel pipe. The few areas in the City served by 2-inch lines were developed in the 1940s. Over the last few decades, replacement and installations have been made with C900 PVC pipe. A map of the existing distribution system is contained in a pocket at the end of this Plan.

In general, the distribution system is reported to have good hydraulic performance, is well looped (providing supply to developed portions of the City from two or more directions), and has relatively large diameter water distribution mains spread throughout the service area. The City indicated that the water main lines are generally in good condition. The City has an annual water main replacement program in place in order to alleviate local problems that may arise in the system.

DISTRIBUTION SYSTEM WATER QUALITY

The City obtains routine samples from the distribution system for analysis of total and fecal coliform. The City randomly obtains eight routine samples per month. For the period from July 5, 2001, through November 24, 2008, total and fecal coliform has not been detected in samples obtained during routine monthly sampling events.

The City also obtains samples from the distribution system biannually for chemical analysis of total lead and total copper. For the period from 1993 through 2007, concentrations of lead ranged from not detected to 0.005 milligrams per liter (mg/L). The Environmental Protection Agency (EPA) action limit for total lead in

municipal water systems is 0.015 mg/L. Copper was detected at concentrations ranging from 0.058 to 0.14 mg/L. The EPA action level for copper is 1.3 mg/L. Based on the lead and copper analytical results from 1993 through 2007, all detected concentrations of lead and copper were less than their corresponding EPA action levels. A summary of the tests is included in the DWP's Water Quality Testing Summary in Appendix A.

Stagnant water in the distribution system can also lead to water quality problems. In a water distribution system the size of Milton-Freewater's, some dead-end mains are an unavoidable result of expanding the system to accommodate the City's growth. These dead-end lines can result in stagnant water sitting in the pipe for periods of time and decreasing water quality when demands are not high. The City has a program in place to flush these lines twice a year or as required when customer complaints are received.

EXISTING PRESSURE ZONES

The service elevation of the City's existing water system ranges from approximately 955 to 1,150 feet above MSL, or a difference of 195 feet, representing a static water pressure range of approximately 84 pounds per square inch (psi). A minimum pressure of 20 psi under all conditions is required by the DWP and an upper limit of 80 psi is suggested for residences in the State of Oregon's Plumbing Specialty Code, 2000 edition (based on 1997 Uniform Plumbing Code). Typically, pressures in the distribution system should be higher than the minimum pressure suggested by the DWP and can be higher than the suggested maximum residential pressure. Minimum distribution system pressures are generally considered to be 20 psi at the property line (as suggested by the DWP) while maximum system pressures can often reach about 90 to 100 psi in the distribution system.

In systems with significant elevation changes over a substantial service area, such as Milton-Freewater's system, the system must be divided into pressure zones that are designed to keep water pressure within reasonable operating ranges. Prior to the merger of Milton and Freewater, both of the cities operated their own water system. Shortly after consolidation, the decision was made to operate the systems at separate pressure levels. This decision was made based on the understanding that the Freewater system would not withstand the higher operating pressures of Milton's system. The pressure difference results from a 75-foot base elevation difference between the North and Middle Reservoirs (formerly the Milton and Freewater Reservoirs, respectively).

The City of Milton-Freewater currently operates three pressure zones in their distribution system. The North Pressure Zone serves the north area of the City of Milton-Freewater to a southerly limit of Broadway Avenue. The Middle Pressure Zone covers an area extending from Broadway Avenue to the south end of the City Limits, excluding a small area in the southwest portion of town. The third zone is relatively new and is called the South Pressure Zone. It serves the higher ground in the southeast areas of the City and further south along U.S. Highway 11 within the Urban Growth Boundary. Based on the layout of these pressure zones, it is possible that some

customers in Milton-Freewater will experience pressures in excess of the 80 psi maximum service pressure suggested in the Plumbing Code. Where possible, each zone has been designed with a minimum static water pressure of 35 psi near the highest elevation in the zone and a maximum static water pressure of 100 psi near the lowest elevation in the zone.

Typically, customers will not complain about excessive pressure unless plumbing fixtures such as hot water heaters begin having pressure-related problems. A system such as Milton-Freewater's that has operated with these pressures for over 50 years is likely not going to have many over-pressurization-related problems because customer's systems have been installed to accommodate the pressures. However, any adjustments to the pressure zone boundaries could result in over-pressurization problems.

The North Pressure Zone has static pressures ranging from 65 psi at the south end of the zone up to 98 psi at the extreme north end of town near Powell Road. The North Pressure Zone can be supplied by the Middle Pressure Zone through a pressure reducing valve (PRV) located at the intersection of DeHaven Street and East Broadway Avenue. This PRV is normally closed but it is set to open when the North Pressure Zone system falls 20 psi below the Middle Pressure Zone. A separate isolation valve between these two zones is located at N.E. 1st Avenue and U.S. Highway 11. This valve is closed during normal system operation but can be opened in emergency conditions.

The Middle Pressure Zone creates static pressures of 100 psi near Broadway Avenue down to 40 psi at the higher elevations along the bluffs in the southwest area of the City. The lowest pressures are seen on Jacquelyn Street, which is located at the highest point in the service area on the southwest hillside.

Static pressures in the South Pressure Zone range from 50 psi near the Sykes Corporation to 126 psi at Well No. 9. The 100 psi static pressure corresponds to an elevation of approximately 1,235 feet, which creates a gap between the Middle and South Pressure Zones as discussed in Chapter 4, Water Storage. Operation of the South Pressure Zone is tied to the Middle Pressure Zone in two critical ways. First, booster pumps located at the Well No. 9 pump house are controlled by a pressure transducer at the South Reservoir, which activates the booster pumps when the reservoir level is low. Water is then drawn from the Middle Pressure Zone and pumped up to fill the South Reservoir. Second, water being fed out of the South Reservoir is then cycled back into the Middle Pressure Zone through a PRV located in the Well No. 9 Pump House. This PRV is set to allow a constant 40 gallons per minute (gpm) flow from the South Pressure Zone to the Middle Pressure Zone (to help circulation of water in the South Reservoir) and increase this flow when pressures drop in the Middle Pressure Zone.

FIRE PROTECTION

The City's water supply, storage, and distribution systems provide good fire protection. Fire flow tests were performed on some of the City's fire hydrants on April 8,

1987, by ISO. The results of the hydrant tests are summarized in Table 2-2 (Chapter 2) and presented in Appendix C. The observed and calculated fire flow discharges available from the hydrants tested are shown on Table 2-2. Based on the ISO test results, the City of Milton-Freewater's water system is generally able to deliver fire flows ranging from approximately 580 to 2,090 gpm with residual pressures remaining well above the minimum required 20 psi. The fire flow tests also utilize a theoretical formula to estimate available fire flows, which are much higher, as shown on Table 2-2 in Chapter 2.

It is important to realize that physical limitations exist in most water systems that do not normally allow fire flows as high as those calculated by the ISO tests. For example, the available fire flows determined by ISO using a theoretical formula assumes the water supply "feeding" the tested area is generally not limited and the 20 psi residual pressure resulting from the fire flow will occur in the general area of the fire hydrants that are tested. In reality, there are likely other connections in the distribution system, such as higher elevation users in the City, that would fall below 20 psi sooner than the formula predicts due to their elevation. In this situation, the theoretical formula over-estimates the available fire flows.

The fire flow tests completed by ISO were conducted by opening two fire hydrants at one time. Thirteen areas were tested (two hydrants at each area), and each hydrant provided flows ranging from approximately 580 gpm to 2,090 gpm. Realistically, individual fire hydrants can only provide flows in the range of 800 to 1,000 gpm from a small port to up to nearly 2,000 gpm from both small ports and the large "pumper" port, assuming the hydrant has a large port. To actually achieve the available fire flows at 20 psi indicated by the ISO calculations, several fire hydrants would need to be completely opened at one time.

Another limitation of actual fire flow capabilities is the supply of water feeding the area of the fire. The City's distribution system is well looped and has a good network of 8-inch diameter and larger water main lines. The capacity of the system to provide water flow is excellent. However, it must be understood that the water main lines supplying the distribution system from the City's reservoir will tend to limit the available fire flow as well. During a large demand on the distribution system, such as a fire flow, the 16-inch and 20-inch lines from the North and Middle Reservoirs can likely deliver flows in the range of 4,000 to 6,000 gpm and then smaller distribution lines branching off these main lines will further reduce the available flows due to hydraulic limitations.

Generally, the City's water system is capable of providing excellent fire flows and has an excellent fire rating from ISO. The discussion presented herein is intended to provide caution concerning the actual available fire flows from the City's distribution system and fire hydrants. Considering the limitations previously discussed, the City's water system appears capable of meeting the maximum recommended ISO fire flow of 3,500 gpm while maintaining 20 psi in the system where this type of flow is needed (i.e., commercial and industrial areas).

DISTRIBUTION SYSTEM PIPING IMPROVEMENTS

Some minor improvements to the distribution system are recommended. The improvements discussed in this section are intended to improve system circulation by providing looping and eliminating dead-end lines, where feasible. Some areas of water main lines in the City are reportedly cast iron and steel pipe that were most likely installed in the 1940s or earlier. The City intends to replace some of these main lines in the near future.

In general, the City's distribution system is in good condition and is well looped. However, approximately 70 dead-end lines were tallied throughout the City's water service area. This relatively high number of dead-end lines is attributable to the unique geological features of the area (i.e., rock bluffs, the Walla Walla River, etc.) that limit the extent to which ideal looped water systems can be constructed.

Table 5-1 summarizes the distribution system improvements currently planned by the City. Many of these improvements would replace aging main lines, improve system circulation, provide looping for existing dead-end lines, and improve fire flows throughout the City's water service area. It is recommended that these improvements are made with a minimum of 8-inch diameter C900 PVC or ductile iron water lines. The improvement list provided by the City is not presented in a particular priority. The City selects which improvements to implement based on several factors such as budget, other area utilities, pipe condition, planned paving projects, etc.

The City indicated that the majority of the residential service lines are in satisfactory condition. The older galvanized iron service lines are likely to develop leaks as time progresses, but it is anticipated that the City's meter testing and maintenance program will address service line work on an as-needed basis during the planning period of this Water System Master Plan. However, as a general rule, all service lines connected to a water main line should be replaced when the main line is upgraded.

WATER LOSS

One important monitoring activity that is currently being performed by the City is conducting a periodic audit of the volume of water supplied to the system versus the volume of water that is being metered and used by its customers. The difference between billed water use and total water supplied is termed "unaccounted for water." A system that has tight controls on its water consumption generally maintains at least 90 percent accountability for all water. That is, 90 percent of the water supplied to the system can be accounted for in usage through service meters, etc. Systems that have a water accountability of less than 90 percent should look for the cause of the water usage discrepancies and make corrections where possible.

The City has begun completing annual water audits. The water audit results for the most recent six years are presented hereafter.

WATER AUDIT RESULTS

| Year | Gallons Produced | Gallons Sold | City Use (gallons) | Gallons Lost | Calculated Water Loss |
|------|------------------|--------------|--------------------|--------------|-----------------------|
| 2002 | 897,069,000 | 710,628,000 | 23,550,000 | 162,891,000 | 18.2% |
| 2003 | 943,157,000 | 749,140,000 | 23,550,000 | 170,467,000 | 18.1% |
| 2004 | 869,999,000 | 649,930,000 | 23,550,000 | 196,519,000 | 22.6% |
| 2005 | 824,892,000 | 634,590,000 | 23,550,000 | 166,752,000 | 20.2% |
| 2006 | 679,488,000 | 565,564,000 | 23,550,000 | 66,824,000 | 9.8% |
| 2007 | 714,993,000 | 550,106,000 | 23,550,000 | 141,337,000 | 19.8% |
| 2008 | 613,669,000 | 504,461,000 | 57,464,000 | 51,744,000 | 8.4% |

The above results show that the City regularly experiences water loss in excess of 10 percent, but has observed water loss below 10 percent in 2006 and 2008. It is possible the older service mains and the service lines being served by these older main lines are a primary source for the unaccounted for water loss. The City should investigate all sources of potential water loss and make corrections where possible in an attempt to maintain at least a 10 percent water loss rate.

The City currently has a leak detection program in place that has led to the replacement of a leaking water main line from Well No. 8 to South Main Street. The City also has a meter change-out program in place. When suspected leaks are discovered by routine monitoring of flow records, the City determines the location of the leak and completes repairs as soon as practically possible. The City is also annually replacing portions of their pre-1940s steel water main lines, which has helped reduce water loss. By using these monitoring techniques to identify suspected leaks and replace old lines, the City is proactively using the Best Management Practices (BMPs) available to them to identify water losses and improve the distribution system.

MAINTENANCE RECORDS

One important operational function of the City's distribution system is to keep accurate records of various system components. These records become invaluable as time passes in terms of planning future improvements and replacing old or deteriorated components. It is recommended that the City keep accurate records on all water meters installed so that, in the future, these meters can be periodically pulled, checked for accuracy, and replaced as appropriate. The distribution system evaluation in this Water System Master Plan did not include determining existing fire hydrant and valve condition. It would be wise for the City to keep accurate records on all hydrants, valves, and other distribution system components. The City does currently check hydrants annually for proper operation. This program should be expanded to include all water valves, exercising them at least annually, with records kept on their operating condition, location, etc.

WATER MANAGEMENT AND CONSERVATION PLAN

One method available to the City to reduce possible water loss and help conserve water is to complete a Water Management and Conservation Plan (WMCP). The City completed a WMCP in 2000 and submitted it to the Oregon Water Resources Department (OWRD) (prepared by Anderson-Perry & Associates, Inc.). These plans are required by the OWRD as outlined in Oregon Administrative Rules (OAR) Chapter 690, Division 86. Completion of a WMCP is usually required when a City applies for a new water right from OWRD. If a WMCP is completed and some of the conservation measures are implemented, the City may find, after sufficient time has passed, that their average daily water use has reduced. By having a WMCP in place, the City will also be able to review applications for new wells within a five-mile radius of the City's wells and voice concerns to the Water Resources Department about potential impacts to the City's water source, as described in the Umatilla Basin Program (OAR 690-057) included in Appendix I.

The OARs applicable to WMCPs also require a 10-year update to the plans. The City is currently preparing an update to their 2000 WMCP. The updated WMCP will be available under separate cover in the summer of 2009.

SUMMARY AND RECOMMENDATIONS

In general, the City's distribution system provides good fire protection and, in most cases, is adequately looped. Some water main line improvements are recommended to enhance system reliability and hydraulic capacity and, where practical, eliminate dead-end lines. These improvements, as outlined in this chapter, include installing new water main lines in a few key areas to improve looping, circulation, and fire flow capacity. The recommended distribution system improvements and estimated costs for the improvements are outlined in Chapter 6, Recommended System Improvements.

DISTRIBUTION SYSTEM IMPROVEMENTS

| Imp. No. | Description and Location of Improvements | Existing Size (in) | Existing Pipe Material | Year Installed | Approximate Length of Improvement (ft) |
|----------|---|--------------------|------------------------|----------------|--|
| 1 | N Elizabeth, N of NE 11th to Parallel | 2 | Galvanized | 1946 | 267 |
| 2 | NE 11th, N Elizabeth to Parallel | 4 | Steel | 1946 | 270 |
| 3 | N Elizabeth, NE 10th North of NE 11th | 4 | Steel | 1946 | 525 |
| 4 | Miller, NE 4th to end | 4 | Cast Iron | 1946 | 520 |
| 5 | NE 1st and NW 1st, Well No. 3 to Depot | 10 | Steel | 1946 | 765 |
| 6 | Well No. 3, Russell to Broadway to DeHaven | 12 | Cast Iron | 1946 | 690 |
| 7 | DeHaven, Broadway to SW 2nd | 12 | Cast Iron | 1947 | 1,450 |
| 8 | SW 2nd, DeHaven to S Elizabeth | 12 | Cast Iron | 1947 | 620 |
| 9 | Catherine, Russell to Golf Course | 2 | Steel | 1940 | 715 |
| 10 | S Main, S Main NE to S Elizabeth | 2 | Steel | 1945 | 680 |
| 11 | S Elizabeth, S Main to near E Broadway | 6 | Steel | ? | 640 |
| 12 | SW 3rd, Pierce to S Main | 4 | Steel | 1940 | 380 |
| 13 | S Elizabeth, SW 2nd to SW 5th and SW 5th, S Elizabeth to S Main | 12 | Cast Iron | 1947 | 1,700 |
| 14 | SE 7th, Mill to near George | 4 | Steel | 1940 | 570 |
| 15 | S Main, SW 5th to SW 10th | 12 | Steel | 1940 | 1,920 |
| 16 | SE 9th, S Main to Well No. 1 | 12 | Steel | 1940 | 280 |
| 17 | SW 7th, S Main to near S Columbia | 2 | Steel | 1940 | 230 |
| 18 | Alley, Locust to SW 8th | 4 | Steel | 1940 | 1,140 |
| 19 | SE 9th, S Main to S Mill | 4 | Steel | 1940 | 350 |
| 20 | Alley, SE 9th to SE 10th | 2 | Steel | 1940 | 260 |
| 21 | SW 10th, S Main to Alley | 4 | Steel | 1940 | 170 |
| 22 | SE 10th, S Main to near S Mill | 2 | Steel | 1940 | 270 |
| 23 | S Mill, SE 9th to SE 11th | 8 | Steel | 1940 | 590 |
| 24 | NW 11th, Evans to N Main | 4 | Steel | 1946 | 400 |
| 25 | N Main, 270' n to 210' s of NW 11th | 2 | Galvanized | ? | 480 |
| 26 | NW 10th, Lamb to end of NW 10th | 4 | Steel | 1953 | 620 |
| 27 | Perkins, NW 8th to NW 10th and NW 10th to Perkins to Evans | 4 | Steel | 1946 | 920 |
| 28 | Ward, NE 8th to alley at Hudson Bay and Ward to Robbins alley to 420' south | 4 | Steel | 1946 | 1,210 |
| 29 | NE 9th, Ward to dead end alley to 420' south | 2 | Steel | 1946 | 250 |
| 30 | Robbins, NE 8th to NE 7th | 4 | Steel | 1940 | 320 |
| 31 | NE 7th, N Main to Russell | 4 | Steel | 1940 | 780 |
| 32 | NW 6th, Lamb to Evans | 8 | Steel | 1945 | 860 |
| 33 | Helen, NW 6th to NW 7th | 4 | Steel | 1945 | 370 |
| 34 | NW 7th, Lamb to Vining | 4 | Steel | 1946 | 480 |
| 35 | Evans, NW 6th to NW 8th | 4 | Steel | 1946 | 660 |
| 36 | NW 6th and NE 6th, Evans to Ward | 6 | Steel | 1946 | 1,120 |
| 37 | Alley between Robbin, NE 6th to midblock south | 6 | Steel | 1946 | 180 |
| 38 | NW 5th, Lamb to Evans | 6 | Steel | 1946 | 840 |
| 39 | Evans, NW 5th to NW 4th | 6 | Steel | 1946 | 280 |
| 40 | NE 6th and Russell, East 470' then south 260' to Well No. 5 | 8 | Steel | 1940 | 730 |
| 41 | West Broadway, Casco to Depot | 4 | Steel | 1940 | 760 |
| 42 | NW 1st and Depot, Northerly to NE 4th and N Main | 6 and 8 | ? | 1940 | 900 |
| 43 | Alley between N Main, NE 5th to near NE 4th | 2 | ? | 1940 | 200 |

CHAPTER 6

RECOMMENDED SYSTEM IMPROVEMENTS

INTRODUCTION

This chapter summarizes the recommendations of the Water System Master Plan and outlines the estimated costs of the proposed water system improvements. Detailed descriptions of the proposed improvements for the water supply system, storage system, and distribution system are included in Chapters 3, 4, and 5, respectively.

SUMMARY OF PROPOSED SYSTEM IMPROVEMENTS

Relatively few improvements were identified for the City of Milton-Freewater's water system in the analysis associated with this planning effort. All of the deficiencies noted and improvements recommended to improve these deficiencies are summarized hereafter. Because of the nature of the City's needs, some of the improvements are considered to be of higher priority than others. Later in this chapter, the improvements are prioritized based on the City's most important water system needs.

It should be noted that the costs for the improvements summarized below anticipate a public bidding process. The City has successfully completed several system improvements with their own staff and may choose to do so with some of these improvements. These cost estimates may need to be adjusted if the City chooses to make the improvements themselves.

Water Supply Improvements. Water supply improvements are recommended in order to connect City Well No. 1 to the Middle Reservoir. This transmission line is intended to deliver water with entrained air from the well directly to the reservoir where the entrained air can dissipate under atmospheric conditions. Table 6-1 presents a summary of the estimated year 2009 cost for this improvement.

Water Storage Improvements. Recommended water storage improvements are related to maintenance of the City's existing reservoirs. They include cleaning, sandblasting, and painting the interior of the Middle Reservoir and the interior and exterior of the North Reservoir.

For estimating purposes, it was assumed the exterior of the North Reservoir will be over-coated with polyurethane (due to lead-based primer containment concerns), while the interior of the reservoir will have a two-component epoxy-based coating applied. The interior of the Middle Reservoir will also have the two-component epoxy-based coating applied. Interior preparation and painting costs are estimated to be \$4.25 per square foot, while exterior preparation and painting costs are estimated to be \$3.50 per square foot. With these assumptions, the estimated costs for coating maintenance on the North and Middle Reservoirs are as follows:

RESERVOIR COATING COST ESTIMATES

| | Interior Coating Cost | Exterior Coating Cost | Total Coating Cost | 35 Percent for Additional Costs (See Note Below) | Total Estimated Cost |
|-----------------------------|--------------------------|--------------------------|--------------------------|---|----------------------------|
| North Reservoir | \$111,100 | \$67,700 | \$178,800 | \$62,600 | \$241,400 |
| Middle Reservoir | \$67,600 | \$0 | \$67,600 | \$23,700 | \$91,300 |
| TOTAL ESTIMATED COST | | | | | \$332,700 |

Note: Additional costs include design and construction engineering, permitting, legal, and a 10 percent construction contingency.

Water Distribution System Improvements. Water distribution system improvements planned by the City are identified in detail in Chapter 5. The year 2009 recommended distribution system improvements are estimated to have a construction cost of \$80.00 per foot for 8-inch water line improvements (replacing all existing pipes 8 inches and smaller, as listed in Chapter 5), and \$88.00 per foot for 12-inch improvements (replacing all existing 12-inch pipes, as listed in Chapter 5). These unit costs account for a valve located every 250 feet, a connection to an existing pipeline every 250 feet, hydrants placed every 750 feet, water service replacements every 150 feet, half of the trench surface restoration costs being asphalt, and half being gravel surfacing.

Increasing these unit costs by 35 percent to account for administration, legal, engineering, permitting, and construction contingency results in unit costs of \$108 per foot for 8-inch water lines and \$119 per foot for 12-inch water lines. The total length of the 8-inch improvements listed in Chapter 5 is estimated to be 19,937 feet, while the proposed 12-inch improvements is estimated to be 7,425 feet. This results in total costs of \$2,153,196 for the 8-inch improvements and \$883,575 for the 12-inch improvements, for a total project cost of \$3,036,771. These cost estimates assume a public bidding and contracting process and take into account all costs described above. If City crews are able to perform this work, it is estimated that these costs would be reduced.

PRIORITY OF IMPROVEMENTS

The water system improvements summarized in this chapter are important to help meet the City's year 2028 water system needs. Because some needs may be of higher priority, the City may wish to complete the improvements in a phased approach. If a phased approach is selected, prioritizing the improvements becomes important to help ensure the City's most important water system needs are addressed first. Outlined in the following table is the recommended priority for the water system improvements described in this Master Plan.

PRIORITY OF WATER SYSTEM IMPROVEMENTS

| Priority | Improvement | Reason for Priority Ranking |
|----------|---|--|
| A | Connecting Well No. 1 to the Middle Reservoir | Allows all water supply sources to be used on a daily basis and reduces the burden on other City wells. |
| B | Painting of Middle and North Reservoirs | Prevents further deterioration of existing reservoir coating and the potential damage to reservoir components. |
| C | Distribution System Improvements | Replaces aging main lines, provides looping for dead-end lines, improves water quality, and provides improved fire protection. |

Increasing the City's supply capacity by bringing the existing air-entrained Well No. 1 back online for daily use should be considered the highest priority improvement to the water system. This would help reduce the additional hours that the City's wells are currently operating to meet peak daily demands. It would also allow the City to better provide enough supply to meet projected peak daily demands through the year 2028.

The next priority should be maintenance related to the City's North and Middle Reservoirs. The information obtained from the cleaning and inspection of the North and Middle Reservoirs by LiquiVision, Inc., indicates that the Middle Reservoir is in need of interior painting. The North Reservoir will likely need recoating within the planning period of this study. These projects should be undertaken by the City within the next five to ten years, if possible, to ensure that corrosion does not begin to deteriorate reservoir appurtenances to a degree that requires replacement.

Finally, the City could complete the recommended distribution system improvements to upgrade aging main lines, help eliminate dead-end lines, improve water quality, and increase fire flows in key areas of the City.

COST SUMMARY

The year 2009 estimated project costs for Priority A, B, and C water system improvements are summarized below. If improvements are completed after 2009, updating the construction costs to account for inflation and more current construction conditions will be required. The total estimated costs are briefly summarized as follows:

- Priority A Improvements (new transmission line from Well No. 1 to Middle Reservoir): \$181,000
- Priority B Improvements (North and Middle Reservoir painting): \$332,700
- Priority C Improvements (distribution system improvements): \$3,036,771

The total estimated water system improvements project costs outlined above are \$3,550,471. Again, these estimated costs assume the public bid process is utilized, the improvements require design and construction engineering services, and a 10 percent construction contingency is included. If the City is able to complete some of these improvements using City crews, the costs will likely be less.

**ESTIMATED COST
SUPPLY SYSTEM IMPROVEMENTS
(YEAR 2009 COST)**

| NO. | ITEM | UNIT | UNIT PRICE | ESTIMATED QUANTITY | TOTAL PRICE |
|--|---------------------------------------|------|------------|--------------------|-------------------|
| SUPPLY SYSTEM IMPROVEMENTS | | | | | |
| 12-inch Transmission Line Extending Southwest on 9th Avenue from City Well No. 1, across Main Street, then Northwest on S. Columbia Street, Tying into Existing Transmission Line from Well No. 2 to the Middle Reservoir | | | | | |
| 1 | Mobilization (5%) | LS | \$ 5,500 | All Req'd | \$ 5,500 |
| 2 | 12-inch Water Line | LF | 50 | 800 | 40,000 |
| 3 | Bored and Jacked Main Street Crossing | LS | 60,000 | All Req'd | 60,000 |
| 4 | 12-inch Valves | EA | 1,800 | 3 | 5,400 |
| 5 | Connect to Existing Line | EA | 1,000 | 2 | 2,000 |
| 6 | Surface Restoration - Asphalt | SY | 45 | 400 | 18,000 |
| 7 | Surface Restoration - Gravel | SY | 8 | 400 | 3,200 |
| Subtotal Construction Costs | | | | | \$ 134,100 |
| Administration, Legal, Engineering, Permitting, and Contingency at 35% | | | | | 46,900 |
| Total Year 2009 Estimated Cost | | | | | \$ 181,000 |

CHAPTER 7

PROJECT FINANCING

INTRODUCTION

This chapter evaluates the financial status of the City's Water Department and outlines alternatives for financing the water system improvements outlined in this Plan. For analysis purposes, it was assumed the City would implement the improvements outlined in Chapter 6 as a single project. These financial alternatives include state and federal grants and loans, as well as financing options for providing the local funding share. In order to construct the proposed improvements as a single project, a financing plan that is acceptable to the citizens of Milton-Freewater would need to be developed to complete the needed improvements. Financing resources available to fund the improvements could include both local funding and available outside loan funding.

Although a detailed analysis of Milton-Freewater's current water rate structure is beyond the scope of this Plan, some discussion of the existing rate structure and current and future water system budgets is included. As a general rule, most utility rate structures include funding for periodic minor system improvements and maintenance items, payroll costs for staff, and an amount to be set aside for future improvements. The majority of the discussion in this chapter will center on available state and federal grant and loan programs that will be important to Milton-Freewater in the decision-making process, and methods of developing the local share needed for the project.

CURRENT WATER USE RATES AND REVENUE

The operation and maintenance of the existing water system is financed through the City's annual budget. Revenue is obtained primarily from water user fees. Water rates (per month) that were current at the time of this study and which have been in effect since July 1, 2008, are summarized in the following table.

WATER RATE INFORMATION

| BASE CHARGE | | |
|---|------------|-------------------|
| Account Type | Connection | Base Monthly Rate |
| Residential and Commercial | All | \$ 17.22 |
| Motels, Assisted Living, Industrial, and Government | 1-1/2" | \$118.75 |
| | 2" | \$173.42 |
| | 3" | \$230.78 |
| | 4" | \$454.91 |
| | 6" | \$624.36 |
| | 8" | \$815.10 |
| | 10" | \$989.95 |

| USAGE CHARGES | | |
|----------------------|--------------------------|----------------------------|
| Account Type | Usage | Per 1,000 gal/month |
| All | 0 to 5,000 gallons | Minimum charge |
| | 5,000 to 500,000 gallons | \$ 1.25 |
| | Over 500,000 gallons | \$ 0.81 |

These water rates are the Water Department's sole source of revenue, and no taxes are assessed to support the water system.

As of August 2008, the City of Milton-Freewater had the following number of water service connections that were metered and billed:

WATER SERVICE CONNECTIONS

| Connection Type | Total Number of Connections |
|--------------------------|------------------------------------|
| Residential | 2,013 |
| Commercial | 240 |
| Industrial | 23 |
| Total Connections | 2,276 |

Some of the accounts listed above include more than one user connected to a single, or master, meter. For example, a duplex in Milton-Freewater that has one meter has been counted as one connection but is charged twice the minimum monthly fee per unit and is counted as two accounts. After review of billing information provided by the City, it was determined that the City has a total of 2,276 connections and 2,911 billable accounts.

The revenue generated annually by the City's Water Department is presented in Table 7-1. As shown in Table 7-1, the City has multiple revenue sources contributing to the Water Department fund. For the purpose of this planning study, three sources of income are anticipated to provide continued stable and reliable revenue to the Water Department fund. These revenue sources are related to water user fees (services), water service installations (water meter sales), and system development charges. These three revenue sources will be referred to as the water system sources in the following discussion.

The annual revenue generated from the water system sources over the period from 2003 through 2009, with fiscal year 2008-09 budgeted numbers, is shown in the following table, along with the City's population. Revenue from the water system sources has increased at an average annual rate of approximately 3.9 percent per year from 2003-04 through 2008-09, including the increased revenue from raising the

minimum monthly water rate in July 2006 and again in July 2008. Using an annual user fee revenue amount of approximately \$1,094,700 for 2008-09, as shown in Table 7-1, and assuming 2,911 accounts, the City currently has an average monthly water user fee of approximately \$31.32 per account. This shows that the City's coverage rates and rates for larger meter connections are substantially increasing the Water Department revenues.

REVENUE FROM WATER SYSTEM SOURCES

| Fiscal Year | Population | Revenue from Water System Sources |
|-------------|------------|-----------------------------------|
| 2003-04 | 6,500 | \$919,268 |
| 2004-05 | 6,540 | \$945,447 |
| 2005-06 | 6,585 | \$976,176 |
| 2006-07 | 6,550 | \$1,045,292 |
| 2007-08 | 6,550 | \$1,092,455 |
| 2008-09* | 6,550 | \$1,228,100 |

*2008-09 are budgeted numbers.

CURRENT FINANCIAL STATUS

Existing Debt. The City of Milton-Freewater currently has two outstanding general obligation bonds on the water system. These bonds are summarized in the following table:

OUTSTANDING GENERAL OBLIGATION BONDS

| Original Amount | Year Issued | Year Debt Expires |
|-----------------|-------------|-------------------|
| \$465,000 | 1994 | 2013 |
| \$1,815,000 | 1997 | 2018 |

The annual principal and interest payments remaining for both loans are approximately \$183,840 per year through 2013, then approximately \$145,697 per year until the year 2018.

Annual Water System Costs. The annual cost of operating, maintaining, and making improvements to Milton-Freewater's water system is summarized in Table 7-2 for fiscal year 2003-04 through the current budget year, 2008-09. The costs presented include all costs for the water system. The City's annual expenditures have been increasing over the last five years at an annual rate of approximately 5.3 percent.

In order to simplify the complex array of revenue sources and expenditures, the annual revenue from water system sources (services, water meter sales, system development charges, merchandising, and interest income) has been compared with annual total operation and maintenance (O&M) costs, debt service costs, and inter-fund transfers. The table below presents this information.

ANNUAL WATER SYSTEM REVENUE VS. EXPENDITURES

| Fiscal Year | Revenue from Water System Sources ¹ | O&M, Debt, and Transfer Expenditures | Balance |
|----------------------|--|--------------------------------------|------------|
| 2003-04 | \$919,268 | \$922,727 | (\$3,459) |
| 2004-05 | \$945,447 | \$969,421 | (\$23,974) |
| 2005-06 | \$976,176 | \$957,799 | \$18,377 |
| 2006-07 | \$1,045,292 | \$1,071,916 | \$26,624 |
| 2007-08 | \$1,092,455 | \$1,073,769 | \$18,686 |
| 2008-09 ² | \$1,228,100 | \$1,196,335 | \$31,765 |

¹ Includes revenue from water user fees (services), water service installations (water meter sales), and system development charges.

² 2008-09 data are derived from the City's budget.

The positive balances since 2005-06 show that operation of the City's water system has been adequately funded over this period. The surplus of revenues from water system sources over O&M, debt service, and transfer expenditures has averaged approximately \$23,863 annually over the last four years. The historical trends for these revenues and expenditures are shown in Figure 7-1, along with a projection of future expenditures. By plotting a "trend" line for the expenditures, the anticipated expenditures in a future year can be determined, assuming no changes in the water system occur. This trend line shows that O&M, debt, and inter-fund transfer expenditures are anticipated to increase to approximately \$1,200,000 in fiscal year 2009-10.

WATER SYSTEM IMPROVEMENTS FUNDING

In order to accomplish the water system improvements discussed in Chapter 6, the City may consider outside funding assistance. A number of state and federal grant and loan programs can provide assistance on municipal improvement projects to cities, counties, and utility districts. These programs offer various levels of funding aimed at different types of projects. These include programs administered by the Oregon Economic and Community Development Department (OECDD), Rural Development (RD) under the U.S. Department of Agriculture, the U.S. Economic Development Administration (EDA), and others. These agencies can provide low-interest loan funding and possibly grant funding for assisting rural communities on public works

projects. Most of these agencies require increases in existing water rates to support loans for system improvements both as a condition of receiving monies and prior to being considered for grant funds. Some of the funding programs provide funding only if the improvements address documented water quality compliance issues.

As many of the proposed system improvements will most likely be constructed in the future, it is likely changes will occur in funding availability and selection criteria. The following is provided to show the current state of the programs and the nuances of funding available now. Funding alternatives should be reevaluated in the early phases of a project that is ready to be initiated.

SUMMARY OF STATE AND FEDERAL GRANT AND LOAN PROGRAMS

The following section briefly summarizes the primary funding programs available to assist the City with a water system improvements project. The programs are generally presented in order of most likely applicability to the City. Some funding programs require a water quality problem for funding eligibility. As the City's projects are generally not based on a water quality issue, funding from these sources is not likely unless the City's situation changes or a water quality issue arises. However, the information is presented herein for completeness and for the possibility of future applicability to the City's needs.

- (1) In conjunction with the Oregon Drinking Water Program (DWP), the OECDD administers the ***Safe Drinking Water Revolving Loan Fund (SDWRLF)***. This program receives a federal funding allocation each year. Although Letters of Interest can be completed at any time, they should be submitted during the annual Letter of Interest process, which typically occurs in the spring of each year. This program provides loans with interest rates around 4.5 percent for a 20-year term, but as low as 1 percent for a 30-year term for communities meeting hardship criteria. Projects are ranked by the following criteria: projects addressing serious human health risks, projects to assure compliance with the Safe Drinking Water Act, and water systems in need based on affordability criteria.

Revisions to the SDWRLF have been implemented for the purpose of making loan funds more affordable to lower income communities. OECDD has developed a "Disadvantaged Community" status in the SDWRLF program where communities that qualify can be eligible for a "hardship criteria" loan interest rate of 1 percent for a 30-year term and for "principal forgiveness" (essentially a grant) up to \$250,000 or 25 percent of the total loan amount, whichever is less. To evaluate eligibility for Disadvantaged Community status, the following criteria must be met:

- a) Funding from any source being evaluated for the improvements project must result in a community's monthly residential water cost for 7,500 gallons of water exceeding 1.48 percent of the 2000 median household income (MHI). Based on the 2000 Census, the MHI in Milton-Freewater is \$28,365. A monthly residential water fee corresponding to 1.48 percent of

this MHI would be approximately \$34.98 per month. The monthly residential water cost must include all OM&R costs, existing debt cost, and the anticipated additional monthly cost for the new debt. If the monthly costs charged to residential customers to meet all these obligations exceed 1.48 percent of the 2000 MHI, then the community meets the Disadvantaged Community status and is eligible for hardship criteria funding, pending further evaluation, as summarized hereafter.

- b) The total loan amount of the project is then reevaluated at the hardship criteria interest rate of 1 percent for a 30-year term. The total loan amount may also be reduced by the principal forgiveness amount, which may not exceed the lesser of \$250,000 or 25 percent of the total SDWRLF award for the project. If the resulting monthly water cost charged to residential customers to cover the existing OM&R, existing debt service, and new loan at the 1 percent rate is still equal to or greater than 1.48 percent of the 2000 MHI, then the community qualifies for the hardship criteria rate and principal forgiveness. If the resulting average monthly water cost required to meet all obligations is less than 1.48 percent of the MHI, then the community does not qualify for the principal forgiveness.

A preliminary analysis of the City of Milton-Freewater's existing water rates, debt service, and OM&R costs indicates that the City may be able to qualify for the Disadvantaged Community status or the hardship criteria loan with principal forgiveness if all improvements outlined in Chapter 6 were pursued at one time. The SDWRLF program is a good source of loan funds for potential water system improvements.

- (2) Another potential funding source is the **U.S. Department of Agriculture, Rural Development (RD)** program (formerly known as Farmers Home Administration). This agency can provide financial assistance to communities through both loans and direct grants. Under the loan program, the agency purchases local bonds. The interest rate for these bonds is dependent on the MHI of the community and other factors, and varies from year to year based on other national economic factors. Application for this type of funding is a fairly lengthy process involving a detailed application, environmental review, etc.

The grant fund eligibility under the agency's current rules is dependent upon the City's MHI in comparison with the 2000 Oregon non-metropolitan MHI. Currently, RD is using a non-metropolitan MHI of \$41,230 as the basis for grant fund eligibility. The City's current (2000 Census) MHI is \$28,365. When comparing the City's MHI with the non-metropolitan MHI, Milton-Freewater would likely qualify for grant funding through RD. However, RD's grant funds are limited and generally very competitive to obtain. The interest rate for RD loans typically varies between 4.0 and 4.5 percent with a repayment period of 40 years if grant funds are provided. The repayment period can be reduced if only loan funds are provided.

The equivalent monthly water rate must provide sufficient revenue to pay for all system operation and maintenance costs, any existing debt service, and the local debt service incurred as a result of the project. Project costs above this level may be paid for by grant funds, which is typically a maximum of \$1,000,000. A general rule is that RD requires 20 percent of the project to be funded through other sources. The objective of the RD loan/grant program is to keep the cost for utilities in small rural communities at a level meeting RD's definition of affordable and similar to what other communities are paying. Currently RD requires a monthly water rate of approximately \$46.00 to 48.00 per month to be eligible to receive grant funds.

Another of the agency's requirements is that loan recipients establish a reserve fund of 10 percent of the bond repayment. If a city does not have these reserves available, they can be established during the first 10 years of the project, effectively making the net interest rate a little higher. The RD program also requires cities to establish either revenue or general obligation bonds to guarantee the loan. The RD program also allows project costs previously incurred by the city, interest paid on interim financing during construction and, in some cases, existing debt to be financed as part of the project.

RD should be considered a potential source of funding for the City's water system improvements. However, RD would likely serve only as a loan source to fund the project since high rates are required to be eligible for grant funds.

- (3) The State of Oregon has developed the **Oregon Bond Bank** as a loan source available to cities for improvement projects. The OECDD also uses the Bond Bank as the source of loan funds for the Water/Wastewater and Special Public Works Fund programs (described below). Periodically, the State of Oregon sells bonds, using the state's credit rating, to maintain a pool of money that the State can, in turn, loan out to cities, counties, and special districts. The state pays the bonding costs and buys down the interest rate a small amount. Interest rates for loans from the Bond Bank are typically around 5 to 6 percent. Local government agencies can finance a loan obtained from the Oregon Bond Bank based on either a local general obligation bond election or a local revenue bond authorization; either way the interest rate is the same. Applications for loans through the Oregon Bond Bank are accepted at any time by the state. This loan source is attractive to small communities because of the slightly lower interest rate and because the local government is not faced with expensive bonding costs. This program is not as appealing as financing through other programs with potential grants or low-interest loans.
- (4) The OECDD also administers the **Water/Wastewater** financing program. This program uses Oregon Lottery funds to help municipalities make improvements to their drinking water and wastewater systems. Project eligibility is generally limited to those projects necessary to ensure compliance with drinking water quality standards administered by the DWP or water quality statutes, rules, orders, or permits administered by the Department of Environmental Quality (DEQ). A project may also be eligible for funding from this program to assist in

bringing the system into compliance with requirements proposed to take effect within the next two years or if the DWP indicates there is a high probability that the system owner will soon be notified of non-compliance.

Funding from this program can be in the form of loans and/or grants. Determination of the final amount of financing available for a specific project, and the loan/grant mix, is based on several factors including the financial strength of the municipality, per capita income of the applicant, existing water and sewer rates as compared to a statewide average, and more.

For reduced rate loans and grants, this program requires that the recipient has a monthly residential rate for 7,500 gallons of water of at least 1.48 percent of the 2000 statewide MHI. As discussed earlier, a monthly residential water fee corresponding to 1.48 percent of this MHI would be approximately \$34.98 per month for Milton-Freewater. The City's current monthly residential water fee for 7,500 gallons is \$20.35. This is approximately \$14.50 under where it would need to be to establish rates at 1.48 percent of the MHI. A water rate increase would be necessary to meet the threshold rate requirement. Therefore, the City does not currently qualify for low-interest loans and/or grant funds. It is possible this criteria could be met in the future due to rate increases that may be necessary to cover rising OM&R costs and/or repay additional loans the City may incur to finance water system improvements.

If the City were to become eligible for grants under the above criteria, a maximum \$750,000 grant may be available for communities with an MHI less than the statewide MHI. Since Milton-Freewater's 2000 MHI (\$28,365) is less than the statewide MHI (\$41,662), the maximum amount of grant funds the City could potentially qualify for is \$750,000. However, if the City is eligible for a grant through this program, the grant award is usually split at least 50/50 with the loan amount. Often, the loan amount is higher due to the requirement to reach the target water rate, so the loan typically exceeds 50 percent of the project cost. Typically, these loans are tied to the Oregon Bond Bank, as previously discussed.

Funding from this program would require a proposed project that is associated with a documented compliance issue, which is not the case at this time.

- (5) The OECDD is also responsible for administering the ***Oregon Community Development Block Grant (OCDBG)*** program. Funding for this program is provided on an annual basis by the U.S. Department of Housing and Urban Development.

Projects that qualify under the Public Works category of the OCDBG program include municipal sewer and water system improvement projects that are user-rate dependent. The community must be primarily residential in nature and the proposed project must primarily benefit city residents. The funds available from this program are limited to \$1,000,000 per community per project or \$20,000 per permanent residential connection benefited by the project, whichever is less.

Those projects necessary to ensure compliance with drinking water quality standards administered by the DWP or water quality statutes, rules, orders, or permits administered by the DEQ are given highest priority under this program. The OECDD considers factors such as the ability of the users to fund the project locally, the urgency of the area's need, the cost in grant dollars per person benefited by the project, and how well the project is targeted toward meeting the national objective of primarily benefiting persons of low to moderate income.

The OECDD, through its OCDBG program, gives water improvement projects that address documented health problems highest priority for funding. The agency does not fund projects that are targeted toward water quantity problems or growth related problems. The OCDBG program also requires the community to have 51 percent or greater low to moderate income residents. The City of Milton-Freewater's percentage of low to moderate income residents is approximately 53.2 percent based on the 2000 Census, which meets this aspect of the program's criteria.

As with the Water/Wastewater financing program, to qualify for this funding source the average residential water rates must be at least 1.48 percent of the 2000 MHI. As previously discussed, the current rate would need to be increased \$14.50 to approximately \$34.98 per month to qualify for grant funds.

- (6) The OECDD is the administrator of the **Special Public Works Fund** program, which is funded by monies from the Oregon Lottery. Funds from this program can be made available for either the purpose of improving public facilities or enabling the community to be in a position to serve additional commercial and industrial businesses. Loan funds are normally available through this program to be utilized by cities and counties for public utility improvements. The interest rate for loans through this program is generally tied to the Oregon Bond Bank, as discussed earlier. The program also offers grant funds once specific loan capacity limits are met, and when economic growth and the creation of new jobs or retention of jobs can be tied to the project. Unless a project can be tied directly to the creation of new family wage jobs or the retention of existing jobs, a project will not be in a competitive position to receive loan and/or grant funds under this program with the limited funds that are available.

If Milton-Freewater desires to move forward with a project involving funding alternatives as presented above, it is important for the City to consult with funding agencies early to ascertain which programs the City would be eligible to receive funding from for the proposed improvements. This consultation with funding agencies is usually done through a "One-Stop Meeting" where representatives of major funding agencies meet with the City to discuss the project and funding needs and identify the funding program best suited for the project. These meetings are typically held in Salem, Oregon. Once the meeting is concluded, the City is then invited to submit a Project Intake Form. OECDD utilizes a Project Intake Form to outline a city's project, including the needs, project requirements, affected area, estimated project cost, timeframe, schedule, etc. OECDD evaluates the project based on information collected for the Intake Form to determine the best funding program suited to the project. OECDD then

invites the City to submit a funding application to the particular funding program identified to best fit the City's needs. The One-Stop Meeting and Project Intake Form process can be completed at any time.

The remainder of this chapter focuses on evaluating funding options for the City's water system improvements, assuming improvements are funded entirely by a loan, which represents the most likely scenario for the City of Milton-Freewater.

PRELIMINARY EQUIVALENT DWELLING UNIT ANALYSIS

When projecting future revenue for a water system, an Equivalent Dwelling Unit (EDU) analysis is usually completed. One EDU is intended to represent the average residential water use for a given city. As an example, each residential connection in Milton-Freewater would represent one EDU. A commercial connection user with water use amounts similar to the average residential use amount would also be considered one EDU. A commercial connection such as a cafe, with three times the typical water usage as an average residential connection, would be considered three EDUs.

An analysis of the City's water service accounts was completed in 1999 to provide a preliminary EDU determination. For that analysis, the City provided total annual water use records for the period from August 1998 through August 1999 for all accounts. The total annual water use of all residential accounts for that period was determined to be 411,389,000 gallons. This total use, divided by 2,648 billable residential accounts, results in an average monthly residential water use volume of 12,946 gallons (155,358 gallons/year). This average residential water use volume was then divided into the total water use for commercial, public, and industrial accounts to estimate the EDUs for each category. The preliminary results are summarized in the following table.

PRELIMINARY EDU ANALYSIS

| Connection Type | Total Number of Connections | Total Number of Billable Accounts | Estimated EDUs |
|-----------------|-----------------------------|-----------------------------------|----------------|
| Residential | 2,013 | 2,648 | 2,648 |
| Commercial | 240 | 240 | 988 |
| Industrial | 23 | 23 | 946 |
| Total | 2,276 | 2,911 | 4,582 |

Some funding agencies will use this type of EDU evaluation as a basis for estimating future yearly revenues and debt capabilities for a city. The EDU determination, which is based on water consumption, is intended to equitably distribute water costs among all users. The EDU determination helps funding agencies determine the maximum loan (debt) amount a city must meet prior to being considered for grant funds. For Milton-Freewater, the analysis presented later in this chapter shows that the City can complete a water system improvements project by obtaining only a loan or

funding the improvements themselves. Many funding sources that provide only loans do not always require an EDU determination. Some of these agencies may only require a city's water rate structure to be equitable and to demonstrate that sufficient revenue can be generated to pay the required annual debt payment. Since this type of funding would most likely be obtained by the City of Milton-Freewater, the analysis presented hereafter for the City's future water rate revenue and estimated debt capacity is based on the current estimate of 2,911 billable accounts, not the preliminary EDU determination of 4,582. This will result in a more conservative estimate of the City's debt capacity.

DEBT CAPACITY

In order to determine the City's ability to fund a water system improvements project, Table 7-3 was prepared. Several assumptions were made as follows:

1. Water usage revenue is based on the number of water service accounts, which is estimated to be 2,911.
2. Operations, maintenance, and replacement (OM&R) costs for the budget year 2009-10 were set at \$572,000 per year. The budget year 2009-10 was used as this would be the earliest time period in which a project could be initiated.
3. Existing bond payments were set at \$183,000 per year.
4. Inter-fund transfers were set at \$445,000 per year based on the three most recent years (2005-06 through 2007-08).
5. Debt service was calculated at 5.0 percent interest for a 20-year repayment period.

The data shown on Table 7-3 provides a general idea of the amount of debt the City could afford to service. Based on this information, it does not appear that the City could afford to service any debt with their current average monthly water cost of approximately \$30 per account. This indicates the City may need to increase the base rate or the overage fees in order to increase revenue should the City seek a loan for water system improvements projects in the future. The various funding programs previously described in this chapter have differing thresholds established for grant assistance. In Milton-Freewater's case, average user rates would need to be approximately \$35 to \$45 or more per month in order to qualify for many of these grant assistance packages.

As stated above, it is important to note that the estimated bond debts shown in Table 7-3 and the average water use costs are based on 2,911 billable water service accounts, not the preliminary estimate of 4,582 EDUs. If the same evaluation were made assuming 4,582 EDUs, the evaluation would show that the City could afford to service a higher debt for the same monthly base water rate cost. It should be recognized that this is only a very preliminary analysis, and the assumptions and figures

should be refined if project implementation proceeds in the future and when agreements are worked out with funding agencies.

PROJECT FUNDING

Based on the estimated debt capacity of the City's Water Department, and the estimated cost of the water system improvements discussed in Chapter 6, it may be possible to obtain grant funds for the project if the City were to pursue all improvements outlined in Chapter 6 at one time. Of the various loan funding programs, the most likely sources of funding would be a loan from Rural Development or a loan from the Safe Drinking Water Revolving Loan Fund. Funding sources for a loan, other than the state and federal funding agencies outlined herein, may be available to the City at competitive rates. If an improvements project is pursued, it is recommended that the City thoroughly investigate other loan sources to ensure the most competitive rates and terms are obtained for the project.

One-Stop Meeting and Project Intake Form. If funding is desired for water system improvements, the City of Milton-Freewater will need to schedule a One-Stop Meeting and submit a Project Intake Form as described earlier in this chapter. As stated above, OECDD evaluates a project based on information presented at the One-Stop Meeting and on the Intake Form to determine the best funding program suited to the project. OECDD then invites a City to submit a funding application to the particular funding program identified by OECDD.

LOCAL FINANCING OPTIONS

Regardless of the ultimate project scope and agency from which funding is obtained, the City may need to develop authorization to incur debt (i.e., bonding) for the needed project improvements. The need to develop authorization to incur debt depends on funding agency requirements and provisions in the City Charter. Bonding by the City is not required by most state funding programs. However, if a bond election is required, there are generally two options the City may use for its bonding authority: general obligation bonds and revenue bonds. General obligation bonds require a vote of the people to give the City the authority to repay the debt service through tax assessments, water revenues, or a combination of both. The taxing authority of the City provides the guarantee for the debt. Revenue bonds are financed through revenues of the water system. Authority to issue revenue bonds can come in two forms. One would be through a local bond election similar to that needed to sell a general obligation bond, and the second would be through Council action authorizing the sale of revenue bonds, if the City charter allows. If citizens do not object to the bonding authority resolution during a 60-day remonstrance period, the City would have authority to sell these revenue bonds.

PROJECT IMPLEMENTATION

The following action items and implementation steps need to be made by the City of Milton-Freewater if they desire to implement a water system improvements project.

The steps outlined are general in nature and include the major steps that need to be undertaken.

Action Items

1. The City will need to formally adopt this Water System Master Plan.
2. The City needs to select the scope of a water system improvements project.
3. If funding assistance is needed to fund the improvements, the City needs to schedule and attend a One-Stop Meeting with OECDD, complete the Project Intake Form, and submit the form to OECDD to initiate funding discussions.
4. The City will need to hold public information meetings to inform its citizens of the needs and scope of the project, to answer questions, and to generate support for a local bond issue, if required.
5. The City will need to acquire any required easements and property for the new water facilities, depending on the location of these improvements.
6. The City will need to prepare funding applications for the water system improvements project, if outside funding is pursued, and submit them to the appropriate funding agencies.

PROPOSED PROJECT IMPLEMENTATION PLAN

Should the City wish to proceed with a water system improvements project, the following Implementation Plan outlines the key steps the City would need to undertake to proceed with project implementation. It is important to note that it typically takes nearly two years or more from the date the City decides to proceed with an improvements project until it is completed and serving the community.

| <u>ITEM</u> | <u>COMPLETION DATE</u> |
|---|-------------------------------|
| 1. Schedule and attend a One-Stop Meeting with OECDD. | Spring 2009 |
| 2. Complete and submit the Project Intake Form to OECDD. | Spring 2009 |
| 3. Initiate funding discussions with funding agencies. | Spring 2009 |
| 4. Submit funding applications to appropriate funding agencies. | Spring - Summer 2009 |
| 5. Obtain local bonding authority, if required. | Fall 2009 |
| 6. Finalize project funding. | Fall 2009 |

ITEM

COMPLETION DATE

- | | |
|-----------------------------------|----------------------|
| 7. Design system improvements. | Winter 2009-10 |
| 8. Construct system improvements. | Spring - Summer 2010 |

The key to implementing part or all of the water system improvements outlined in Chapter 6, as a single project, is the ability of the City to fund the project themselves or acquire low-interest loan funding. The City will have to work closely with its citizens to inform them of the system needs and the necessity for increased water user costs. Depending on the scope of improvements, the City may need to plan on average user costs being in the range of approximately \$35 to \$40 per month to obtain the loan funds required to complete the improvements. Rates at these levels may result in the City becoming eligible for grant funds or special interest rates.

The City of Milton-Freewater has an excellent water system that operates efficiently. The City's existing multiple reservoirs and wells provide considerable redundancy in the water system. Water system improvements as outlined in this Water System Master Plan will help to improve the reliability and quality of the water system, which would help to continue to meet the needs of the City for many years to come.

Water Department Revenues

| Fiscal Year | Services (User Fees) | Water Meter Sales (Installations) | System Development Charges | Merchandising Revenues | Interest Income | Miscellaneous Income | Total Revenues |
|-------------|----------------------|-----------------------------------|----------------------------|------------------------|-----------------|----------------------|----------------|
| 2003-04 | \$902,065 | \$3,911 | \$10,440 | \$382 | \$2,086 | \$384 | \$919,268 |
| 2004-05 | \$920,411 | \$3,440 | \$7,175 | \$10,707 | \$3,714 | \$0 | \$945,447 |
| 2005-06 | \$960,996 | \$0 | \$6,280 | \$3,468 | \$5,335 | \$97 | \$976,176 |
| 2006-07 | \$1,033,422 | \$0 | \$6,565 | \$0 | \$5,305 | \$0 | \$1,045,292 |
| 2007-08 | \$961,705 | \$0 | \$125,908 | \$0 | \$4,847 | \$0 | \$1,092,455 |
| 2008-09* | \$1,094,700 | \$5,000 | \$121,000 | \$1,400 | \$0 | \$6,000 | \$1,228,100 |

Notes: *2008-09 revenue is projected per the City's adopted budget.



CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WATER DEPARTMENT REVENUES

TABLE
7-1

Water Department Expenditures

Actual Data From the City's Audit Reports

| Fiscal Year | Personnel Cost | Operating Cost | Capital Outlay | Total O,M,&R Cost | Existing Debt Service | Total O,M,&R and Existing Debt Cost | Inter-Fund Transfers Out (Net) | Total Cost |
|-------------|----------------|----------------|----------------|-------------------|-----------------------|-------------------------------------|--------------------------------|-------------|
| 2003-04 | \$110,676 | \$224,410 | \$32,193 | \$367,279 | \$183,706 | \$550,985 | \$371,742 | \$922,727 |
| 2004-05 | \$134,014 | \$224,707 | \$33,812 | \$392,533 | \$154,661 | \$547,194 | \$422,227 | \$969,421 |
| 2005-06 | \$174,313 | \$225,419 | \$4,809 | \$404,541 | \$184,731 | \$589,272 | \$368,527 | \$957,799 |
| 2006-07 | \$183,319 | \$231,732 | \$47,133 | \$462,184 | \$175,682 | \$637,866 | \$434,050 | \$1,071,916 |
| 2007-08 | \$201,391 | \$229,919 | \$12,812 | \$444,122 | \$181,787 | \$625,909 | \$447,860 | \$1,073,769 |
| 2008-09* | \$231,952 | \$250,219 | \$87,860 | \$570,031 | \$182,155 | \$752,186 | \$444,149 | \$1,196,335 |

Notes: *2008-09 data derived from the City's budget.



CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
WATER DEPARTMENT
EXPENDITURES

TABLE
7-2

Preliminary
Water Rate Analysis For Bonding Capacity
2009-10 Budget Year

| Rates | Expenditures | | | | | Bonding Capacity ⁵ | |
|-------|-----------------------------------|----------------------|-------------------------------------|------------------------|----------------------------------|-------------------------------|------------------------------------|
| | Average Monthly Cost ¹ | Revenue ² | Estimated O,M,&R Costs ³ | Existing Bond Payments | Interfund Transfers ⁴ | | Revenue Available for Debt Service |
| \$30 | \$1,047,960 | \$183,000 | \$183,000 | \$445,000 | \$0 | \$1,200,000 | \$0 |
| \$32 | \$1,117,824 | \$183,000 | \$183,000 | \$445,000 | \$0 | \$1,200,000 | \$0 |
| \$34 | \$1,187,688 | \$183,000 | \$183,000 | \$445,000 | \$0 | \$1,200,000 | \$0 |
| \$36 | \$1,257,552 | \$183,000 | \$183,000 | \$445,000 | \$57,552 | \$1,200,000 | \$717,606 |
| \$38 | \$1,327,416 | \$183,000 | \$183,000 | \$445,000 | \$127,416 | \$1,200,000 | \$1,588,728 |
| \$40 | \$1,397,280 | \$183,000 | \$183,000 | \$445,000 | \$197,280 | \$1,200,000 | \$2,459,850 |
| \$42 | \$1,467,144 | \$183,000 | \$183,000 | \$445,000 | \$267,144 | \$1,200,000 | \$3,330,973 |
| \$44 | \$1,537,008 | \$183,000 | \$183,000 | \$445,000 | \$337,008 | \$1,200,000 | \$4,202,095 |

¹ The current base rate of \$17.22 for 5,000 gallons is attributable for approximately 57 percent of the City's revenue. Additional water use and commercial and industrial rates cause the average monthly cost to increase to approximately \$30.00 per month.

² Assumes 2,911 water system accounts.


³ Projected budget year 2009-10 O,M,&R cost including personnel, operating, and capital outlay expenditures.

⁴ Interfund transfers are the average amount from 2006-07 through 2008-09 budget.

⁵ Assumed loan funding at 5 percent for 20 years. Values are rounded to the nearest \$1,000.



Historical and Projected City Water Budget



Notes:
2008-09 data are derived from
the City's Budget.



CITY OF
MILTON-FREEWATER, OREGON
WATER SYSTEM MASTER PLAN
HISTORICAL AND PROJECTED
CITY WATER BUDGET

FIGURE
7-1

TABLE OF CONTENTS

APPENDICES

| | |
|---|--|
| A | Drinking Water Program Water Quality Testing Summary |
| B | Drinking Water Program Sanitary Survey Information |
| C | ISO Fire Protection Report |
| D | City Well Log and Pump Data |
| E | Water Right Data |
| F | Area Well Logs |
| G | Walla Walla River Water Quality Data |
| H | Reservoir Inspection Information |
| I | Umatilla Basin Program - OAR 690-507 |

APPENDIX A

Drinking Water Program Water Quality Testing Summary

Oregon Department of Human Services

Drinking Water Program

Water System #: OR4100522
 MILTON-FREEWATER, CITY OF

Certification Level Required

Distribution: 2
 Treatment: None
 Filtration: None

Licensed Operators and their certification levels

| Cert Number | Name | Distribution Level | Is DRC* Distribution | Treatment Level | Is DRC* Treatment | Filtration Endorsement | License Expires |
|---------------|------------------------|--------------------|----------------------|-----------------|-------------------|------------------------|-----------------------|
| D-1790 | Scott D. Amon | 1 | | | | | 12/31/2008 |
| D-1827 | Steve P. Birdwell, Sr. | 2 | | | | | 12/31/2008 |
| T-1845 D-1845 | David L. Bradshaw | 2 | DRC Dist | 2 | | | 12/31/2008 12/31/2008 |
| D-6509 | Murdeth S. Brannan | | | | | | 12/31/2006 |
| D-6511 | Robin W. Burrowes | | | | | | 12/31/2006 |
| D-6558 | David G. Robertson | 1 | | | | | 12/31/2009 |
| D-6559 | Emilio A. Sandoval | 1 | | | | | 12/31/2009 |
| D-6275 | Ken A. Weis | 2 | | | | | 12/31/2009 |
| D-6560 | Richard L. Worden | 1 | | | | | 12/31/2009 |

*Direct Responsible Charge

**Contract Operator

***Only Operators with a current certification will appear.

Distribution Grade 2

| EPA Rule | Requirements |
|---|--|
| 333-061-0235 OPERATOR REQUIREMENTS LEVELS 1-4 | HS/GED and 3 years experience, OR HS/GED and 1 year relevant post-high school education and 2 years experience |

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format
[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water Program

OR41 00522

MILTON-FREEWATER, CITY OF

Classification: COMMUNITY

Contact: DAVE BRADSHAW
PO BOX 6
MILTON-FREEWATER, OR
97862

Phone: 541-938-8272**County:** UMATILLA**Activity Status:** ACTIVE -- History**Population:** 6,500**Number of Connections:** 2,400**Operating Period:** January 1 to
December 31**Regulating Agency:** REGION 1**Certified Operator(s)****Owner Type:** LOCAL GOVERNMENT

Required: Y

Licensed By: N/A

Distribution class: 2

**Approved Drinking Water Protection
Plan:** No

Treatment class: None

Source Water Assessment: YesFiltration Endorsement
Required: No**Last System Survey Date:** Apr 20, 2004**Sources**

| <u>ID</u> | <u>Facility Name</u> | <u>Well Logs</u> | <u>Activity Status</u> | <u>Availability</u> | <u>Source Type</u> | <u>Sampling Point?</u> |
|-----------|-------------------------------------|------------------|------------------------|---------------------|--------------------|------------------------|
| EP-A | EP FOR WELLFIELD (WELLS #1 & #2) | | A | | GW | Yes |
| SRC-AA | WELL #1 | | A | permanent | GW | Yes |
| SRC-AB | WELL #2 | | A | permanent | GW | Yes |
| EP-B | EP FOR WELLFIELD (WELLS #3,#5 & #6) | | A | | GW | Yes |
| SRC-BA | WELL #3 | | A | permanent | GW | Yes |
| SRC-BB | WELL #5 | | A | permanent | GW | Yes |
| SRC-BC | WELL #6 | | A | permanent | GW | Yes |
| EP-C | EP FOR WELL #8 | | A | | GW | Yes |
| SRC-CA | WELL #8 - COUSE CREEK ROAD | | A | permanent | GW | Yes |
| EP-D | EP FOR WELL #9 | | A | | GW | Yes |
| SRC-DA | WELL #9 | | A | permanent | GW | Yes |

Treatment

| <u>State ID</u> | <u>Facility Name</u> | <u>Treatment Process</u> | <u>Treatment Objective</u> |
|-----------------|-------------------------------------|--------------------------------|----------------------------|
| WTP-A | TP FOR WELLFIELD (WELLS #1 & #2) | RESID. MAINT. HYPOCHLORINATION | OTHER |
| WTP-B | TP FOR WELLFIELD (WELLS #3,#5 & #6) | RESID. MAINT. HYPOCHLORINATION | OTHER |
| WTP-C | TP FOR WELL #8 | RESID. MAINT. HYPOCHLORINATION | OTHER |
| WTP-D | TP FOR WELL#9 | RESID. MAINT. HYPOCHLORINATION | OTHER |

Consumer Confidence Reports

| <u>For Year</u> | <u>Date Received</u> | <u>Date Certified</u> |
|-----------------|----------------------|-----------------------|
| 2007 | Mar 24, 2008 | Mar 24, 2008 |
| 2006 | Apr 02, 2007 | Apr 02, 2007 |
| 2005 | Apr 10, 2006 | Apr 03, 2006 |

2004

Jul 29, 2005

Jul 26, 2005

Cross Connection Annual Summary Reports

| <u>Ordinance Received</u> | <u>Ordinance Status</u> | <u>ASR Received</u> |
|---------------------------|-------------------------|----------------------|
| Yes | Final | 2007 2006 2005 |

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format

[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water Program

PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

Group Abbreviations: (ARS = Arsenic, DBP = Disinfection By Products, IOC = Inorganic Chemical, LCR = Lead/Copper, NO3 = Nitrate, OC = Organic Chemical, SOC = Synthetic Organic Chemical, RAD = Radionuclides, TCR = Coliform, VOC = Volatile Organic Chemical, RL = SWTR)

Note: Violations are displayed for the last 5 years only.

| Violation History | | | | | | | | | |
|-------------------|-------------------|--------------|-------------|-------|---|------------------------|------------------------|--------------|------|
| ID | Monitoring Period | | Facility ID | Group | Violation: Type - Count | Action | Enforcement | Hide | Date |
| | Begin | End | | | | | | | |
| 32214 | Apr 01, 2008 | Apr 30, 2008 | | TCR | Routine Coliform: did not Report Enough - 1 | | | | |
| 32162 | Jul 01, 2007 | Jul 31, 2007 | | TCR | Routine Coliform: did not Report Enough - 1 | | | | |
| 32161 | Jan 01, 2005 | Dec 31, 2005 | EP-B | NO3 | Chemical Late/Nonreporting - 1 | ST COMPLIANCE ACHIEVED | | Nov 30, 2006 | |
| 32184 | Jan 01, 2005 | Dec 31, 2007 | | ARS | Chemical Late/Nonreporting - 1 | | | | |
| 32213 | Jan 01, 2005 | Dec 31, 2007 | EP-B | SOC | Chemical Late/Nonreporting - 29 | Show analytes | | | |
| 32237 | Jan 01, 2005 | Dec 31, 2007 | EP-B | VOC | Chemical Late/Nonreporting - 21 | Show analytes | | | |
| 32157 | Jan 01, 2004 | Dec 31, 2004 | EP-C | NO3 | Chemical Late/Nonreporting - 1 | RETURNED TO COMPLIANCE | | Jul 26, 2006 | |
| 32157 | Jan 01, 2004 | Dec 31, 2004 | EP-C | NO3 | Chemical Late/Nonreporting - 1 | ST COMPLIANCE ACHIEVED | | Nov 30, 2006 | |
| 32156 | Jan 01, 2002 | Dec 31, 2004 | EP-A | SOC | Chemical Late/Nonreporting - 29 | Show analytes | RETURNED TO COMPLIANCE | Jul 26, 2006 | |

For all compliance errors please phone Chuck Michael, DWP Compliance Specialist, at 971-673-0405

For further information on this public water system click on the area of interest below.

System Info :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format
[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water Program

[Click here for Coliform fact sheet :: Spreadsheet :: MRDL Summary](#)

PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

Recent Coliform Test Results (SDWIS database)

| Sample Date | # Samples | Type | Coliform Type | Results ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|------|---------------|-------------------|---------------------|-------------|-------------|--------------|
| Dec 02, 2008 | 1 | RT | Total | Absent--081203K2 | | N/A | 0.07 | Dec 10, 2008 |
| Dec 02, 2008 | 1 | RT | Total | Absent--081203K1 | | N/A | 0.06 | Dec 10, 2008 |
| Nov 24, 2008 | 1 | RT | Total | Absent--081125H2 | | N/A | 0.17 | Dec 03, 2008 |
| Nov 24, 2008 | 1 | RT | Total | Absent--081125H1 | | N/A | 0.15 | Dec 03, 2008 |
| Nov 18, 2008 | 1 | RT | Total | Absent--081119E2 | | N/A | 0.12 | Nov 28, 2008 |
| Nov 18, 2008 | 1 | RT | Total | Absent--081119E1 | | N/A | 0.13 | Nov 28, 2008 |
| Nov 12, 2008 | 1 | RT | Total | Absent--081113D2 | | N/A | 0.12 | Nov 21, 2008 |
| Nov 12, 2008 | 1 | RT | Total | Absent--081113D1 | | N/A | 0.09 | Nov 21, 2008 |
| Nov 04, 2008 | 1 | RT | Total | Absent--081105N3 | | N/A | 0.07 | Nov 10, 2008 |
| Nov 04, 2008 | 1 | RT | Total | Absent--081105N2 | | N/A | 0.07 | Nov 10, 2008 |
| Oct 28, 2008 | 1 | RT | Total | Absent--081029F2 | | N/A | 0.20 | Nov 07, 2008 |
| Oct 28, 2008 | 1 | RT | Total | Absent--081029F1 | | N/A | 0.10 | Nov 07, 2008 |
| Oct 21, 2008 | 1 | RT | Total | Absent--081022D2L | | N/A | 0.31 | Oct 27, 2008 |
| Oct 21, 2008 | 1 | RT | Total | Absent--081022D1L | | N/A | 0.27 | Oct 27, 2008 |
| Oct 07, 2008 | 1 | RT | Total | Absent--081008J2L | | N/A | 0.37 | Oct 14, 2008 |
| Oct 07, 2008 | 1 | RT | Total | Absent--081008J1L | | N/A | 0.33 | Oct 14, 2008 |
| Oct 01, 2008 | 1 | RT | Total | Absent--081002H2 | | N/A | 0.23 | Oct 06, 2008 |
| Oct 01, 2008 | 1 | RT | Total | Absent--081002H1 | | N/A | 0.26 | Oct 06, 2008 |
| Sep 23, 2008 | 1 | RT | Total | Absent--080923I2 | | N/A | 0.31 | Oct 06, 2008 |
| Sep 23, 2008 | 1 | RT | Total | Absent--080923I1 | | N/A | 0.32 | Oct 06, 2008 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------|---------------------|-------------|-------------|--------------|
| Sep 16, 2008 | 1 | RT | Total | Absent--080917I1L | | N/A | 0.03 | Sep 24, 2008 |
| Sep 16, 2008 | 1 | RT | Total | Absent--080917I2 | | N/A | 0.06 | Sep 24, 2008 |
| Sep 09, 2008 | 1 | RT | Total | Absent--080910H1 | | N/A | 0.23 | Sep 24, 2008 |
| Sep 09, 2008 | 1 | RT | Total | Absent--080910H2 | | N/A | 0.10 | Sep 24, 2008 |
| Sep 03, 2008 | 1 | RT | Total | Absent--080904K1 | | N/A | 0.24 | Sep 11, 2008 |
| Sep 03, 2008 | 1 | RT | Total | Absent--080904K2 | | N/A | 0.18 | Sep 11, 2008 |
| Aug 26, 2008 | 1 | RT | Total | Absent--080827I2 | | N/A | 0.88 | Sep 05, 2008 |
| Aug 26, 2008 | 1 | RT | Total | Absent--080827I1 | | N/A | 0.55 | Sep 05, 2008 |
| Aug 19, 2008 | 1 | RT | Total | Absent--080820F2 | | N/A | 0.24 | Aug 28, 2008 |
| Aug 19, 2008 | 1 | RT | Total | Absent--080820F1 | | N/A | 0.25 | Aug 28, 2008 |

| | | | | | | | |
|--------------|---|----|-------|------------------|----------|------|--------------|
| Aug 14, 2008 | 1 | RT | Total | Absent--081015J2 | N/A | 0.18 | Oct 23, 2008 |
| Aug 14, 2008 | 1 | RT | Total | Absent--081015J1 | N/A | 0.12 | Oct 23, 2008 |
| Aug 13, 2008 | 1 | RT | Total | Absent--080814H2 | N/A | 0.10 | Aug 28, 2008 |
| Aug 13, 2008 | 1 | RT | Total | Absent--080814H1 | N/A | 0.02 | Aug 28, 2008 |
| Aug 05, 2008 | 1 | RT | Total | Absent--080806K3 | N/A | 0.22 | Aug 14, 2008 |
| Aug 05, 2008 | 1 | RT | Total | Absent--080806K2 | N/A | 0.26 | Aug 14, 2008 |
| Jul 29, 2008 | 1 | RT | Total | Absent--A80730B1 | HOSE BIB | 0.17 | Aug 05, 2008 |
| Jul 29, 2008 | 1 | RT | Total | Absent--A80730B4 | HOSE BIB | 0.27 | Aug 05, 2008 |
| Jul 29, 2008 | 1 | RT | Total | Absent--A80730B3 | HOSE BIB | 0.33 | Aug 05, 2008 |
| Jul 29, 2008 | 1 | RT | Total | Absent--A80730B2 | HOSE BIB | 0.10 | Aug 05, 2008 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-----------------------|---------------------|-------------|-------------|--------------|
| Jul 09, 2008 | 1 | RT | Total | Absent--MO080710PU131 | N/A | | 0.37 | Aug 06, 2008 |
| Jul 09, 2008 | 1 | RT | Total | Absent--MO080710PN123 | N/A | | 0.22 | Aug 06, 2008 |
| Jul 01, 2008 | 1 | RT | Total | Absent--MO080702PP329 | N/A | | 0.19 | Jul 24, 2008 |
| Jul 01, 2008 | 1 | RT | Total | Absent--MO080702PP328 | N/A | | 0.19 | Jul 24, 2008 |
| Jun 25, 2008 | 1 | RT | Total | Absent--MO080626PF212 | N/A | | 0.05 | Jul 07, 2008 |
| Jun 25, 2008 | 1 | RT | Total | Absent--MO080626PF211 | N/A | | 0.43 | Jul 07, 2008 |
| Jun 18, 2008 | 1 | RT | Total | Absent--MO080619PE27 | N/A | | 0.08 | Jul 02, 2008 |
| Jun 18, 2008 | 1 | RT | Total | Absent--MO080619PE28 | N/A | | 0.08 | Jul 02, 2008 |
| Jun 11, 2008 | 1 | RT | Total | Absent--MO080612PD35 | N/A | | 0.28 | Jul 02, 2008 |
| Jun 11, 2008 | 1 | RT | Total | Absent--MO080612PD34 | N/A | | 0.17 | Jul 02, 2008 |
| Jun 04, 2008 | 1 | RT | Total | Absent--MO080605PK316 | N/A | | 0.39 | Jul 02, 2008 |
| Jun 04, 2008 | 1 | RT | Total | Absent--MO080605PK315 | N/A | | 0.33 | Jul 02, 2008 |
| May 28, 2008 | 1 | RT | Total | Absent--MO080529PE26 | N/A | | 0.22 | Jun 05, 2008 |
| May 28, 2008 | 1 | RT | Total | Absent--MO080529PE25 | N/A | | 0.24 | Jun 05, 2008 |
| May 21, 2008 | 1 | RT | Total | Absent--MO080522PB22 | N/A | | 0.13 | Jun 02, 2008 |
| May 21, 2008 | 1 | RT | Total | Absent--MO080522PB23 | N/A | | 0.07 | Jun 02, 2008 |
| May 14, 2008 | 1 | RT | Total | Absent--MO080515PI212 | N/A | | 0.05 | May 27, 2008 |
| May 14, 2008 | 1 | RT | Total | Absent--MO080515PI211 | N/A | | 0.22 | May 27, 2008 |
| May 07, 2008 | 1 | RT | Total | Absent--MO080508PF48 | N/A | | 1.05 | May 27, 2008 |
| May 07, 2008 | 1 | RT | Total | Absent--MO080508PF47 | N/A | | 0.73 | May 27, 2008 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-----------------------|---------------------|-------------|-------------|--------------|
| Apr 22, 2008 | 1 | RT | Total | Absent--M0080423PH213 | N/A | | 0.26 | May 01, 2008 |
| Apr 22, 2008 | 1 | RT | Total | Absent--M0080423PH212 | N/A | | 0.20 | May 01, 2008 |
| Apr 16, 2008 | 1 | RT | Total | Absent--M0080417PB23 | N/A | | 0.13 | May 01, 2008 |
| Apr 16, 2008 | 1 | RT | Total | Absent--M0080417PB22 | N/A | | 0.25 | May 01, 2008 |
| Apr 09, 2008 | 1 | RT | Total | Absent--M0080410PE28 | N/A | | 0.16 | May 01, 2008 |
| Apr 09, 2008 | 1 | RT | Total | Absent--M0080410PE27 | N/A | | 0.10 | May 01, 2008 |

| | | | | | | | |
|--------------|---|----|-------|-----------------------|-----|------|--------------|
| Mar 25, 2008 | 1 | RT | Total | Absent--M0080326PI217 | N/A | 0.11 | Mar 31, 2008 |
| Mar 25, 2008 | 1 | RT | Total | Absent--M0080326PI216 | N/A | 0.04 | Mar 31, 2008 |
| Mar 19, 2008 | 1 | RT | Total | Absent--M0080320PE27 | N/A | 0.06 | Mar 31, 2008 |
| Mar 19, 2008 | 1 | RT | Total | Absent--M0080320PE26 | N/A | 0.20 | Mar 31, 2008 |
| Mar 11, 2008 | 1 | RT | Total | Absent--M0080312PJ218 | N/A | 0.35 | Mar 17, 2008 |
| Mar 11, 2008 | 1 | RT | Total | Absent--M0080312PJ217 | N/A | 0.36 | Mar 17, 2008 |
| Mar 05, 2008 | 1 | RT | Total | Absent--M0080306PD48 | N/A | 0.04 | Mar 10, 2008 |
| Mar 05, 2008 | 1 | RT | Total | Absent--M0080306PD49 | N/A | 0.27 | Mar 10, 2008 |
| Feb 27, 2008 | 1 | RT | Total | Absent--M0080228PB22 | N/A | 0.22 | Mar 03, 2008 |
| Feb 27, 2008 | 1 | RT | Total | Absent--M0080228PB23 | N/A | 0.19 | Mar 03, 2008 |
| Feb 20, 2008 | 1 | RT | Total | Absent--M0080221PA21 | N/A | 0.28 | Feb 25, 2008 |
| Feb 20, 2008 | 1 | RT | Total | Absent--M0080221PA22 | N/A | 0.27 | Feb 25, 2008 |
| Feb 13, 2008 | 1 | RT | Total | Absent--M0080214PE26 | N/A | 0.04 | Feb 19, 2008 |
| Feb 13, 2008 | 1 | RT | Total | Absent--M0080214PE27 | N/A | 0.22 | Feb 19, 2008 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-----------------------|---------------------|-------------|--------------|--------------|
| Feb 06, 2008 | 1 | RT | Total | Absent--M0080207PE49 | N/A | 0.19 | Feb 19, 2008 | |
| Feb 06, 2008 | 1 | RT | Total | Absent--M0080207PE410 | N/A | 0.03 | Feb 19, 2008 | |
| Jan 30, 2008 | 1 | RT | Total | Absent--M0080131PE26 | N/A | 0.03 | Feb 04, 2008 | |
| Jan 30, 2008 | 1 | RT | Total | Absent--M0080131PE27 | N/A | 0.05 | Feb 04, 2008 | |
| Jan 22, 2008 | 1 | RT | Total | Absent--M0080123PH216 | N/A | 0.30 | Jan 28, 2008 | |
| Jan 22, 2008 | 1 | RT | Total | Absent--M0080123PH215 | N/A | 0.23 | Jan 28, 2008 | |
| Jan 15, 2008 | 1 | RT | Total | Absent--M0080116PG28 | N/A | 0.10 | Jan 22, 2008 | |
| Jan 15, 2008 | 1 | RT | Total | Absent--M0080116PG29 | N/A | 0.10 | Jan 22, 2008 | |
| Jan 08, 2008 | 1 | RT | Total | Absent--M0080109PH411 | N/A | 0.45 | Jan 14, 2008 | |
| Jan 08, 2008 | 1 | RT | Total | Absent--M0080109PH410 | N/A | 0.44 | Jan 14, 2008 | |
| Jan 02, 2008 | 1 | RT | Total | Absent--M0080103PF217 | N/A | 0.05 | Jan 09, 2008 | |
| Jan 02, 2008 | 1 | RT | Total | Absent--M0080103PF216 | N/A | 0.07 | Jan 09, 2008 | |
| Dec 26, 2007 | 1 | RT | Total | Absent--M0071227PB22 | N/A | 0.41 | Dec 31, 2007 | |
| Dec 26, 2007 | 1 | RT | Total | Absent--M0071227PB23 | N/A | 0.45 | Dec 31, 2007 | |
| Dec 19, 2007 | 1 | RT | Total | Absent--M0071220PC23 | N/A | 0.10 | Dec 26, 2007 | |
| Dec 19, 2007 | 1 | RT | Total | Absent--M0071220PC24 | N/A | 0.31 | Dec 26, 2007 | |
| Dec 11, 2007 | 1 | RT | Total | Absent--M0071212PE26 | N/A | 0.28 | Dec 17, 2007 | |
| Dec 11, 2007 | 1 | RT | Total | Absent--M0071212PE25 | N/A | 0.13 | Dec 17, 2007 | |
| Dec 05, 2007 | 1 | RT | Total | Absent--M0071206PD47 | N/A | 0.16 | Dec 10, 2007 | |
| Dec 05, 2007 | 1 | RT | Total | Absent--M0071206PD46 | N/A | 0.15 | Dec 10, 2007 | |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|--------------|--------------|
| Nov 28, 2007 | 1 | RT | Total | Absent--M0071129PD28 | N/A | 0.18 | Dec 03, 2007 | |
| Nov 28, 2007 | 1 | RT | Total | Absent--M0071129PD27 | N/A | 0.02 | Dec 03, 2007 | |

| | | | | | | | |
|--------------|---|----|-------|------------------------|-----|------|--------------|
| Nov 19, 2007 | 1 | RT | Total | Absent--M0071120PL218 | N/A | 0.17 | Nov 23, 2007 |
| Nov 19, 2007 | 1 | RT | Total | Absent--M0071120PL217 | N/A | 0.16 | Nov 23, 2007 |
| Nov 14, 2007 | 1 | RT | Total | Absent--M00711115PL219 | N/A | 0.13 | Nov 21, 2007 |
| Nov 14, 2007 | 1 | RT | Total | Absent--M0071115PL220 | N/A | 0.25 | Nov 21, 2007 |
| Nov 08, 2007 | 1 | RT | Total | Absent--M0071109PC44 | N/A | 0.22 | Nov 15, 2007 |
| Nov 08, 2007 | 1 | RT | Total | Absent--M0071109PC43 | N/A | 0.20 | Nov 15, 2007 |
| Oct 31, 2007 | 1 | RT | Total | Absent--M0071101PG216 | N/A | 0.17 | Nov 05, 2007 |
| Oct 31, 2007 | 1 | RT | Total | Absent--M0071101PG215 | N/A | 0.01 | Nov 05, 2007 |
| Oct 24, 2007 | 1 | RT | Total | Absent--M0071025PD25 | N/A | 0.12 | Oct 31, 2007 |
| Oct 24, 2007 | 1 | RT | Total | Absent--M0071025PD24 | N/A | 0.10 | Oct 31, 2007 |
| Oct 17, 2007 | 1 | RT | Total | Absent--M0071018PE28 | N/A | 0.43 | Oct 22, 2007 |
| Oct 17, 2007 | 1 | RT | Total | Absent--M0071018PE27 | N/A | 0.48 | Oct 22, 2007 |
| Oct 10, 2007 | 1 | RT | Total | Absent--M0071011PG28 | N/A | 0.12 | Oct 15, 2007 |
| Oct 10, 2007 | 1 | RT | Total | Absent--M0071011PG27 | N/A | 0.10 | Oct 15, 2007 |
| Oct 03, 2007 | 1 | RT | Total | Absent--M0071004PE8 | N/A | 0.08 | Oct 09, 2007 |
| Oct 03, 2007 | 1 | RT | Total | Absent--M0071004PG49 | N/A | 0.62 | Oct 09, 2007 |
| Sep 19, 2007 | 1 | RT | Total | Absent--M0070920PG314 | N/A | 0.33 | Sep 24, 2007 |
| Sep 19, 2007 | 1 | RT | Total | Absent--M0070920PG313 | N/A | 0.01 | Sep 24, 2007 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|------------------------|---------------------|-------------|-------------|--------------|
| Sep 19, 2007 | 1 | RT | Total | Absent--M0070920PG312 | | N/A | 0.38 | Sep 24, 2007 |
| Sep 12, 2007 | 1 | RT | Total | Absent--M0070914PB23 | | N/A | 0.29 | Sep 19, 2007 |
| Sep 12, 2007 | 1 | RT | Total | Absent--M0070914PB22 | | N/A | 0.23 | Sep 19, 2007 |
| Sep 05, 2007 | 1 | RT | Total | Absent--M0070906PIL417 | | N/A | 0.09 | Sep 10, 2007 |
| Sep 05, 2007 | 1 | RT | Total | Absent--M0070906PIL416 | | N/A | 0.41 | Sep 10, 2007 |
| Aug 29, 2007 | 1 | RT | Total | Absent--M0070830PE25 | | N/A | 0.25 | Sep 06, 2007 |
| Aug 29, 2007 | 1 | RT | Total | Absent--M0070830PE26 | | N/A | 0.22 | Sep 06, 2007 |
| Aug 22, 2007 | 1 | RT | Total | Absent--M0070823PG29 | | N/A | 0.40 | Aug 27, 2007 |
| Aug 22, 2007 | 1 | RT | Total | Absent--M0070823PG210 | | N/A | 0.38 | Aug 27, 2007 |
| Aug 15, 2007 | 1 | RT | Total | Absent--M0070816PH28 | | N/A | 0.25 | Aug 20, 2007 |
| Aug 15, 2007 | 1 | RT | Total | Absent--M0070816PH27 | | N/A | 0.20 | Aug 20, 2007 |
| Aug 08, 2007 | 1 | RT | Total | Absent--M0070809PF411 | | N/A | 0.28 | Aug 13, 2007 |
| Aug 08, 2007 | 1 | RT | Total | Absent--M0070809PF410 | | N/A | 0.15 | Aug 13, 2007 |
| Aug 01, 2007 | 1 | RT | Total | Absent--M0070802PH219 | | N/A | 0.25 | Aug 06, 2007 |
| Aug 01, 2007 | 1 | RT | Total | Absent--M0070802PH218 | | N/A | 0.20 | Aug 06, 2007 |
| Jul 25, 2007 | 1 | RT | Total | Absent--M0070726PB23 | | N/A | 0.19 | Aug 01, 2007 |
| Jul 25, 2007 | 1 | RT | Total | Absent--M0070726PB22 | | N/A | 0.41 | Aug 01, 2007 |
| Jul 18, 2007 | 1 | RT | Total | Absent--M0070719PD26 | | N/A | 0.25 | Aug 01, 2007 |
| Jul 18, 2007 | 1 | RT | Total | Absent--M0070719PD25 | | N/A | 0.20 | Aug 01, 2007 |
| Jul 11, 2007 | 1 | RT | Total | Absent--M0070712PF213 | | N/A | 0.23 | Jul 16, 2007 |

Repeat

| Sample Date | # Samples | Coliform Type | Type | Results--ID | of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-----------------------|--------------|-------------|-------------|--------------|
| Jul 11, 2007 | 1 | RT | Total | Absent--M0070712PF212 | | N/A | 0.14 | Jul 16, 2007 |
| Jun 27, 2007 | 1 | RT | Total | Absent--M0070628PH310 | | N/A | 0.25 | Jul 05, 2007 |
| Jun 27, 2007 | 1 | RT | Total | Absent--M0070628PH311 | | N/A | 0.28 | Jul 05, 2007 |
| Jun 19, 2007 | 1 | RT | Total | Absent--M0070620PH210 | | N/A | 0.08 | Jun 25, 2007 |
| Jun 19, 2007 | 1 | RT | Total | Absent--M0070620PH29 | | N/A | 0.20 | Jun 25, 2007 |
| Jun 13, 2007 | 1 | RT | Total | Absent--M0070614PF213 | | N/A | 0.06 | Jun 18, 2007 |
| Jun 13, 2007 | 1 | RT | Total | Absent--M0070614PF212 | | N/A | 0.01 | Jun 18, 2007 |
| Jun 06, 2007 | 1 | RT | Total | Absent--M0070607PI513 | | N/A | 0.35 | Jun 11, 2007 |
| Jun 06, 2007 | 1 | RT | Total | Absent--M0070607PI512 | | N/A | 0.95 | Jun 11, 2007 |
| May 30, 2007 | 1 | RT | Total | Absent--M0070531PD27 | | N/A | 0.16 | Jun 04, 2007 |
| May 30, 2007 | 1 | RT | Total | Absent--M0070531PD26 | | N/A | 0.10 | Jun 04, 2007 |
| May 23, 2007 | 1 | RT | Total | Absent--M0070524PJ212 | | N/A | 0.05 | Jun 04, 2007 |
| May 23, 2007 | 1 | RT | Total | Absent--M0070524PJ211 | | N/A | 0.11 | Jun 04, 2007 |
| May 16, 2007 | 1 | RT | Total | Absent--M0070517PH217 | | N/A | 0.17 | May 21, 2007 |
| May 16, 2007 | 1 | RT | Total | Absent--M0070517PH216 | | N/A | 0.18 | May 21, 2007 |
| May 09, 2007 | 1 | RT | Total | Absent--M0070510PG210 | | N/A | 0.24 | May 14, 2007 |
| May 09, 2007 | 1 | RT | Total | Absent--M0070510PG29 | | N/A | 0.29 | May 14, 2007 |
| May 02, 2007 | 1 | RT | Total | Absent--M0070503PG411 | | N/A | 0.15 | May 07, 2007 |
| May 02, 2007 | 1 | RT | Total | Absent--M0070503PG412 | | N/A | 0.14 | May 07, 2007 |
| Apr 25, 2007 | 1 | RT | Total | Absent--M0070426PF27 | | N/A | 0.14 | May 02, 2007 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-----------------------|---------------------|-------------|-------------|--------------|
| Apr 25, 2007 | 1 | RT | Total | Absent--M0070426PF26 | | N/A | 0.14 | May 02, 2007 |
| Apr 17, 2007 | 1 | RT | Total | Absent--M0070418PI211 | | N/A | 0.16 | Apr 23, 2007 |
| Apr 17, 2007 | 1 | RT | Total | Absent--M0070418PI210 | | N/A | 0.22 | Apr 23, 2007 |
| Apr 11, 2007 | 1 | RT | Total | Absent--M0070412PD25 | | N/A | 0.19 | Apr 16, 2007 |
| Apr 11, 2007 | 1 | RT | Total | Absent--M0070412PD24 | | N/A | 0.22 | Apr 16, 2007 |
| Apr 04, 2007 | 1 | RT | Total | Absent--M0070405PF48 | | N/A | 0.15 | Apr 09, 2007 |
| Apr 04, 2007 | 1 | RT | Total | Absent--M0070405PF47 | | N/A | 0.15 | Apr 09, 2007 |
| Mar 27, 2007 | 1 | RT | Total | Absent--M0070327PG38 | | N/A | 0.48 | Apr 02, 2007 |
| Mar 27, 2007 | 1 | RT | Total | Absent--M0070327PG37 | | N/A | 0.68 | Apr 02, 2007 |
| Mar 21, 2007 | 1 | RT | Total | Absent--M0070322PG210 | | N/A | 0.22 | Mar 26, 2007 |
| Mar 21, 2007 | 1 | RT | Total | Absent--M0070322PG29 | | N/A | 0.19 | Mar 26, 2007 |
| Mar 14, 2007 | 1 | RT | Total | Absent--M0070315PK212 | | N/A | 0.31 | Mar 19, 2007 |
| Mar 14, 2007 | 1 | RT | Total | Absent--M0070315PK211 | | N/A | 0.26 | Mar 19, 2007 |
| Mar 07, 2007 | 1 | RT | Total | Absent--M0070308PD45 | | N/A | 0.14 | Mar 14, 2007 |
| Mar 07, 2007 | 1 | RT | Total | Absent--M0070308PD44 | | N/A | 0.13 | Mar 14, 2007 |
| Feb 28, 2007 | 1 | RT | Total | Absent--M0070301PG29 | | N/A | 0.25 | Mar 05, 2007 |
| Feb 28, 2007 | 1 | RT | Total | Absent--M0070301PG28 | | N/A | 0.22 | Mar 05, 2007 |

| Feb 21, 2007 | 1 | RT | Total | Absent--M0070222PE26 | N/A | 0.20 | Feb 26, 2007 | |
|--------------|-----------|---------------|-------|------------------------|---------------------|-------------|--------------|--------------|
| Feb 21, 2007 | 1 | RT | Total | Absent--M0070222PE25 | N/A | 0.17 | Feb 26, 2007 | |
| Feb 14, 2007 | 1 | RT | Total | Absent--M0070215PF27 | N/A | 0.31 | Feb 20, 2007 | |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Feb 14, 2007 | 1 | RT | Total | Absent--M0070215PF26 | N/A | 0.25 | Feb 20, 2007 | |
| Feb 07, 2007 | 1 | RT | Total | Absent--M0070208PE48 | N/A | 0.10 | Feb 12, 2007 | |
| Feb 07, 2007 | 1 | RT | Total | Absent--M0070208PE47 | N/A | 0.08 | Feb 12, 2007 | |
| Jan 31, 2007 | 1 | RT | Total | Absent--M0070201PC24 | N/A | 0.24 | Feb 05, 2007 | |
| Jan 31, 2007 | 1 | RT | Total | Absent--M0070201PC23 | N/A | 0.10 | Feb 05, 2007 | |
| Jan 24, 2007 | 1 | RT | Total | Absent--M0070125PE27 | N/A | 0.15 | Jan 29, 2007 | |
| Jan 24, 2007 | 1 | RT | Total | Absent--M0070125PE26 | N/A | 0.20 | Jan 29, 2007 | |
| Jan 17, 2007 | 1 | RT | Total | Absent--M0070118PC26 | N/A | 0.34 | Jan 22, 2007 | |
| Jan 17, 2007 | 1 | RT | Total | Absent--M0070118PC25 | N/A | 0.29 | Jan 22, 2007 | |
| Jan 10, 2007 | 1 | RT | Total | Absent--M0070111PF27 | N/A | 0.17 | Jan 16, 2007 | |
| Jan 10, 2007 | 1 | RT | Total | Absent--M0070111PF26 | N/A | 0.19 | Jan 16, 2007 | |
| Jan 03, 2007 | 1 | RT | Total | Absent--M0070104PG49 | N/A | 0.45 | Jan 10, 2007 | |
| Jan 03, 2007 | 1 | RT | Total | Absent--M0070104PG48 | N/A | 0.70 | Jan 10, 2007 | |
| Dec 26, 2006 | 1 | RT | Total | Absent--M0061227PD26 | N/A | 0.16 | Jan 03, 2007 | |
| Dec 26, 2006 | 1 | RT | Total | Absent--M0061227PD25 | N/A | 0.16 | Jan 03, 2007 | |
| Dec 18, 2006 | 1 | RT | Total | Absent--M0061219PE26 | N/A | 0.39 | Dec 26, 2006 | |
| Dec 18, 2006 | 1 | RT | Total | Absent--M0061219PE25 | N/A | 0.41 | Dec 26, 2006 | |
| Dec 13, 2006 | 1 | RT | Total | Absent--M0061214PH211 | N/A | 0.09 | Dec 18, 2006 | |
| Dec 13, 2006 | 1 | RT | Total | Absent--M0061214PH210 | N/A | 0.04 | Dec 18, 2006 | |
| Dec 06, 2006 | 1 | RT | Total | Absent--M0061207PF47 | N/A | 0.35 | Dec 11, 2006 | |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Dec 06, 2006 | 1 | RT | Total | Absent--M0061207PF46 | N/A | 0.39 | Dec 11, 2006 | |
| Nov 29, 2006 | 1 | RT | Total | Absent--M0061130PG210 | N/A | 0.13 | Dec 04, 2006 | |
| Nov 29, 2006 | 1 | RT | Total | Absent--M0061130PG29 | N/A | 0.15 | Dec 04, 2006 | |
| Nov 20, 2006 | 1 | RT | Total | Absent--M0061121PK216 | N/A | 0.30 | Nov 30, 2006 | |
| Nov 20, 2006 | 1 | RT | Total | Absent--M0061121PK215 | N/A | 0.26 | Nov 30, 2006 | |
| Nov 15, 2006 | 1 | RT | Total | Absent--M0061116PC24 | N/A | 0.26 | Nov 20, 2006 | |
| Nov 15, 2006 | 1 | RT | Total | Absent--M0061116PC23 | N/A | 0.24 | Nov 20, 2006 | |
| Nov 07, 2006 | 1 | RT | Total | Absent--M0061108PE25 | N/A | 0.13 | Nov 10, 2006 | |
| Nov 07, 2006 | 1 | RT | Total | Absent--M0061108PE26 | N/A | 0.39 | Nov 13, 2006 | |
| Nov 01, 2006 | 1 | RT | Total | Absent--M0061102PF411 | N/A | 0.14 | Nov 06, 2006 | |
| Nov 01, 2006 | 1 | RT | Total | Absent--M0061102PF410 | N/A | 0.04 | Nov 06, 2006 | |
| Oct 25, 2006 | 1 | RT | Total | Absent--M0061026PE25-2 | N/A | 0.04 | Oct 30, 2006 | |
| Oct 25, 2006 | 1 | RT | Total | Absent--M0061026PE25-1 | N/A | 0.04 | Oct 30, 2006 | |

| | | | | | | | |
|--------------|---|----|-------|-------------------------|-----|------|--------------|
| Oct 18, 2006 | 1 | RT | Total | Absent--M0061019PG27-2 | N/A | 0.19 | Oct 23, 2006 |
| Oct 18, 2006 | 1 | RT | Total | Absent--M0061019PG27-1 | N/A | 0.19 | Oct 23, 2006 |
| Oct 11, 2006 | 1 | RT | Total | Absent--M0061012PF210-2 | N/A | 0.50 | Oct 16, 2006 |
| Oct 11, 2006 | 1 | RT | Total | Absent--M0061012PF210-1 | N/A | 0.50 | Oct 16, 2006 |
| Oct 04, 2006 | 1 | RT | Total | Absent--M0061005PF46-2 | N/A | 0.27 | Oct 12, 2006 |
| Oct 04, 2006 | 1 | RT | Total | Absent--M0061005PF46-1 | N/A | 0.27 | Oct 12, 2006 |
| Sep 27, 2006 | 1 | RT | Total | Absent--M0060928PC33-2 | N/A | 0.20 | Oct 04, 2006 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | Cl Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Sep 27, 2006 | 1 | RT | Total | Absent--M0060928PC33-1 | N/A | | 0.20 | Oct 04, 2006 |
| Sep 20, 2006 | 1 | RT | Total | Absent--M0060921PE25-2 | N/A | | 0.12 | Sep 25, 2006 |
| Sep 20, 2006 | 1 | RT | Total | Absent--M0060921PE25-1 | N/A | | 0.12 | Sep 25, 2006 |
| Sep 13, 2006 | 1 | RT | Total | Absent--M0060914PE27-2 | N/A | | 0.39 | Sep 20, 2006 |
| Sep 13, 2006 | 1 | RT | Total | Absent--M0060914PE27-1 | N/A | | 0.39 | Sep 20, 2006 |
| Sep 06, 2006 | 1 | RT | Total | Absent--M0060907PF48-2 | N/A | | 0.25 | Sep 12, 2006 |
| Sep 06, 2006 | 1 | RT | Total | Absent--M0060907PF48-1 | N/A | | 0.25 | Sep 12, 2006 |
| Aug 30, 2006 | 1 | RT | Total | Absent--M0060831PC23-2 | N/A | | 0.33 | Sep 05, 2006 |
| Aug 30, 2006 | 1 | RT | Total | Absent--M0060831PC23-1 | N/A | | 0.33 | Sep 05, 2006 |
| Aug 23, 2006 | 1 | RT | Total | Absent--M0060824PA21-2 | N/A | | 0.38 | Aug 28, 2006 |
| Aug 23, 2006 | 1 | RT | Total | Absent--M0060824PA21-1 | N/A | | 0.38 | Aug 28, 2006 |
| Aug 16, 2006 | 1 | RT | Total | Absent--M0060817PE26-2 | N/A | | 0.52 | Aug 24, 2006 |
| Aug 16, 2006 | 1 | RT | Total | Absent--M0060817PE26-1 | N/A | | 0.52 | Aug 24, 2006 |
| Aug 09, 2006 | 1 | RT | Total | Absent--M0060810PE411-2 | N/A | | 0.27 | Aug 14, 2006 |
| Aug 09, 2006 | 1 | RT | Total | Absent--M0060810PE411-1 | N/A | | 0.27 | Aug 14, 2006 |
| Aug 02, 2006 | 1 | RT | Total | Absent--M0060803PD25-2 | N/A | | 0.39 | Aug 07, 2006 |
| Aug 02, 2006 | 1 | RT | Total | Absent--M0060803PD25-1 | N/A | | 0.39 | Aug 07, 2006 |
| Jul 26, 2006 | 1 | RT | Total | Absent--M0060727PF28-2 | N/A | | 0.36 | Aug 01, 2006 |
| Jul 26, 2006 | 1 | RT | Total | Absent--M0060727PF28-1 | N/A | | 0.36 | Aug 01, 2006 |
| Jul 19, 2006 | 1 | RT | Total | Absent--M0060720PB34-2 | N/A | | 0.12 | Jul 24, 2006 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | Cl Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Jul 19, 2006 | 1 | RT | Total | Absent--M0060720PB34-1 | N/A | | 0.12 | Jul 24, 2006 |
| Jul 12, 2006 | 1 | RT | Total | Absent--M0060713PJ421 | N/A | | 0.01 | Jul 17, 2006 |
| Jul 06, 2006 | 1 | RT | Total | Absent--M0060707PH211-2 | N/A | | 0.04 | Jul 17, 2006 |
| Jul 06, 2006 | 1 | RT | Total | Absent--M0060707PH211-1 | N/A | | 0.04 | Jul 17, 2006 |
| Jun 28, 2006 | 1 | RT | Total | Absent--M0060629PF28-2 | N/A | | 0.14 | Jul 03, 2006 |
| Jun 28, 2006 | 1 | RT | Total | Absent--M0060629PF28-1 | N/A | | 0.14 | Jul 03, 2006 |
| Jun 22, 2006 | 1 | RT | Total | Absent--M0060623PB22-2 | N/A | | 0.24 | Jul 03, 2006 |
| Jun 22, 2006 | 1 | RT | Total | Absent--M0060623PB22-1 | N/A | | 0.24 | Jul 03, 2006 |
| Jun 14, 2006 | 1 | RT | Total | Absent--M0060615PG28-2 | N/A | | 0.26 | Jun 19, 2006 |

| Jun 14, 2006 | 1 | RT | Total | Absent--M0060615PG28-1 | N/A | 0.26 | Jun 19, 2006 | |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|--------------|--------------|
| Jun 07, 2006 | 1 | RT | Total | Absent--M0060608PD44-2 | N/A | 0.25 | Jun 12, 2006 | |
| Jun 07, 2006 | 1 | RT | Total | Absent--M0060608PD44-1 | N/A | 0.25 | Jun 12, 2006 | |
| May 24, 2006 | 1 | RT | Total | Absent--M0060525PC211-2 | N/A | 0.22 | May 30, 2006 | |
| May 24, 2006 | 1 | RT | Total | Absent--M0060525PC211-1 | N/A | 0.22 | May 30, 2006 | |
| May 17, 2006 | 1 | RT | Total | Absent--M0060518PE25-2 | N/A | 0.28 | May 22, 2006 | |
| May 17, 2006 | 1 | RT | Total | Absent--M0060518PE25-1 | N/A | 0.28 | May 22, 2006 | |
| May 10, 2006 | 1 | RT | Total | Absent--M0060511PH29-2 | N/A | 0.27 | May 17, 2006 | |
| May 10, 2006 | 1 | RT | Total | Absent--M0060511PH29-1 | N/A | 0.27 | May 17, 2006 | |
| May 03, 2006 | 1 | RT | Total | Absent--M0060504PD44-2 | N/A | 0.15 | May 08, 2006 | |
| May 03, 2006 | 1 | RT | Total | Absent--M0060504PD44-1 | N/A | 0.15 | May 08, 2006 | |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Apr 27, 2006 | 1 | RT | Total | Absent--M0060428PF29-2 | N/A | 0.32 | May 03, 2006 | |
| Apr 27, 2006 | 1 | RT | Total | Absent--M0060428PF29-1 | N/A | 0.32 | May 03, 2006 | |
| Apr 19, 2006 | 1 | RT | Total | Absent--M0060420PD24-2 | N/A | 0.09 | Apr 26, 2006 | |
| Apr 19, 2006 | 1 | RT | Total | Absent--M0060420PD24-1 | N/A | 0.09 | Apr 26, 2006 | |
| Apr 12, 2006 | 1 | RT | Total | Absent--M0060413PH28-2 | N/A | 0.22 | Apr 17, 2006 | |
| Apr 12, 2006 | 1 | RT | Total | Absent--M0060413PH28-1 | N/A | 0.22 | Apr 17, 2006 | |
| Apr 05, 2006 | 1 | RT | Total | Absent--M0060406PH413 | N/A | 0.23 | Apr 10, 2006 | |
| Mar 29, 2006 | 1 | RT | Total | Absent--M0060330PB22-2 | N/A | 0.20 | Apr 03, 2006 | |
| Mar 29, 2006 | 1 | RT | Total | Absent--M0060330PB22-1 | N/A | 0.20 | Apr 03, 2006 | |
| Mar 22, 2006 | 1 | RT | Total | Absent--M0060323PD24-2 | N/A | 0.22 | Mar 27, 2006 | |
| Mar 22, 2006 | 1 | RT | Total | Absent--M0060323PD24-1 | N/A | 0.22 | Mar 27, 2006 | |
| Mar 16, 2006 | 1 | RT | Total | Absent--M0060317PD24-2 | N/A | 0.19 | Mar 27, 2006 | |
| Mar 16, 2006 | 1 | RT | Total | Absent--M0060317PD24-1 | N/A | 0.19 | Mar 27, 2006 | |
| Mar 08, 2006 | 1 | RT | Total | Absent--M0060309PE48 | N/A | 0.27 | Mar 13, 2006 | |
| Mar 08, 2006 | 1 | RT | Total | Absent--M0060309PE47 | N/A | 0.29 | Mar 13, 2006 | |
| Feb 22, 2006 | 1 | RT | Total | Absent--M0060223PE25-2 | N/A | 0.22 | Mar 01, 2006 | |
| Feb 22, 2006 | 1 | RT | Total | Absent--M0060223PE25-1 | N/A | 0.22 | Mar 01, 2006 | |
| Feb 15, 2006 | 1 | RT | Total | Absent--M0060216PH210-2 | N/A | 0.43 | Feb 21, 2006 | |
| Feb 15, 2006 | 1 | RT | Total | Absent--M0060216PH210-1 | N/A | 0.43 | Feb 21, 2006 | |
| Feb 08, 2006 | 1 | RT | Total | Absent--M0060209PG211-2 | N/A | 0.22 | Feb 13, 2006 | |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Feb 08, 2006 | 1 | RT | Total | Absent--M0060209PG211-1 | N/A | 0.22 | Feb 13, 2006 | |
| Feb 01, 2006 | 1 | RT | Total | Absent--M0060202PE45-2 | N/A | 0.30 | Feb 08, 2006 | |
| Feb 01, 2006 | 1 | RT | Total | Absent--M0060202PE45-1 | N/A | 0.30 | Feb 08, 2006 | |
| Jan 25, 2006 | 1 | RT | Total | Absent--M0060126PD25-2 | N/A | 0.15 | Jan 30, 2006 | |
| Jan 25, 2006 | 1 | RT | Total | Absent--M0060126PD25-1 | N/A | 0.15 | Jan 30, 2006 | |

| | | | | | | | |
|--------------|---|----|-------|------------------------|-----|------|--------------|
| Jan 18, 2006 | 1 | RT | Total | Absent--M0060119PF48-2 | N/A | 0.22 | Jan 23, 2006 |
| Jan 18, 2006 | 1 | RT | Total | Absent--M0060119PF48-1 | N/A | 0.22 | Jan 23, 2006 |
| Jan 11, 2006 | 1 | RT | Total | Absent--M0060113PB22-2 | N/A | 0.25 | Jan 23, 2006 |
| Jan 11, 2006 | 1 | RT | Total | Absent--M0060113PB22-1 | N/A | 0.25 | Jan 23, 2006 |
| Jan 04, 2006 | 1 | RT | Total | Absent--M0060105PC24-2 | N/A | 0.27 | Jan 09, 2006 |
| Jan 04, 2006 | 1 | RT | Total | Absent--M0060105PC24-1 | N/A | 0.27 | Jan 09, 2006 |
| Dec 28, 2005 | 1 | RT | Total | Absent--M0051229PE28-2 | N/A | 0.04 | Jan 03, 2006 |
| Dec 28, 2005 | 1 | RT | Total | Absent--M0051229PE28-1 | N/A | 0.04 | Jan 03, 2006 |
| Dec 20, 2005 | 1 | RT | Total | Absent--M0051221PD24 | N/A | 0.12 | Dec 27, 2005 |
| Dec 14, 2005 | 1 | RT | Total | Absent--M0051215PD54-2 | N/A | 0.08 | Dec 19, 2005 |
| Dec 14, 2005 | 1 | RT | Total | Absent--M0051215PD54-1 | N/A | 0.08 | Dec 19, 2005 |
| Dec 07, 2005 | 1 | RT | Total | Absent--M0051208PD46-2 | N/A | 0.17 | Dec 12, 2005 |
| Dec 07, 2005 | 1 | RT | Total | Absent--M0051208PD46-1 | N/A | 0.17 | Dec 12, 2005 |
| Nov 30, 2005 | 1 | RT | Total | Absent--M0051201PD25-2 | N/A | 0.17 | Dec 12, 2005 |
| Nov 30, 2005 | 1 | RT | Total | Absent--M0051201PD25-1 | N/A | 0.17 | Dec 12, 2005 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|--------------|--------------|
| Nov 16, 2005 | 1 | RT | Total | Absent--M0051117PC23-2 | N/A | 0.20 | Nov 21, 2005 | |
| Nov 16, 2005 | 1 | RT | Total | Absent--M0051117PC23-1 | N/A | 0.20 | Nov 21, 2005 | |
| Nov 09, 2005 | 1 | RT | Total | Absent--M0051110PD24-2 | N/A | 0.23 | Nov 16, 2005 | |
| Nov 09, 2005 | 1 | RT | Total | Absent--M0051110PD24-1 | N/A | 0.23 | Nov 16, 2005 | |
| Nov 02, 2005 | 1 | RT | Total | Absent--M0051103PC43-2 | N/A | 0.37 | Nov 07, 2005 | |
| Nov 02, 2005 | 1 | RT | Total | Absent--M0051103PC43-1 | N/A | 0.37 | Nov 07, 2005 | |
| Oct 26, 2005 | 1 | RT | Total | Absent--M0051027PC28-2 | N/A | 0.12 | Oct 31, 2005 | |
| Oct 26, 2005 | 1 | RT | Total | Absent--M0051027PC28-1 | N/A | 0.12 | Oct 31, 2005 | |
| Oct 19, 2005 | 1 | RT | Total | Absent--M0051020PC23-2 | N/A | 0.19 | Oct 24, 2005 | |
| Oct 19, 2005 | 1 | RT | Total | Absent--M0051020PC23-1 | N/A | 0.19 | Oct 24, 2005 | |
| Oct 12, 2005 | 1 | RT | Total | Absent--M0051013PE26 | N/A | 0.15 | Oct 17, 2005 | |
| Oct 12, 2005 | 1 | RT | Total | Absent--M0051013PE25 | N/A | 0.18 | Oct 17, 2005 | |
| Oct 05, 2005 | 1 | RT | Total | Absent--M0051006PG48-2 | N/A | 0.11 | Oct 12, 2005 | |
| Oct 05, 2005 | 1 | RT | Total | Absent--M0051006PG48-1 | N/A | 0.11 | Oct 12, 2005 | |
| Sep 28, 2005 | 1 | RT | Total | Absent--M0050929PD26-2 | N/A | 0.84 | Oct 04, 2005 | |
| Sep 28, 2005 | 1 | RT | Total | Absent--M0050929PD26-1 | N/A | 0.84 | Oct 04, 2005 | |
| Sep 21, 2005 | 1 | RT | Total | Absent--M0050922PF210-2 | N/A | 0.16 | Sep 27, 2005 | |
| Sep 21, 2005 | 1 | RT | Total | Absent--M0050922PF210-1 | N/A | 0.16 | Sep 27, 2005 | |
| Sep 14, 2005 | 1 | RT | Total | Absent--M0050915PE28-2 | N/A | 0.29 | Sep 19, 2005 | |
| Sep 14, 2005 | 1 | RT | Total | Absent--M0050915PE28-1 | N/A | 0.29 | Sep 19, 2005 | |
| Sep 07, 2005 | 1 | RT | Total | Absent--M0050908PF47-2 | N/A | 0.19 | Sep 12, 2005 | |

| | | | | | | | |
|--------------|---|----|-------|-------------------------|-----|------|--------------|
| Sep 07, 2005 | 1 | RT | Total | Absent--M0050908PF47-1 | N/A | 0.19 | Sep 12, 2005 |
| Aug 24, 2005 | 1 | RT | Total | Absent--M0050825PE45-2 | N/A | 0.17 | Aug 29, 2005 |
| Aug 24, 2005 | 1 | RT | Total | Absent--M0050825PE45-1 | N/A | 0.17 | Aug 29, 2005 |
| Aug 17, 2005 | 1 | RT | Total | Absent--M0050818PC23-2 | N/A | 0.20 | Aug 22, 2005 |
| Aug 17, 2005 | 1 | RT | Total | Absent--M0050818PC23-1 | N/A | 0.20 | Aug 22, 2005 |
| Aug 10, 2005 | 1 | RT | Total | Absent--M0050811PH49-2 | N/A | 0.18 | Aug 16, 2005 |
| Aug 10, 2005 | 1 | RT | Total | Absent--M0050811PH49-1 | N/A | 0.18 | Aug 16, 2005 |
| Aug 03, 2005 | 1 | RT | Total | Absent--M0050804PD24-2 | N/A | 0.24 | Aug 09, 2005 |
| Aug 03, 2005 | 1 | RT | Total | Absent--M0050804PD24-1 | N/A | 0.24 | Aug 09, 2005 |
| Jul 27, 2005 | 1 | RT | Total | Absent--M0050728PI29-2 | N/A | 0.30 | Aug 01, 2005 |
| Jul 27, 2005 | 1 | RT | Total | Absent--M0050728PI29-1 | N/A | 0.30 | Aug 01, 2005 |
| Jul 20, 2005 | 1 | RT | Total | Absent--M0050721PK215-2 | N/A | 0.18 | Jul 25, 2005 |
| Jul 20, 2005 | 1 | RT | Total | Absent--M0050721PK215-1 | N/A | 0.18 | Jul 25, 2005 |
| Jul 13, 2005 | 1 | RT | Total | Absent--M0050714PE27-2 | N/A | 0.04 | Jul 18, 2005 |
| Jul 13, 2005 | 1 | RT | Total | Absent--M0050714PE27-1 | N/A | 0.04 | Jul 18, 2005 |
| Jul 06, 2005 | 1 | RT | Total | Absent--M0050707PK223-2 | N/A | 0.14 | Jul 11, 2005 |
| Jul 06, 2005 | 1 | RT | Total | Absent--M0050707PK223-1 | N/A | 0.14 | Jul 11, 2005 |
| Jun 29, 2005 | 1 | RT | Total | Absent--M0050630PJ212-2 | N/A | 0.23 | Jul 11, 2005 |
| Jun 29, 2005 | 1 | RT | Total | Absent--M0050630PJ212-1 | N/A | 0.23 | Jul 11, 2005 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|--------------|--------------|
| Jun 22, 2005 | 1 | RT | Total | Absent--M0050623PE26-2 | N/A | 0.03 | Jun 27, 2005 | |
| Jun 22, 2005 | 1 | RT | Total | Absent--M0050623PE26-1 | N/A | 0.03 | Jun 27, 2005 | |
| Jun 15, 2005 | 1 | RT | Total | Absent--M0050616PC210-2 | N/A | 0.16 | Jun 20, 2005 | |
| Jun 15, 2005 | 1 | RT | Total | Absent--M0050616PC210-1 | N/A | 0.16 | Jun 20, 2005 | |
| Jun 08, 2005 | 1 | RT | Total | Absent--M0050609PF210-2 | N/A | 0.27 | Jun 13, 2005 | |
| Jun 08, 2005 | 1 | RT | Total | Absent--M0050609PF210-1 | N/A | 0.27 | Jun 13, 2005 | |
| Jun 01, 2005 | 1 | RT | Total | Absent--M0050602PG417-2 | N/A | 0.25 | Jun 06, 2005 | |
| Jun 01, 2005 | 1 | RT | Total | Absent--M0050602PG417-1 | N/A | 0.25 | Jun 06, 2005 | |
| May 25, 2005 | 1 | RT | Total | Absent--M0050526PE29-2 | N/A | 0.16 | Jun 06, 2005 | |
| May 25, 2005 | 1 | RT | Total | Absent--M0050526PE29-1 | N/A | 0.16 | Jun 06, 2005 | |
| May 18, 2005 | 1 | RT | Total | Absent--M0050519PG212-2 | N/A | 0.10 | May 23, 2005 | |
| May 18, 2005 | 1 | RT | Total | Absent--M0050519PG212-1 | N/A | 0.10 | May 23, 2005 | |
| May 11, 2005 | 1 | RT | Total | Absent--M0050512PI212-2 | N/A | 0.24 | May 16, 2005 | |
| May 11, 2005 | 1 | RT | Total | Absent--M0050512PI212-1 | N/A | 0.24 | May 16, 2005 | |
| May 04, 2005 | 1 | RT | Total | Absent--M0050505PH48-2 | N/A | 0.03 | May 11, 2005 | |
| May 04, 2005 | 1 | RT | Total | Absent--M0050505PH48-1 | N/A | 0.03 | May 11, 2005 | |
| Apr 27, 2005 | 1 | RT | Total | Absent--M0050428PG214-2 | N/A | 0.17 | May 02, 2005 | |
| Apr 27, 2005 | 1 | RT | Total | Absent--M0050428PG214-1 | N/A | 0.17 | May 02, 2005 | |
| Apr 20, 2005 | 1 | RT | Total | Absent--M0050421PC23-2 | N/A | 0.24 | Apr 28, 2005 | |
| Apr 20, 2005 | 1 | RT | Total | Absent--M0050421PC23-1 | N/A | 0.24 | Apr 28, 2005 | |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Apr 13, 2005 | 1 | RT | Total | Absent--M0050414PG213-2 | | N/A | 0.20 | Apr 18, 2005 |
| Apr 13, 2005 | 1 | RT | Total | Absent--M0050414PG213-1 | | N/A | 0.20 | Apr 18, 2005 |
| Apr 06, 2005 | 1 | RT | Total | Absent--M0050407PA41-4 | | N/A | 0.13 | Apr 11, 2005 |
| Apr 06, 2005 | 1 | RT | Total | Absent--M0050407PA41-3 | | N/A | 0.13 | Apr 11, 2005 |
| Apr 06, 2005 | 1 | RT | Total | Absent--M0050407PA41-2 | | N/A | 0.13 | Apr 11, 2005 |
| Apr 06, 2005 | 1 | RT | Total | Absent--M0050407PA41-1 | | N/A | 0.13 | Apr 11, 2005 |
| Mar 30, 2005 | 1 | RT | Total | Absent--M0050331PC23-2 | | N/A | 0.14 | Apr 04, 2005 |
| Mar 30, 2005 | 1 | RT | Total | Absent--M0050331PC23-1 | | N/A | 0.14 | Apr 04, 2005 |
| Mar 23, 2005 | 1 | RT | Total | Absent--M0050324PA21-2 | | N/A | 0.29 | Mar 28, 2005 |
| Mar 23, 2005 | 1 | RT | Total | Absent--M0050324PA21-1 | | N/A | 0.29 | Mar 28, 2005 |
| Mar 16, 2005 | 1 | RT | Total | Absent--M0050317PC23-2 | | N/A | 0.26 | Mar 21, 2005 |
| Mar 16, 2005 | 1 | RT | Total | Absent--M0050317PC23-1 | | N/A | 0.26 | Mar 21, 2005 |
| Mar 09, 2005 | 1 | RT | Total | Absent--M0050310PC23-2 | | N/A | 0.23 | Mar 14, 2005 |
| Mar 09, 2005 | 1 | RT | Total | Absent--M0050310PC23-1 | | N/A | 0.23 | Mar 14, 2005 |
| Mar 02, 2005 | 1 | RT | Total | Absent--M0050303PD44-2 | | N/A | 0.22 | Mar 09, 2005 |
| Mar 02, 2005 | 1 | RT | Total | Absent--M0050303PD44-1 | | N/A | 0.22 | Mar 09, 2005 |
| Feb 23, 2005 | 1 | RT | Total | Absent--M0050224PE26-2 | | N/A | 0.30 | Mar 02, 2005 |
| Feb 23, 2005 | 1 | RT | Total | Absent--M0050224PE26-1 | | N/A | 0.30 | Mar 02, 2005 |
| Feb 16, 2005 | 1 | RT | Total | Absent--M0050217PE26-2 | | N/A | 0.23 | Feb 22, 2005 |
| Feb 16, 2005 | 1 | RT | Total | Absent--M0050217PE26-1 | | N/A | 0.23 | Feb 22, 2005 |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Feb 09, 2005 | 1 | RT | Total | Absent--M0050210PF26-2 | | N/A | 0.18 | Feb 14, 2005 |
| Feb 09, 2005 | 1 | RT | Total | Absent--M0050210PF26-1 | | N/A | 0.18 | Feb 14, 2005 |
| Feb 02, 2005 | 1 | RT | Total | Absent--M0050203PH48-2 | | N/A | 0.26 | Feb 07, 2005 |
| Feb 02, 2005 | 1 | RT | Total | Absent--M0050203PH48-1 | | N/A | 0.26 | Feb 07, 2005 |
| Jan 26, 2005 | 1 | RT | Total | Absent--M0050127PD24-2 | | N/A | 0.09 | Jan 31, 2005 |
| Jan 26, 2005 | 1 | RT | Total | Absent--M0050127PD24-1 | | N/A | 0.09 | Jan 31, 2005 |
| Jan 19, 2005 | 1 | RT | Total | Absent--M0050120PI210-2 | | N/A | 0.29 | Jan 24, 2005 |
| Jan 19, 2005 | 1 | RT | Total | Absent--M0050120PI210-1 | | N/A | 0.29 | Jan 24, 2005 |
| Jan 12, 2005 | 1 | RT | Total | Absent--M0050113PE28-2 | | N/A | 0.24 | Jan 18, 2005 |
| Jan 12, 2005 | 1 | RT | Total | Absent--M0050113PE28-1 | | N/A | 0.24 | Jan 18, 2005 |
| Jan 05, 2005 | 1 | RT | Total | Absent--M0050106PE28-2 | | N/A | 0.12 | Jan 10, 2005 |
| Jan 05, 2005 | 1 | RT | Total | Absent--M0050106PE28-1 | | N/A | 0.12 | Jan 10, 2005 |
| Dec 29, 2004 | 1 | RT | Total | Absent--M0041230PA21-2 | | N/A | 0.26 | Jan 05, 2005 |
| Dec 29, 2004 | 1 | RT | Total | Absent--M0041230PA21-1 | | N/A | 0.26 | Jan 05, 2005 |
| Dec 20, 2004 | 1 | RT | Total | Absent--M0041221PD24-2 | | N/A | 0.20 | Dec 28, 2004 |
| Dec 20, 2004 | 1 | RT | Total | Absent--M0041221PD24-1 | | N/A | 0.20 | Dec 28, 2004 |

| | | | | | | | |
|--------------|---|----|-------|-------------------------|-----|------|--------------|
| Dec 15, 2004 | 1 | RT | Total | Absent--M0041216PC24-2 | N/A | 0.15 | Dec 20, 2004 |
| Dec 15, 2004 | 1 | RT | Total | Absent--M0041216PC24-1 | N/A | 0.15 | Dec 20, 2004 |
| Dec 08, 2004 | 1 | RT | Total | Absent--M0041209PH212-2 | N/A | 0.10 | Dec 13, 2004 |
| Dec 08, 2004 | 1 | RT | Total | Absent--M0041209PH212-1 | N/A | 0.10 | Dec 13, 2004 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Dec 01, 2004 | 1 | RT | Total | Absent--M0041202PB42-2 | | N/A | 0.19 | Dec 13, 2004 |
| Dec 01, 2004 | 1 | RT | Total | Absent--M0041202PB42-1 | | N/A | 0.19 | Dec 13, 2004 |
| Nov 22, 2004 | 1 | RT | Total | Absent--M0041123PF36-3 | | N/A | 0.17 | Dec 01, 2004 |
| Nov 22, 2004 | 1 | RT | Total | Absent--M0041123PF36-2 | | N/A | 0.17 | Dec 01, 2004 |
| Nov 22, 2004 | 1 | RT | Total | Absent--M0041123PF36-1 | | N/A | 0.17 | Dec 01, 2004 |
| Nov 17, 2004 | 1 | RT | Total | Absent--M0041118PD37-3 | | N/A | 0.25 | Nov 24, 2004 |
| Nov 17, 2004 | 1 | RT | Total | Absent--M0041118PD37-2 | | N/A | 0.25 | Nov 24, 2004 |
| Nov 17, 2004 | 1 | RT | Total | Absent--M0041118PD37-1 | | N/A | 0.25 | Nov 24, 2004 |
| Nov 03, 2004 | 1 | RT | Total | Absent--M0041104PM414-2 | | N/A | 0.12 | Nov 10, 2004 |
| Nov 03, 2004 | 1 | RT | Total | Absent--M0041104PM414-1 | | N/A | 0.12 | Nov 10, 2004 |
| Oct 27, 2004 | 1 | RT | Total | Absent--M0041028PF26-2 | | N/A | 0.29 | Nov 03, 2004 |
| Oct 27, 2004 | 1 | RT | Total | Absent--M0041028PF26-1 | | N/A | 0.29 | Nov 03, 2004 |
| Oct 20, 2004 | 1 | RT | Total | Absent--M0041021PF26-2 | | N/A | 0.08 | Nov 03, 2004 |
| Oct 20, 2004 | 1 | RT | Total | Absent--M0041021PF26-1 | | N/A | 0.08 | Nov 03, 2004 |
| Oct 13, 2004 | 1 | RT | Total | Absent--M0041014PE27-2 | | N/A | 0.26 | Oct 18, 2004 |
| Oct 13, 2004 | 1 | RT | Total | Absent--M0041014PE27-1 | | N/A | 0.26 | Oct 18, 2004 |
| Oct 06, 2004 | 1 | RT | Total | Absent--M0041007PE210-2 | | N/A | 0.12 | Oct 12, 2004 |
| Oct 06, 2004 | 1 | RT | Total | Absent--M0041007PE210-1 | | N/A | 0.12 | Oct 12, 2004 |
| Sep 22, 2004 | 1 | RT | Total | Absent--M0040923PH212-2 | | N/A | 0.21 | Oct 04, 2004 |
| Sep 22, 2004 | 1 | RT | Total | Absent--M0040923PH212-1 | | N/A | 0.21 | Oct 04, 2004 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Sep 15, 2004 | 1 | RT | Total | Absent--M0040916PD26-2 | | N/A | 0.17 | Oct 04, 2004 |
| Sep 15, 2004 | 1 | RT | Total | Absent--M0040916PD26-1 | | N/A | 0.17 | Oct 04, 2004 |
| Sep 08, 2004 | 1 | RT | Total | Absent--M0040909PK228-2 | | N/A | 0.07 | Sep 13, 2004 |
| Sep 08, 2004 | 1 | RT | Total | Absent--M0040909PK228-1 | | N/A | 0.07 | Sep 13, 2004 |
| Sep 01, 2004 | 1 | RT | Total | Absent--M0040902PH215-2 | | N/A | 0.20 | Sep 07, 2004 |
| Sep 01, 2004 | 1 | RT | Total | Absent--M0040902PH215-1 | | N/A | 0.20 | Sep 07, 2004 |
| Aug 25, 2004 | 1 | RT | Total | Absent--M0040826PG210-2 | | N/A | 0.19 | Aug 30, 2004 |
| Aug 25, 2004 | 1 | RT | Total | Absent--M0040826PG210-1 | | N/A | 0.19 | Aug 30, 2004 |
| Aug 18, 2004 | 1 | RT | Total | Absent--M0040819PF46-2 | | N/A | 0.16 | Aug 23, 2004 |
| Aug 18, 2004 | 1 | RT | Total | Absent--M0040819PF46-1 | | N/A | 0.16 | Aug 23, 2004 |
| Aug 11, 2004 | 1 | RT | Total | Absent--M0040812PH211-2 | | N/A | 0.34 | Aug 16, 2004 |
| Aug 11, 2004 | 1 | RT | Total | Absent--M0040812PH211-1 | | N/A | 0.34 | Aug 16, 2004 |

| | | | | | | | |
|--------------|---|----|-------|-------------------------|-----|------|--------------|
| Aug 04, 2004 | 1 | RT | Total | Absent--M0040805PD26-2 | N/A | 0.22 | Aug 11, 2004 |
| Aug 04, 2004 | 1 | RT | Total | Absent--M0040805PD26-1 | N/A | 0.22 | Aug 11, 2004 |
| Jul 28, 2004 | 1 | RT | Total | Absent--M0040729PD24-2 | N/A | 0.23 | Aug 02, 2004 |
| Jul 28, 2004 | 1 | RT | Total | Absent--M0040729PD24-1 | N/A | 0.23 | Aug 02, 2004 |
| Jul 21, 2004 | 1 | RT | Total | Absent--M0040722PG27-2 | N/A | 0.19 | Aug 02, 2004 |
| Jul 21, 2004 | 1 | RT | Total | Absent--M0040722PG27-1 | N/A | 0.19 | Aug 02, 2004 |
| Jul 14, 2004 | 1 | RT | Total | Absent--M0040715PK216-2 | N/A | 0.34 | Jul 29, 2004 |
| Jul 14, 2004 | 1 | RT | Total | Absent--M0040715PK216-1 | N/A | 0.34 | Jul 29, 2004 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Jul 08, 2004 | 1 | RT | Total | Absent--M0040709PC24-2 | | N/A | 0.25 | Jul 19, 2004 |
| Jul 08, 2004 | 1 | RT | Total | Absent--M0040709PC24-1 | | N/A | 0.25 | Jul 19, 2004 |
| Jun 23, 2004 | 1 | RT | Total | Absent--M0040624PF27-2 | | N/A | | Jun 28, 2004 |
| Jun 23, 2004 | 1 | RT | Total | Absent--M0040624PF27-1 | | N/A | | Jun 28, 2004 |
| Jun 16, 2004 | 1 | RT | Total | Absent--M0040617PD25-2 | | N/A | | Jun 21, 2004 |
| Jun 16, 2004 | 1 | RT | Total | Absent--M0040617PD25-1 | | N/A | | Jun 21, 2004 |
| Jun 09, 2004 | 1 | RT | Total | Absent--M0040610PD24-2 | | N/A | | Jun 17, 2004 |
| Jun 09, 2004 | 1 | RT | Total | Absent--M0040610PD24-1 | | N/A | | Jun 17, 2004 |
| Jun 02, 2004 | 1 | RT | Total | Absent--M004603PH312-2 | | N/A | | Jun 07, 2004 |
| Jun 02, 2004 | 1 | RT | Total | Absent--M004603PH312-1 | | N/A | | Jun 07, 2004 |
| May 26, 2004 | 1 | RT | Total | Absent--M0040527PK212-2 | | N/A | | Jun 02, 2004 |
| May 26, 2004 | 1 | RT | Total | Absent--M0040527PK212-1 | | N/A | | Jun 02, 2004 |
| May 19, 2004 | 1 | RT | Total | Absent--M0040520PG213-2 | | N/A | | May 25, 2004 |
| May 19, 2004 | 1 | RT | Total | Absent--M0040520PG213-1 | | N/A | | May 25, 2004 |
| May 12, 2004 | 1 | RT | Total | Absent--M0040513PE25-2 | | N/A | | May 25, 2004 |
| May 12, 2004 | 1 | RT | Total | Absent--M0040513PE25-1 | | N/A | | May 25, 2004 |
| May 05, 2004 | 1 | RT | Total | Absent--M0040506PD24-2 | | N/A | | May 10, 2004 |
| May 05, 2004 | 1 | RT | Total | Absent--M0040506PD24-1 | | N/A | | May 10, 2004 |
| Apr 28, 2004 | 1 | RT | Total | Absent--M0040429PB22-2 | | N/A | | May 04, 2004 |
| Apr 28, 2004 | 1 | RT | Total | Absent--M0040429PB22-1 | | N/A | | May 04, 2004 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Apr 21, 2004 | 1 | RT | Total | Absent--M0040422PE35-2 | | N/A | | Apr 28, 2004 |
| Apr 21, 2004 | 1 | RT | Total | Absent--M0040422PE35-1 | | N/A | | Apr 28, 2004 |
| Apr 14, 2004 | 1 | RT | Total | Absent--M0040415PG213-2 | | N/A | | Apr 19, 2004 |
| Apr 14, 2004 | 1 | RT | Total | Absent--M0040415PG213-1 | | N/A | | Apr 19, 2004 |
| Apr 08, 2004 | 1 | RT | Total | Absent--M0040409PC26-2 | | N/A | | Apr 19, 2004 |
| Apr 08, 2004 | 1 | RT | Total | Absent--M0040409PC26-1 | | N/A | | Apr 19, 2004 |
| Mar 24, 2004 | 1 | RT | Total | Absent--M0040325PD46-2 | | N/A | | Mar 29, 2004 |
| Mar 24, 2004 | 1 | RT | Total | Absent--M0040325PD46-1 | | N/A | | Mar 29, 2004 |

| Mar 17, 2004 | 1 | RT | Total | Absent--M0040318PF212-2 | N/A | Mar 22, 2004 | | |
|--------------|-----------|---------------|-------|-------------------------|---------------------|--------------|-------------|--------------|
| Mar 17, 2004 | 1 | RT | Total | Absent--M0040318PF212-1 | N/A | Mar 22, 2004 | | |
| Mar 10, 2004 | 1 | RT | Total | Absent--M0040311PF26-2 | N/A | Mar 15, 2004 | | |
| Mar 10, 2004 | 1 | RT | Total | Absent--M0040311PF26-1 | N/A | Mar 15, 2004 | | |
| Mar 03, 2004 | 1 | RT | Total | Absent--M0040304PC27-2 | N/A | Mar 08, 2004 | | |
| Mar 03, 2004 | 1 | RT | Total | Absent--M0040304PC27-1 | N/A | Mar 08, 2004 | | |
| Feb 25, 2004 | 1 | RT | Total | Absent--M0040226PC23-2 | N/A | Mar 01, 2004 | | |
| Feb 25, 2004 | 1 | RT | Total | Absent--M0040226PC23-1 | N/A | Mar 01, 2004 | | |
| Feb 18, 2004 | 1 | RT | Total | Absent--M0040219PG29-2 | N/A | Feb 25, 2004 | | |
| Feb 18, 2004 | 1 | RT | Total | Absent--M0040219PG29-1 | N/A | Feb 25, 2004 | | |
| Feb 11, 2004 | 1 | RT | Total | Absent--M0040212PD24-2 | N/A | Feb 17, 2004 | | |
| Feb 11, 2004 | 1 | RT | Total | Absent--M0040212PD24-1 | N/A | Feb 17, 2004 | | |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Feb 04, 2004 | 1 | RT | Total | Absent--M0040205PD24-2 | N/A | Feb 09, 2004 | | |
| Feb 04, 2004 | 1 | RT | Total | Absent--M0040205PD24-1 | N/A | Feb 09, 2004 | | |
| Jan 28, 2004 | 1 | RT | Total | Absent--M0040129PD24-2 | N/A | Feb 04, 2004 | | |
| Jan 28, 2004 | 1 | RT | Total | Absent--M0040129PD24-1 | N/A | Feb 04, 2004 | | |
| Jan 21, 2004 | 1 | RT | Total | Absent--M0040122PC23-2 | N/A | Jan 26, 2004 | | |
| Jan 21, 2004 | 1 | RT | Total | Absent--M0040122PC23-1 | N/A | Jan 26, 2004 | | |
| Jan 14, 2004 | 1 | RT | Total | Absent--M0040115PF26-2 | N/A | Jan 20, 2004 | | |
| Jan 14, 2004 | 1 | RT | Total | Absent--M0040115PF26-1 | N/A | Jan 20, 2004 | | |
| Jan 07, 2004 | 1 | RT | Total | Absent--M0040108PA21-2 | N/A | Jan 12, 2004 | | |
| Jan 07, 2004 | 1 | RT | Total | Absent--M0040108PA21-1 | N/A | Jan 12, 2004 | | |
| Dec 17, 2003 | 1 | RT | Total | Absent--M0031218PD24-2 | N/A | Dec 22, 2003 | | |
| Dec 17, 2003 | 1 | RT | Total | Absent--M0031218PD24-1 | N/A | Dec 22, 2003 | | |
| Dec 05, 2003 | 1 | RT | Total | Absent--66001-2 | N/A | Dec 15, 2003 | | |
| Dec 05, 2003 | 1 | RT | Total | Absent--66001-1 | N/A | Dec 15, 2003 | | |
| Dec 03, 2003 | 1 | RT | Total | Absent--M0031204PG28-2 | N/A | Dec 10, 2003 | | |
| Dec 03, 2003 | 1 | RT | Total | Absent--M0031204PG28-1 | N/A | Dec 10, 2003 | | |
| Dec 01, 2003 | 1 | RT | Total | Absent--M0031211PF211-2 | N/A | Dec 15, 2003 | | |
| Dec 01, 2003 | 1 | RT | Total | Absent--M0031211PF211-1 | N/A | Dec 15, 2003 | | |
| Nov 24, 2003 | 1 | RT | Total | Absent--M0031125PI29-2 | N/A | Nov 28, 2003 | | |
| Nov 24, 2003 | 1 | RT | Total | Absent--M0031125PI29-1 | N/A | Nov 28, 2003 | | |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Nov 19, 2003 | 1 | RT | Total | Absent--M0031120PD24-2 | N/A | Nov 26, 2003 | | |
| Nov 19, 2003 | 1 | RT | Total | Absent--M0031120PD24-1 | N/A | Nov 26, 2003 | | |
| Nov 12, 2003 | 1 | RT | Total | Absent--M0031113PI29-2 | N/A | Nov 17, 2003 | | |
| Nov 12, 2003 | 1 | RT | Total | Absent--M0031113PI29-1 | N/A | Nov 17, 2003 | | |

| | | | | | | |
|--------------|---|----|-------|-------------------------|-----------------|--------------|
| Nov 05, 2003 | 1 | RT | Total | Absent--M0031106PH216-2 | N/A | Nov 10, 2003 |
| Nov 05, 2003 | 1 | RT | Total | Absent--M0031106PH216-1 | N/A | Nov 10, 2003 |
| Oct 29, 2003 | 1 | RT | Total | Absent--M0031030PF26-2 | 321 S ELIZABETH | Nov 06, 2003 |
| Oct 29, 2003 | 1 | RT | Total | Absent--M0031030PF26-1 | 321 S ELIZABETH | Nov 06, 2003 |
| Oct 22, 2003 | 1 | RT | Total | Absent--M0031023PG212-2 | N/A | Oct 29, 2003 |
| Oct 22, 2003 | 1 | RT | Total | Absent--M0031023PG212-1 | N/A | Oct 29, 2003 |
| Oct 15, 2003 | 1 | RT | Total | Absent--M0031016PG28-2 | N/A | Oct 20, 2003 |
| Oct 15, 2003 | 1 | RT | Total | Absent--M0031016PG28-1 | N/A | Oct 20, 2003 |
| Oct 08, 2003 | 1 | RT | Total | Absent--M0031009PJ211-2 | N/A | Oct 14, 2003 |
| Oct 08, 2003 | 1 | RT | Total | Absent--M0031009PJ211-1 | N/A | Oct 14, 2003 |
| Oct 01, 2003 | 1 | RT | Total | Absent--M0031002PD24-2 | N/A | Oct 08, 2003 |
| Oct 01, 2003 | 1 | RT | Total | Absent--M0031002PD24-1 | N/A | Oct 08, 2003 |
| Sep 24, 2003 | 1 | RT | Total | Absent--M0030925PI216-2 | N/A | Oct 03, 2003 |
| Sep 24, 2003 | 1 | RT | Total | Absent--M0030925PI216-1 | N/A | Oct 03, 2003 |
| Sep 17, 2003 | 1 | RT | Total | Absent--M0030918PJ217-2 | N/A | Sep 22, 2003 |
| Sep 17, 2003 | 1 | RT | Total | Absent--M0030918PJ217-1 | N/A | Sep 22, 2003 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Sep 10, 2003 | 1 | RT | Total | Absent--M0030911PG212-2 | N/A | | | Sep 22, 2003 |
| Sep 10, 2003 | 1 | RT | Total | Absent--M0030911PG212-1 | N/A | | | Sep 22, 2003 |
| Sep 03, 2003 | 1 | RT | Total | Absent--M0030904PG211-2 | N/A | | | Sep 15, 2003 |
| Sep 03, 2003 | 1 | RT | Total | Absent--M0030904PG211-1 | N/A | | | Sep 15, 2003 |
| Aug 27, 2003 | 1 | RT | Total | Absent--M0030828PF211-2 | N/A | | | Sep 04, 2003 |
| Aug 27, 2003 | 1 | RT | Total | Absent--M0030828PF211-1 | N/A | | | Sep 04, 2003 |
| Aug 20, 2003 | 1 | RT | Total | Absent--M0030821PG27 | N/A | | | Aug 27, 2003 |
| Aug 20, 2003 | 1 | RT | Total | Absent--M0030821PG28 | N/A | | | Aug 27, 2003 |
| Aug 13, 2003 | 1 | RT | Total | Absent--M0030814PH210-2 | N/A | | | Aug 18, 2003 |
| Aug 13, 2003 | 1 | RT | Total | Absent--M0030814PH210-1 | N/A | | | Aug 18, 2003 |
| Aug 06, 2003 | 1 | RT | Total | Absent--M0030807PG211-2 | N/A | | | Aug 11, 2003 |
| Aug 06, 2003 | 1 | RT | Total | Absent--M0030807PG211-1 | N/A | | | Aug 11, 2003 |
| Jul 23, 2003 | 1 | RT | Total | Absent--M0030724PC23-2 | N/A | | | Jul 30, 2003 |
| Jul 23, 2003 | 1 | RT | Total | Absent--M0030724PC23-1 | N/A | | | Jul 30, 2003 |
| Jul 16, 2003 | 1 | RT | Total | Absent--M030717PF27-2 | N/A | | | Jul 23, 2003 |
| Jul 16, 2003 | 1 | RT | Total | Absent--M030717PF27-1 | N/A | | | Jul 23, 2003 |
| Jul 09, 2003 | 1 | RT | Total | Absent--M0030710PF26-2 | N/A | | | Jul 16, 2003 |
| Jul 09, 2003 | 1 | RT | Total | Absent--M0030710PF26-1 | N/A | | | Jul 16, 2003 |
| Jul 02, 2003 | 1 | RT | Total | Absent--M0030703PG210-2 | N/A | | | Jul 16, 2003 |
| Jul 02, 2003 | 1 | RT | Total | Absent--M0030703PG210-1 | N/A | | | Jul 16, 2003 |

| | | | | | | |
|--------------|---|----|-------|-------------------------|-----|--------------|
| Jun 25, 2003 | 1 | RT | Total | Absent--M0030626PE28 | N/A | Jul 08, 2003 |
| Jun 25, 2003 | 1 | RT | Total | Absent--M0030626PE27 | N/A | Jul 23, 2003 |
| Jun 18, 2003 | 1 | RT | Total | Absent--M0030619PF210-2 | N/A | Jul 08, 2003 |
| Jun 18, 2003 | 1 | RT | Total | Absent--M0030619PF210-1 | N/A | Jul 08, 2003 |
| Jun 11, 2003 | 1 | RT | Total | Absent--M0030612PE25-2 | N/A | Jun 23, 2003 |
| Jun 11, 2003 | 1 | RT | Total | Absent--M0030612PE25-1 | N/A | Jun 23, 2003 |
| Jun 04, 2003 | 1 | RT | Total | Absent--M0030605PH29-2 | N/A | Jun 09, 2003 |
| Jun 04, 2003 | 1 | RT | Total | Absent--M0030605PH29-1 | N/A | Jun 09, 2003 |
| May 28, 2003 | 1 | RT | Total | Absent--M0030529PF28-2 | N/A | Jun 02, 2003 |
| May 28, 2003 | 1 | RT | Total | Absent--M0030529PF28-1 | N/A | Jun 02, 2003 |
| May 21, 2003 | 1 | RT | Total | Absent--M0030522PE26-2 | N/A | May 27, 2003 |
| May 21, 2003 | 1 | RT | Total | Absent--M0030522PE26-1 | N/A | May 27, 2003 |
| May 15, 2003 | 1 | RT | Total | Absent--M0030516PE27-2 | N/A | May 27, 2003 |
| May 15, 2003 | 1 | RT | Total | Absent--M0030516PE27-1 | N/A | May 27, 2003 |
| May 07, 2003 | 1 | RT | Total | Absent--M0030508PE210-2 | N/A | May 12, 2003 |
| May 07, 2003 | 1 | RT | Total | Absent--M0030508PE210-1 | N/A | May 12, 2003 |
| Apr 23, 2003 | 1 | RT | Total | Absent--M0030424PE25-2 | N/A | May 05, 2003 |
| Apr 23, 2003 | 1 | RT | Total | Absent--M0030424PE25-1 | N/A | May 05, 2003 |
| Apr 16, 2003 | 1 | RT | Total | Absent--M0030417PH29-2 | N/A | Apr 21, 2003 |
| Apr 16, 2003 | 1 | RT | Total | Absent--M0030417PH29-1 | N/A | Apr 21, 2003 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Apr 10, 2003 | 1 | RT | Total | Absent--M0030411PE26-2 | | N/A | | Apr 21, 2003 |
| Apr 10, 2003 | 1 | RT | Total | Absent--M0030411PE26-1 | | N/A | | Apr 21, 2003 |
| Apr 02, 2003 | 1 | RT | Total | Absent--M0030403PB23-2 | | N/A | | Apr 07, 2003 |
| Apr 02, 2003 | 1 | RT | Total | Absent--M0030403PB23-1 | | N/A | | Apr 07, 2003 |
| Mar 26, 2003 | 1 | RT | Total | Absent--M0030327PA21-2 | | N/A | | Apr 07, 2003 |
| Mar 26, 2003 | 1 | RT | Total | Absent--M0030327PA21-1 | | N/A | | Apr 07, 2003 |
| Mar 19, 2003 | 1 | RT | Total | Absent--M0030320PJ212-2 | | N/A | | Mar 24, 2003 |
| Mar 19, 2003 | 1 | RT | Total | Absent--M0030320PJ212-1 | | N/A | | Mar 24, 2003 |
| Mar 12, 2003 | 1 | RT | Total | Absent--M0030314PI28-2 | | N/A | | Mar 24, 2003 |
| Mar 12, 2003 | 1 | RT | Total | Absent--M0030314PI28-1 | | N/A | | Mar 24, 2003 |
| Mar 05, 2003 | 1 | RT | Total | Absent--M0030306PH210-2 | | N/A | | Mar 11, 2003 |
| Mar 05, 2003 | 1 | RT | Total | Absent--M0030306PH210-1 | | N/A | | Mar 11, 2003 |
| Feb 26, 2003 | 1 | RT | Total | Absent--M0030227PB22-2 | | N/A | | Mar 03, 2003 |
| Feb 26, 2003 | 1 | RT | Total | Absent--M0030227PB22-1 | | N/A | | Mar 03, 2003 |
| Feb 12, 2003 | 1 | RT | Total | Absent--M0030213PG28-2 | | N/A | | Mar 03, 2003 |
| Feb 12, 2003 | 1 | RT | Total | Absent--M0030213PG28-1 | | N/A | | Mar 03, 2003 |
| Feb 05, 2003 | 1 | RT | Total | Absent--M0030206PG29-2 | | N/A | | Feb 12, 2003 |
| Feb 05, 2003 | 1 | RT | Total | Absent--M0030206PG29-1 | | N/A | | Feb 12, 2003 |
| Jan 29, 2003 | 1 | RT | Total | Absent--M0030130PF29-2 | | N/A | | Feb 05, 2003 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|-------------------------|---------------------|-------------|-------------|--------------|
| Jan 29, 2003 | 1 | RT | Total | Absent--M0030130PF29-1 | | N/A | | Feb 05, 2003 |
| Jan 22, 2003 | 1 | RT | Total | Absent--M0030123PK214-2 | | N/A | | Feb 05, 2003 |
| Jan 22, 2003 | 1 | RT | Total | Absent--M0030123PK214-1 | | N/A | | Feb 05, 2003 |
| Jan 15, 2003 | 1 | RT | Total | Absent--M0030116PD26-2 | | N/A | | Jan 27, 2003 |
| Jan 15, 2003 | 1 | RT | Total | Absent--M0030116PD26-1 | | N/A | | Jan 27, 2003 |
| Jan 08, 2003 | 1 | RT | Total | Absent--M0030109PE313-2 | | N/A | | Jan 27, 2003 |
| Jan 08, 2003 | 1 | RT | Total | Absent--M0030109PE313-1 | | N/A | | Jan 27, 2003 |
| Jan 02, 2003 | 1 | RT | Total | Absent--030103PC23-2 | | N/A | | Jan 13, 2003 |
| Jan 02, 2003 | 1 | RT | Total | Absent--030103PC23-1 | | N/A | | Jan 13, 2003 |
| Dec 26, 2002 | 1 | RT | Total | Absent--021227PC25-2 | | N/A | | Jan 02, 2003 |
| Dec 26, 2002 | 1 | RT | Total | Absent--021227PC25-1 | | N/A | | Jan 02, 2003 |
| Dec 19, 2002 | 1 | RT | Total | Absent--M0030220PI210-2 | | N/A | | Mar 03, 2003 |
| Dec 19, 2002 | 1 | RT | Total | Absent--M0030220PI210-1 | | N/A | | Mar 03, 2003 |
| Dec 18, 2002 | 1 | RT | Total | Absent--021219PB22-2 | | N/A | | Jan 02, 2003 |
| Dec 18, 2002 | 1 | RT | Total | Absent--021219PB22-1 | | N/A | | Jan 02, 2003 |
| Dec 11, 2002 | 1 | RT | Total | Absent--021212PF26-2 | | N/A | | Dec 16, 2002 |
| Dec 11, 2002 | 1 | RT | Total | Absent--021212PF26-1 | | N/A | | Dec 16, 2002 |
| Dec 04, 2002 | 1 | RT | Total | Absent--021205PH28-2 | | N/A | | Dec 12, 2002 |
| Dec 04, 2002 | 1 | RT | Total | Absent--021205PH28-1 | | N/A | | Dec 12, 2002 |
| Nov 25, 2002 | 1 | RT | Total | Absent--021126PI29-2 | | N/A | | Dec 04, 2002 |
| Nov 25, 2002 | 1 | RT | Total | Absent--021126PI29-1 | | N/A | | Dec 04, 2002 |
| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
| Nov 20, 2002 | 1 | RT | Total | Absent--21121PG210-2 | | N/A | | Nov 25, 2002 |
| Nov 20, 2002 | 1 | RT | Total | Absent--21121PG210-1 | | N/A | | Nov 25, 2002 |
| Nov 13, 2002 | 1 | RT | Total | Absent--215114PG23-2 | | N/A | | Nov 25, 2002 |
| Nov 13, 2002 | 1 | RT | Total | Absent--215114PG23-1 | | N/A | | Nov 25, 2002 |
| Nov 06, 2002 | 1 | RT | Total | Absent--21107PL224-2 | | N/A | | Nov 18, 2002 |
| Nov 06, 2002 | 1 | RT | Total | Absent--21107PL224-1 | | N/A | | Nov 18, 2002 |
| Oct 30, 2002 | 1 | RT | Total | Absent--021031PF26-2 | | N/A | | Nov 04, 2002 |
| Oct 30, 2002 | 1 | RT | Total | Absent--021031PF26-1 | | N/A | | Nov 04, 2002 |
| Oct 23, 2002 | 1 | RT | Total | Absent--021024PB12 | | N/A | | Oct 30, 2002 |
| Oct 16, 2002 | 1 | RT | Total | Absent--021017PG28-2 | | N/A | | Oct 21, 2002 |
| Oct 16, 2002 | 1 | RT | Total | Absent--021017PG28-1 | | N/A | | Oct 21, 2002 |
| Oct 09, 2002 | 1 | RT | Total | Absent--21010PH211-2 | | N/A | | Oct 21, 2002 |
| Oct 09, 2002 | 1 | RT | Total | Absent--21010PH211-1 | | N/A | | Oct 21, 2002 |
| Oct 02, 2002 | 1 | RT | Total | Absent--21003PG210-2 | | N/A | | Oct 14, 2002 |
| Oct 02, 2002 | 1 | RT | Total | Absent--21003PG210-1 | | N/A | | Oct 14, 2002 |

| | | | | | | |
|--------------|---|----|-------|----------------------|-----|--------------|
| Sep 25, 2002 | 1 | RT | Total | Absent--20926PI210 | N/A | Oct 03, 2002 |
| Sep 25, 2002 | 1 | RT | Total | Absent--20926PI211 | N/A | Oct 03, 2002 |
| Sep 18, 2002 | 1 | RT | Total | Absent--020919PD24-2 | N/A | Sep 25, 2002 |
| Sep 18, 2002 | 1 | RT | Total | Absent--020919PD24-1 | N/A | Sep 25, 2002 |
| Sep 11, 2002 | 1 | RT | Total | Absent--20912PD24-2 | N/A | Sep 18, 2002 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|-------------|--------------|
| Sep 11, 2002 | 1 | RT | Total | Absent--20912PD24-1 | | N/A | | Sep 18, 2002 |
| Sep 04, 2002 | 1 | RT | Total | Absent--20905PF210-2 | | S WALNUT | | Sep 11, 2002 |
| Sep 04, 2002 | 1 | RT | Total | Absent--20905PF210-1 | | S WALNUT | | Sep 11, 2002 |
| Aug 28, 2002 | 1 | RT | Total | Absent--020829PE26-2 | | VINING ST | | Sep 06, 2002 |
| Aug 28, 2002 | 1 | RT | Total | Absent--020829PE26-1 | | VINING ST | | Sep 06, 2002 |
| Aug 21, 2002 | 1 | RT | Total | Absent--20822PH210-2 | | N/A | | Sep 06, 2002 |
| Aug 21, 2002 | 1 | RT | Total | Absent--20822PH210-1 | | N/A | | Sep 06, 2002 |
| Aug 14, 2002 | 1 | RT | Total | Absent--020815PF26-2 | | N/A | | |
| Aug 14, 2002 | 1 | RT | Total | Absent--020815PF26-1 | | N/A | | |
| Aug 07, 2002 | 1 | RT | Total | Absent--20808PM216-2 | | N/A | | |
| Aug 07, 2002 | 1 | RT | Total | Absent--20808PM216-1 | | N/A | | |
| Jul 24, 2002 | 1 | RT | Total | Absent--20725PK211-2 | | N/A | | |
| Jul 24, 2002 | 1 | RT | Total | Absent--20725PK211-1 | | N/A | | |
| Jul 17, 2002 | 1 | RT | Total | Absent--20718PF26-2 | | N/A | | |
| Jul 17, 2002 | 1 | RT | Total | Absent--20718PF26-1 | | N/A | | |
| Jul 10, 2002 | 1 | RT | Total | Absent--20711PH214-2 | | N/A | | |
| Jul 10, 2002 | 1 | RT | Total | Absent--20711PH214-1 | | N/A | | |
| Jul 02, 2002 | 1 | RT | Total | Absent--20703PG27-2 | | N/A | | |
| Jul 02, 2002 | 1 | RT | Total | Absent--20703PG27-1 | | N/A | | |
| Jun 26, 2002 | 1 | RT | Total | Absent--20627PK213-2 | | N/A | | |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|-------------|--------------|
| Jun 26, 2002 | 1 | RT | Total | Absent--20627PK213-1 | | N/A | | |
| Jun 19, 2002 | 1 | RT | Total | Absent--20620PJ210-2 | | N/A | | Jun 26, 2002 |
| Jun 19, 2002 | 1 | RT | Total | Absent--20620PJ210-1 | | N/A | | Jun 26, 2002 |
| Jun 12, 2002 | 1 | RT | Total | Absent--6132PJ216-2 | | N/A | | Jun 17, 2002 |
| Jun 12, 2002 | 1 | RT | Total | Absent--6132PJ216-1 | | N/A | | Jun 17, 2002 |
| Jun 05, 2002 | 1 | RT | Total | Absent--20606PH215-2 | | N/A | | Jun 11, 2002 |
| Jun 05, 2002 | 1 | RT | Total | Absent--20606PH215-1 | | N/A | | Jun 11, 2002 |
| May 29, 2002 | 1 | RT | Total | Absent--20530PI212-2 | | N/A | | Jun 05, 2002 |
| May 29, 2002 | 1 | RT | Total | Absent--20530PI212-1 | | N/A | | Jun 05, 2002 |
| May 22, 2002 | 1 | RT | Total | Absent--20523PI213-2 | | N/A | | May 31, 2002 |
| May 22, 2002 | 1 | RT | Total | Absent--20523PI213-1 | | N/A | | May 31, 2002 |

| | | | | | | |
|--------------|---|----|-------|----------------------|-----|--------------|
| May 15, 2002 | 1 | RT | Total | Absent--20516PJ221-2 | N/A | May 20, 2002 |
| May 15, 2002 | 1 | RT | Total | Absent--20516PJ221-1 | N/A | May 20, 2002 |
| May 15, 2002 | 1 | RT | Total | Absent--42-20516PJ-2 | N/A | May 20, 2002 |
| May 15, 2002 | 1 | RT | Total | Absent--42-20516PJ-1 | N/A | May 20, 2002 |
| May 08, 2002 | 1 | RT | Total | Absent--20509PF29 | N/A | May 13, 2002 |
| May 08, 2002 | 1 | RT | Total | Absent--20509PF28 | N/A | May 13, 2002 |
| May 01, 2002 | 1 | RT | Total | Absent--20502PF28-2 | N/A | May 08, 2002 |
| May 01, 2002 | 1 | RT | Total | Absent--20502PF28-1 | N/A | May 08, 2002 |
| Apr 24, 2002 | 1 | RT | Total | Absent--20425PD24-2 | N/A | Apr 29, 2002 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|-------------|--------------|
| Apr 24, 2002 | 1 | RT | Total | Absent--20425PD24-1 | | N/A | | Apr 29, 2002 |
| Apr 17, 2002 | 1 | RT | Total | Absent--20418P+D25-2 | | N/A | | Apr 24, 2002 |
| Apr 17, 2002 | 1 | RT | Total | Absent--20418P+D25-1 | | N/A | | Apr 24, 2002 |
| Apr 10, 2002 | 1 | RT | Total | Absent--20411PK316-2 | | N/A | | Apr 16, 2002 |
| Apr 10, 2002 | 1 | RT | Total | Absent--20411PK316-1 | | N/A | | Apr 16, 2002 |
| Apr 04, 2002 | 1 | RT | Total | Absent--20405PD26-2 | | N/A | | Apr 15, 2002 |
| Apr 04, 2002 | 1 | RT | Total | Absent--20405PD26-1 | | N/A | | Apr 15, 2002 |
| Mar 27, 2002 | 1 | RT | Total | Absent--20328PG27-2 | | N/A | | Apr 01, 2002 |
| Mar 27, 2002 | 1 | RT | Total | Absent--20328PG27-1 | | N/A | | Apr 01, 2002 |
| Mar 20, 2002 | 1 | RT | Total | Absent--20321PG27-2 | | N/A | | Mar 25, 2002 |
| Mar 20, 2002 | 1 | RT | Total | Absent--20321PG27-1 | | N/A | | Mar 25, 2002 |
| Mar 13, 2002 | 1 | RT | Total | Absent--20314PF210-2 | | N/A | | Mar 18, 2002 |
| Mar 13, 2002 | 1 | RT | Total | Absent--20314PF210-1 | | N/A | | Mar 18, 2002 |
| Mar 06, 2002 | 1 | RT | Total | Absent--20307PE23-2 | | N/A | | Mar 11, 2002 |
| Mar 06, 2002 | 1 | RT | Total | Absent--20307PE23-1 | | N/A | | Mar 11, 2002 |
| Feb 27, 2002 | 1 | RT | Total | Absent--020228PE26-2 | | N/A | | Mar 05, 2002 |
| Feb 27, 2002 | 1 | RT | Total | Absent--020228PE26-1 | | N/A | | Mar 05, 2002 |
| Feb 20, 2002 | 1 | RT | Total | Absent--20221PG210-2 | | N/A | | Feb 25, 2002 |
| Feb 20, 2002 | 1 | RT | Total | Absent--20221PG210-1 | | N/A | | Feb 25, 2002 |
| Feb 13, 2002 | 1 | RT | Total | Absent--20214PE28-2 | | N/A | | Feb 19, 2002 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|-------------|--------------|
| Feb 13, 2002 | 1 | RT | Total | Absent--20214PE28-1 | | N/A | | Feb 19, 2002 |
| Feb 06, 2002 | 1 | RT | Total | Absent--20207PD26-2 | | N/A | | Feb 11, 2002 |
| Feb 06, 2002 | 1 | RT | Total | Absent--20207PD26-1 | | N/A | | Feb 11, 2002 |
| Jan 30, 2002 | 1 | RT | Total | Absent--20131PE46-2 | | N/A | | Feb 04, 2002 |
| Jan 30, 2002 | 1 | RT | Total | Absent--20131PE46-1 | | N/A | | Feb 04, 2002 |
| Jan 23, 2002 | 1 | RT | Total | Absent--020124PB22-2 | | N/A | | Jan 28, 2002 |
| Jan 23, 2002 | 1 | RT | Total | Absent--020124PB22-1 | | N/A | | Jan 28, 2002 |

| | | | | | | |
|--------------|---|----|-------|----------------------|-----|--------------|
| Jan 16, 2002 | 1 | RT | Total | Absent--20117PD27-2 | N/A | Jan 22, 2002 |
| Jan 16, 2002 | 1 | RT | Total | Absent--20117PD27-1 | N/A | Jan 22, 2002 |
| Jan 09, 2002 | 1 | RT | Total | Absent--20110PD24-2 | N/A | Jan 14, 2002 |
| Jan 09, 2002 | 1 | RT | Total | Absent--20110PD24-1 | N/A | Jan 14, 2002 |
| Jan 02, 2002 | 1 | RT | Total | Absent--20103PL216-2 | N/A | Jan 07, 2002 |
| Jan 02, 2002 | 1 | RT | Total | Absent--20103PL216-1 | N/A | Jan 07, 2002 |
| Dec 26, 2001 | 1 | RT | Total | Absent--11227PF27-2 | N/A | Jan 07, 2002 |
| Dec 26, 2001 | 1 | RT | Total | Absent--11227PF27-1 | N/A | Jan 07, 2002 |
| Dec 19, 2001 | 1 | RT | Total | Absent--11220PE26-2 | N/A | Dec 27, 2001 |
| Dec 19, 2001 | 1 | RT | Total | Absent--11220PE26-1 | N/A | Dec 27, 2001 |
| Dec 12, 2001 | 1 | RT | Total | Absent--11213PE218-2 | N/A | Dec 18, 2001 |
| Dec 12, 2001 | 1 | RT | Total | Absent--11213PE218-1 | N/A | Dec 18, 2001 |
| Dec 05, 2001 | 1 | RT | Total | Absent--11206PO210-2 | N/A | Dec 10, 2001 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|-------------|--------------|
| Dec 05, 2001 | 1 | RT | Total | Absent--11206PO210-1 | | N/A | | Dec 10, 2001 |
| Nov 29, 2001 | 1 | RT | Total | Absent--11130C23-2 | | N/A | | Dec 10, 2001 |
| Nov 29, 2001 | 1 | RT | Total | Absent--11130C23-1 | | N/A | | Dec 10, 2001 |
| Nov 19, 2001 | 1 | RT | Total | Absent--11120PI213-2 | | N/A | | Dec 03, 2001 |
| Nov 19, 2001 | 1 | RT | Total | Absent--11120PI213-1 | | N/A | | Dec 03, 2001 |
| Nov 15, 2001 | 1 | RT | Total | Absent--11116PC23-2 | | N/A | | Nov 23, 2001 |
| Nov 15, 2001 | 1 | RT | Total | Absent--11116PC23-1 | | N/A | | Nov 23, 2001 |
| Nov 07, 2001 | 1 | RT | Total | Absent--11108PF26-2 | | N/A | | Nov 16, 2001 |
| Nov 07, 2001 | 1 | RT | Total | Absent--11108PF26-1 | | N/A | | Nov 16, 2001 |
| Oct 31, 2001 | 1 | RT | Total | Absent--11101PF26-2 | | N/A | | Nov 07, 2001 |
| Oct 31, 2001 | 1 | RT | Total | Absent--11101PF26-1 | | N/A | | Nov 07, 2001 |
| Oct 24, 2001 | 1 | RT | Total | Absent--11025PF26-2 | | N/A | | Oct 30, 2001 |
| Oct 24, 2001 | 1 | RT | Total | Absent--11025PF26-1 | | N/A | | Oct 30, 2001 |
| Oct 17, 2001 | 1 | RT | Total | Absent--11018PK219-2 | | N/A | | Oct 22, 2001 |
| Oct 17, 2001 | 1 | RT | Total | Absent--11018PK219-1 | | N/A | | Oct 22, 2001 |
| Oct 10, 2001 | 1 | RT | Total | Absent--11011PG213-2 | | N/A | | Oct 15, 2001 |
| Oct 10, 2001 | 1 | RT | Total | Absent--11011PG213-1 | | N/A | | Oct 15, 2001 |
| Oct 04, 2001 | 1 | RT | Total | Absent--11004PF210-2 | | N/A | | Oct 09, 2001 |
| Oct 04, 2001 | 1 | RT | Total | Absent--11004PF210-1 | | N/A | | Oct 09, 2001 |
| Sep 26, 2001 | 1 | RT | Total | Absent--10927PI29-2 | | N/A | | Oct 01, 2001 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | CI Residual | Receive Date |
|--------------|-----------|---------------|-------|---------------------|---------------------|-------------|-------------|--------------|
| Sep 26, 2001 | 1 | RT | Total | Absent--10927PI29-1 | | N/A | | Oct 01, 2001 |
| Sep 19, 2001 | 1 | RT | Total | Absent--10920PD25-2 | | N/A | | Sep 24, 2001 |
| Sep 19, 2001 | 1 | RT | Total | Absent--10920PD25-1 | | N/A | | Sep 24, 2001 |

| | | | | | | |
|--------------|---|----|-------|----------------------|-----|--------------|
| Sep 12, 2001 | 1 | RT | Total | Absent--10913PG28-2 | N/A | Sep 19, 2001 |
| Sep 12, 2001 | 1 | RT | Total | Absent--10913PG28-1 | N/A | Sep 19, 2001 |
| Sep 05, 2001 | 1 | RT | Total | Absent--10906PH211-2 | N/A | Sep 13, 2001 |
| Sep 05, 2001 | 1 | RT | Total | Absent--10906PH211-1 | N/A | Sep 13, 2001 |
| Aug 22, 2001 | 1 | RT | Total | Absent--10823PK217-2 | N/A | Aug 27, 2001 |
| Aug 22, 2001 | 1 | RT | Total | Absent--10823PK217-1 | N/A | Aug 27, 2001 |
| Aug 15, 2001 | 1 | RT | Total | Absent--10816PI317-2 | N/A | Aug 21, 2001 |
| Aug 15, 2001 | 1 | RT | Total | Absent--10816PI317-1 | N/A | Aug 21, 2001 |
| Aug 08, 2001 | 1 | RT | Total | Absent--10809PM220-2 | N/A | Aug 14, 2001 |
| Aug 08, 2001 | 1 | RT | Total | Absent--10809PM220-1 | N/A | Aug 14, 2001 |
| Aug 01, 2001 | 1 | RT | Total | Absent--10802PI217-2 | N/A | Aug 06, 2001 |
| Aug 01, 2001 | 1 | RT | Total | Absent--10802PI217-1 | N/A | Aug 06, 2001 |
| Jul 25, 2001 | 1 | RT | Total | Absent--10726PG28-2 | N/A | Aug 01, 2001 |
| Jul 25, 2001 | 1 | RT | Total | Absent--10726PG28-1 | N/A | Aug 01, 2001 |
| Jul 18, 2001 | 1 | RT | Total | Absent--10719PJ214-2 | N/A | Jul 23, 2001 |
| Jul 18, 2001 | 1 | RT | Total | Absent--10719PJ214-1 | N/A | Jul 23, 2001 |
| Jul 12, 2001 | 1 | RT | Total | Absent--10713F28-2 | N/A | Jul 23, 2001 |

| Sample Date | # Samples | Coliform Type | Type | Results--ID | Repeat of Sample ID | Sample Site | Cl Residual | Receive Date |
|--------------|-----------|---------------|-------|----------------------|---------------------|-------------|-------------|--------------|
| Jul 12, 2001 | 1 | RT | Total | Absent--10713F28-1 | | N/A | | Jul 23, 2001 |
| Jul 05, 2001 | 1 | RT | Total | Absent--107069PC23-2 | | N/A | | Jul 17, 2001 |
| Jul 05, 2001 | 1 | RT | Total | Absent--107069PC23-1 | | N/A | | Jul 17, 2001 |

[Click here to show results prior to](#)

[Recent Batch Numbers](#)

Oregon Department of Human Services

Drinking Water Program**MILTON-FREEWATER, CITY OF**

PWS #: 00522 System Status: Active System Type: C Population: 6,500

Current Open Coliform Sample Schedule*(subject to change based upon future test results)***7 Routine sample(s) per Month to be taken beginning 01/01/1991 -***(A begin date of 01/01/1991 indicates the year the Total Coliform Rule was established)**Community and Non-transient Non-community water systems that use chlorine or chloramines must measure the residual disinfectant level at the same points in the distribution system and at the same time when total coliforms are sampled.***Repeat, Temporary Routine, and Prior Coliform Sample Schedules**

sample(s) -

Instructions and Notes

- 1) If no prior sample schedules appear, then no prior schedules exist within the database.
- 2) Schedules for water systems that are classified as "NP" (State Regulated) may not appear. If the system is active, the system must sample and test for the presence of coliform bacteria with a frequency of 1 sample per quarter (1 sample per month for those systems with a surface water source or a groundwater source determined to be under the influence of surface water). If the sample tests positive for the presence of total or fecal coliform or E-Coli, a minimum of 4 repeat samples must be taken. 5 routine samples must then be taken the following month. If these 5 samples test negative for the presence of coliform bacteria, the system may return to a quarterly sample schedule beginning with the next quarter (e.g. a routine quarterly sample tests positive in January, 4 repeats need to be taken within 24 hours following the positive sample, 5 routine samples need to be taken in February and if none of these samples tests positive, the system can go back on a quarterly schedule beginning April 1st).

In any case, as soon as a sample tests positive for the presence of coliform bacteria, the system should contact the Department of Human Services at 971-673-0405 and ask to speak with the person handling phone duty for the Drinking Water Program.

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List for all Oregon Drinking Water Systems in Excel or printable screen format](#)
[SNC Reports for Oregon Drinking Water Systems](#)

Oregon Department of Human Services

Drinking Water Program

PWSID: 00522
 PWSName: MILTON-FREEWATER, CITY OF
 Status: A
 System Type: C
 Population: 6500

[Fact Sheets](#)
[Definitions](#)
[Public Notice](#)
[Alerts](#)
[Enforcements](#)
[Spreadsheet](#)

Action Levels: Lead = 0.0155 mg/l Copper = 1.35 mg/l

Lead and Copper 90th Percentile Results

| Sample Date | Date Received | Round | Sample Count | Duration | Lead (mg/l) | Copper (mg/l) |
|--------------|---------------|-------|--------------|----------|-------------|---------------|
| Jul 11, 2007 | Aug 03, 2007 | 0008 | 20 | 3Y | 0.0020 | 0.0810 |
| Jun 22, 2004 | Jul 20, 2004 | 0007 | 20 | 3Y | 0.0020 | 0.0600 |
| Sep 05, 2001 | Oct 11, 2001 | 0006 | 20 | 3Y | 0.0020 | 0.0910 |
| Mar 04, 1998 | Apr 09, 1998 | 0005 | 20 | YR | 0.0010 | 0.1400 |
| Aug 14, 1996 | Mar 05, 1997 | 0004 | 20 | YR | 0.0014 | 0.0580 |
| Sep 06, 1995 | Oct 10, 1995 | 0003 | 20 | YR | 0.0000 | 0.0600 |
| Jul 01, 1993 | Apr 22, 1993 | 0002 | 40 | 6M | 0.0050 | 0.1200 |
| Jan 11, 1993 | Feb 11, 1993 | 0001 | 40 | 6M | 0.0010 | 0.1000 |

More Info

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for](#)
[Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan](#)
[Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection](#)
[ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format
[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water ProgramND = Not Detected at the Minimum Reporting Level [Spreadsheet](#)

Nitrate Samples - PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

| Sample ID | Sample Date | Receive Date | Analyte Name | Source Name | Source ID | Results | MCL | UOM |
|-------------|-------------|--------------|------------------------|-------------------------------------|-----------|-----------|---------|------|
| A71024B3 | 10/23/07 | 11/05/07 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A71024B4 | 10/23/07 | 11/05/07 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | ND | 10.0000 | MG/L |
| A71024B1 | 10/23/07 | 11/05/07 | NITRATE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |
| A71024B2 | 10/23/07 | 11/05/07 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A60804D1 | 08/03/06 | 08/22/06 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A60804D2 | 08/03/06 | 08/22/06 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 0.8000000 | 10.0000 | MG/L |
| A60804D3 | 08/03/06 | 08/22/06 | NITRATE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |
| A60804D4 | 08/03/06 | 08/22/06 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A50914AQ-1 | 09/13/05 | 01/10/06 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A50914AO-1 | 09/13/05 | 12/07/05 | NITRATE (AS N) | EP FOR WELL #8 | EP-C | 0.3000000 | 10.0000 | MG/L |
| A50914AY-1 | 09/13/05 | 01/10/06 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A41117AP-2 | 11/16/04 | 12/01/04 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A41117AP-3 | 11/16/04 | 12/01/04 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A41117AP-4 | 11/16/04 | 12/01/04 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 1.6000000 | 10.0000 | MG/L |
| A41117AP-5 | 11/16/04 | 12/01/04 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 0.2000000 | 10.0000 | MG/L |
| A41117AP-65 | 11/16/04 | 12/01/04 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 0.4000000 | 10.0000 | MG/L |
| A41117AP-1 | 11/16/04 | 12/01/04 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A31009E-4 | 10/08/03 | 10/27/03 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A31009E-5 | 10/08/03 | 10/27/03 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | 0.7000000 | 10.0000 | MG/L |
| A31009E-6 | 10/08/03 | 10/27/03 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | ND | 10.0000 | MG/L |
| A31009E-3 | 10/08/03 | 10/27/03 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 0.7000000 | 10.0000 | MG/L |
| A31009E-1 | 10/08/03 | 10/27/03 | NITRATE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |
| A31009E-2 | 10/08/03 | 10/27/03 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A21205S-11 | 12/04/02 | 12/30/02 | NITRATE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |
| A21205S-11 | 12/04/02 | 12/30/02 | NITRATE+NITRITE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |

| | | | | | | | | |
|------------|----------|----------|------------------------|-------------------------------------|------|-----------|---------|------|
| A21205O-1I | 12/04/02 | 12/30/02 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A21205O-1I | 12/04/02 | 12/30/02 | NITRATE+NITRITE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A20724B-1I | 07/23/02 | 08/29/02 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A20724B-1I | 07/23/02 | 08/29/02 | NITRATE+NITRITE (AS N) | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 10.0000 | MG/L |
| A20724A-1I | 07/23/02 | 08/29/02 | NITRATE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 0.8400000 | 10.0000 | MG/L |
| A20724A-1I | 07/23/02 | 08/29/02 | NITRATE+NITRITE (AS N) | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | 0.8400000 | 10.0000 | MG/L |
| A20724C-1I | 07/23/02 | 10/04/02 | NITRATE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |
| A20724C-1I | 07/23/02 | 10/04/02 | NITRATE+NITRITE (AS N) | EP FOR WELL #8 | EP-C | ND | 10.0000 | MG/L |
| A20724D-1I | 07/23/02 | 08/29/02 | NITRATE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |
| A20724D-1I | 07/23/02 | 08/29/02 | NITRATE+NITRITE (AS N) | EP FOR WELL #9 | EP-D | ND | 10.0000 | MG/L |

Archived Nitrate Samples - PWS ID: 00522

| Sample Date | Receive Date | Analyte Name | Source Name | Source ID | Results | MCL |
|-------------|--------------|--------------|----------------------------|-----------|-----------|---------|
| 08/29/01 | 09/19/01 | Nitrate | WELL #1 | AA | 1.2000000 | 10.0000 |
| 08/29/01 | 09/19/01 | Nitrate | WELL #2 | AB | 1.2000000 | 10.0000 |
| 08/29/01 | 09/19/01 | Nitrate | WELL #3 | BA | 1.3000000 | 10.0000 |
| 08/29/01 | 09/19/01 | Nitrate | WELL #5 | BB | 1.2000000 | 10.0000 |
| 08/29/01 | 09/19/01 | Nitrate | WELL #6 | BC | 1.8000000 | 10.0000 |
| 08/29/01 | 09/24/01 | Nitrate | ENTRY POINT - WELL #8 | C | 1.3000000 | 10.0000 |
| 08/29/01 | 09/24/01 | Nitrate | EP FOR WELL #9 | D | 1.2000000 | 10.0000 |
| 12/05/00 | 12/18/00 | Nitrate | WELL #1 | AA | 0.3000000 | 10.0000 |
| 12/05/00 | 12/18/00 | Nitrate | WELL #3 | BA | 2.0000000 | 10.0000 |
| 12/05/00 | 12/18/00 | Nitrate | WELL #5 | BB | 0.9000000 | 10.0000 |
| 12/05/00 | 12/18/00 | Nitrate | WELL #6 | BC | 1.2000000 | 10.0000 |
| 12/05/00 | 12/18/00 | Nitrate | WELL #8 - COUSE CREEK ROAD | CA | 0.4000000 | 10.0000 |
| 12/05/00 | 12/18/00 | Nitrate | WELL #9 | DA | 0.4000000 | 10.0000 |
| 11/03/99 | 11/23/99 | Nitrate | WELL #1 | AA | ND | 10.0000 |
| 11/03/99 | 11/26/99 | Nitrate | WELL #2 | AB | 0.0400000 | 10.0000 |
| 11/03/99 | 11/26/99 | Nitrate | WELL #3 | BA | 0.2700000 | 10.0000 |
| 11/03/99 | 12/09/99 | Nitrate | WELL #5 | BB | 0.5800000 | 10.0000 |
| 11/03/99 | 11/23/99 | Nitrate | WELL #6 | BC | 0.5700000 | 10.0000 |
| 11/03/99 | 11/23/99 | Nitrate | WELL #8 - COUSE CREEK ROAD | CA | ND | 10.0000 |
| 04/22/99 | 06/11/99 | Nitrate | WELL #9 | DA | 0.2000000 | 10.0000 |
| 02/11/98 | 03/05/98 | Nitrate | WELL #1 | AA | ND | 10.0000 |
| 02/11/98 | 03/05/98 | Nitrate | WELL #2 | AB | 0.0100000 | 10.0000 |
| 02/11/98 | 03/05/98 | Nitrate | WELL #5 | BB | 1.3000000 | 10.0000 |
| 02/11/98 | 03/05/98 | Nitrate | WELL #6 | BC | 3.2000000 | 10.0000 |

| | | | | | | |
|----------|----------|-----------------|---------------------------------|----|-----------|---------|
| 02/11/98 | 03/05/98 | Nitrate | WELL #8 - COUSE CREEK ROAD | CA | ND | 10.0000 |
| 05/22/96 | 07/24/96 | Nitrate | WELL #1 | AA | 0.7600000 | 10.0000 |
| 05/22/96 | 07/24/96 | Nitrate | WELL #2 | AB | 0.0300000 | 10.0000 |
| 05/22/96 | 07/24/96 | Nitrate | WELL #5 | BB | ND | 10.0000 |
| 05/22/96 | 07/24/96 | Nitrate | WELL #6 | BC | 0.4000000 | 10.0000 |
| 05/22/96 | 07/24/96 | Nitrate | ENTRY POINT - WELL #8 | C | ND | 10.0000 |
| 05/22/96 | 07/24/96 | Nitrate | WELL #8 - COUSE CREEK ROAD | CA | ND | 10.0000 |
| 01/04/95 | 01/31/95 | Nitrate | WELL #1 | AA | ND | 10.0000 |
| 01/04/95 | 01/31/95 | Nitrate | WELL #2 | AB | 0.0200000 | 10.0000 |
| 01/04/95 | 01/31/95 | Nitrate | WELL #5 | BB | 1.1000000 | 10.0000 |
| 01/04/95 | 01/31/95 | Nitrate | WELL #6 | BC | 0.3500000 | 10.0000 |
| 01/04/95 | 01/31/95 | Nitrate | WELL #8 - COUSE CREEK ROAD | CA | ND | 10.0000 |
| 07/28/93 | 11/09/93 | Nitrate | WELL #1 | AA | ND | 10.0000 |
| 07/28/93 | 11/09/93 | Nitrate-Nitrite | WELL #1 | AA | ND | 10.0000 |
| 07/28/93 | 11/09/93 | Nitrate | WELL #2 | AB | 0.0400000 | 10.0000 |
| 07/28/93 | 11/09/93 | Nitrate-Nitrite | WELL #2 | AB | 0.0400000 | 10.0000 |
| 07/28/93 | 11/09/93 | Nitrate | WELL #5 | BB | 0.3200000 | 10.0000 |
| 07/28/93 | 11/09/93 | Nitrate-Nitrite | WELL #5 | BB | 0.3200000 | 10.0000 |
| 07/28/93 | 11/10/93 | Nitrate | WELL #6 | BC | 0.3300000 | 10.0000 |
| 07/28/93 | 11/10/93 | Nitrate-Nitrite | WELL #6 | BC | 0.3300000 | 10.0000 |
| 07/28/93 | 11/10/93 | Nitrate | WELL #8 - COUSE CREEK ROAD | CA | ND | 10.0000 |
| 07/28/93 | 11/10/93 | Nitrate-Nitrite | WELL #8 - COUSE CREEK ROAD | CA | ND | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate | WELL #1 | AA | 0.0200000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate-Nitrite | WELL #1 | AA | 0.0200000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate | WELL #2 | AB | 0.0200000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate-Nitrite | WELL #2 | AB | 0.0200000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate | WELL #5 | BB | 0.5000000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate-Nitrite | WELL #5 | BB | 0.5000000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate | WELL #6 | BC | 0.3700000 | 10.0000 |
| 04/14/93 | 11/30/93 | Nitrate-Nitrite | WELL #6 | BC | 0.4000000 | 10.0000 |
| 03/25/92 | 05/13/92 | Nitrate | WELLFIELD (WELLS #1 & #2) | A | ND | 10.0000 |
| 03/25/92 | 05/13/92 | Nitrate | WELLFIELD (WELLS #3,#5 & #6) | B | 1.0000000 | 10.0000 |
| 03/25/92 | 05/13/92 | Nitrate | WELL #8 | C | ND | 10.0000 |
| 06/16/91 | 07/23/91 | Nitrate | WELLFIELD (WELLS #1 & #2) | A | ND | 10.0000 |
| 06/16/91 | 07/23/91 | Nitrate | WELLFIELD (WELLS #3,#5 & #6) | B | 0.7000000 | 10.0000 |
| 06/16/91 | 07/23/91 | Nitrate | WELL #8 | C | ND | 10.0000 |

| | | | | | | |
|----------|----------|---------|------------------------------|---|-----------|---------|
| 06/20/88 | 07/06/88 | Nitrate | WELLFIELD (WELLS #1 & #2) | A | ND | 10.0000 |
| 06/20/88 | 07/06/88 | Nitrate | WELLFIELD (WELLS #3,#5 & #6) | B | 1.9700000 | 10.0000 |
| 06/20/88 | 07/06/88 | Nitrate | WELL #8 | C | ND | 10.0000 |
| 07/16/85 | 07/16/85 | Nitrate | WELLFIELD (WELLS #1 & #2) | A | 0.3800000 | 10.0000 |

A blank or a 0 in the MCL column indicates that a MCL has not been set for that chemical.

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for](#)
[Chemicals](#)

[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan](#)
[Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection](#)
[ASRs](#)

[Inventory List for all Oregon Drinking Water Systems in Excel or printable screen format](#)
[SNC Reports for Oregon Drinking Water Systems](#)

Oregon Department of Human Services

Drinking Water ProgramND = Not Detected at the Minimum Reporting Level [Spreadsheet](#)

Arsenic Samples - PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

| Sample ID | Sample Date | Receive Date | Source Name | Source ID | Results | MCL | UOM |
|------------|-------------|--------------|-------------------------------------|-----------|---------|--------|------|
| A50914AQ-1 | 09/13/05 | 01/10/06 | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 0.0500 | MG/L |
| A50914AO-1 | 09/13/05 | 12/07/05 | EP FOR WELL #8 | EP-C | ND | 0.0500 | MG/L |
| A50914AY-1 | 09/13/05 | 01/10/06 | EP FOR WELL #9 | EP-D | ND | 0.0500 | MG/L |
| A21205S-1I | 12/04/02 | 12/30/02 | EP FOR WELL #8 | EP-C | ND | 0.0500 | MG/L |
| A21205O-1I | 12/04/02 | 12/30/02 | EP FOR WELL #9 | EP-D | ND | 0.0500 | MG/L |
| A20724B-1I | 07/23/02 | 08/29/02 | EP FOR WELLFIELD (WELLS #1 & #2) | EP-A | ND | 0.0500 | MG/L |
| A20724A-1I | 07/23/02 | 08/29/02 | EP FOR WELLFIELD (WELLS #3,#5 & #6) | EP-B | ND | 0.0500 | MG/L |
| A20724C-1I | 07/23/02 | 10/04/02 | EP FOR WELL #8 | EP-C | ND | 0.0500 | MG/L |
| A20724D-1I | 07/23/02 | 08/29/02 | EP FOR WELL #9 | EP-D | ND | 0.0500 | MG/L |

Archived Arsenic Samples - PWS ID: 00522

| Sample Date | Receive Date | Source Name | Source ID | Results | MCL |
|-------------|--------------|----------------------------|-----------|-----------|--------|
| 11/03/99 | 11/23/99 | WELL #1 | AA | ND | 0.0500 |
| 11/03/99 | 11/26/99 | WELL #2 | AB | 0.0002000 | 0.0500 |
| 11/03/99 | 11/26/99 | WELL #3 | BA | 0.0004000 | 0.0500 |
| 11/03/99 | 12/09/99 | WELL #5 | BB | ND | 0.0500 |
| 11/03/99 | 11/23/99 | WELL #6 | BC | ND | 0.0500 |
| 11/03/99 | 11/23/99 | WELL #8 - COUSE CREEK ROAD | CA | 0.0005000 | 0.0500 |
| 04/22/99 | 06/11/99 | WELL #9 | DA | ND | 0.0500 |
| 05/22/96 | 07/24/96 | WELL #1 | AA | ND | 0.0500 |
| 05/22/96 | 07/24/96 | WELL #2 | AB | ND | 0.0500 |
| 05/22/96 | 07/24/96 | WELL #5 | BB | ND | 0.0500 |
| 05/22/96 | 07/24/96 | WELL #6 | BC | ND | 0.0500 |
| 05/22/96 | 07/24/96 | ENTRY POINT - WELL #8 | C | ND | 0.0500 |
| 05/22/96 | 07/24/96 | WELL #8 - COUSE CREEK ROAD | CA | ND | 0.0500 |
| 07/28/93 | 11/09/93 | WELL #1 | AA | ND | 0.0500 |
| 07/28/93 | 11/09/93 | WELL #2 | AB | ND | 0.0500 |

| | | | | | |
|----------|----------|------------------------------------|----|----|--------|
| 07/28/93 | 11/09/93 | WELL #5 | BB | ND | 0.0500 |
| 07/28/93 | 11/10/93 | WELL #6 | BC | ND | 0.0500 |
| 07/28/93 | 11/10/93 | WELL #8 - COUSE CREEK ROAD | CA | ND | 0.0500 |
| 04/14/93 | 11/30/93 | WELL #1 | AA | ND | 0.0500 |
| 04/14/93 | 11/30/93 | WELL #2 | AB | ND | 0.0500 |
| 04/14/93 | 11/30/93 | WELL #5 | BB | ND | 0.0500 |
| 04/14/93 | 11/30/93 | WELL #6 | BC | ND | 0.0500 |
| 03/25/92 | 05/13/92 | WELLFIELD (WELLS #1 & #2) | A | ND | 0.0500 |
| 03/25/92 | 05/13/92 | WELLFIELD (WELLS #3,#5 & #6) | B | ND | 0.0500 |
| 03/25/92 | 05/13/92 | WELL #8 | C | ND | 0.0500 |
| 06/16/91 | 07/23/91 | WELLFIELD (WELLS #1 & #2) | A | ND | 0.0500 |
| 06/16/91 | 07/23/91 | WELLFIELD (WELLS #3,#5 & #6) | B | ND | 0.0500 |
| 06/16/91 | 07/23/91 | WELL #8 | C | ND | 0.0500 |
| 06/20/88 | 07/06/88 | WELLFIELD (WELLS #1 & #2) | A | ND | 0.0500 |
| 06/20/88 | 07/06/88 | WELLFIELD (WELLS #3,#5 & #6) | B | ND | 0.0500 |
| 07/16/85 | 07/16/85 | WELLFIELD (WELLS #1 & #2) | A | ND | 0.0500 |

A blank or a 0 in the MCL column indicates that a MCL has not been set for that chemical.

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for](#)
[Chemicals](#)

[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan](#)
[Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection](#)
[ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format
[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water Program

ND = Not Detected at the Minimum Reporting Level; [Spreadsheet](#) - = Not Sampled

Disinfection By-product Monitoring - PWS ID: 00522 = MILTON-FREEWATER, CITY OF

| Sample ID | Sample Date | Receive Date | Source ID | TTHM mg/L MCL = 0.08 | HAA5 mg/L MCL = 0.06 | Bromate mg/L |
|-------------|-------------|--------------|-----------|-------------------------|-------------------------|--------------|
| A71022A1 | 10/22/07 | 12/07/07 | DIST-A | ND | ND | - |
| A71022A2 | 10/22/07 | 12/07/07 | DIST-A | 0.0011000 | ND | - |
| A71022A3 | 10/22/07 | 12/07/07 | DIST-A | 0.0007000 | ND | - |
| A71022A4 | 10/22/07 | 12/06/07 | DIST-A | 0.0010000 | ND | - |
| A40908BR-01 | 09/07/04 | 10/13/04 | DIST-A | ND | 0.0006000 | - |
| A40908BR-02 | 09/07/04 | 10/13/04 | DIST-A | ND | 0.0007000 | - |

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List for all Oregon Drinking Water Systems in Excel or printable screen format](#)
[SNC Reports for Oregon Drinking Water Systems](#)

DWP Outreach Plan

PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

- ▼ Disinfectant Byproducts (DBP)
- ▼ Total Organic Carbon (TOC)
- ▼ Bromate
- ▼ Chlorine(MRDL) Monitoring and Results

DBP

Applicability

DBP Monitoring applies to Community Water Systems and Non-Transient Non-Community water systems that add a chemical disinfectant (excluding U/V disinfection) to their water or that purchase from a system that adds a chemical disinfectant.

Description

Disinfectant Byproducts (DBPs) include Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5). These byproducts are formed when chemical disinfectants react with organic compounds (such as TOC). DBPs are a health concern because they may cause cancer, as well as liver, kidney, and central nervous system problems.

Monitoring

DBP Monitoring applies to Community Water Systems and Non-Transient Non-Community water systems that add a chemical disinfectant (excluding U/V disinfection) to their water or that purchase from a system that adds a chemical disinfectant. Monitoring is summarized in the table below:

Monitoring for Total Trihalomethanes & Haloacetic Acids

| System Type | Routine Monitoring | Reduced Monitoring |
|--|---------------------------------|--|
| Surface Water with Population 10,000 & Up | 4 Samples per Plant per Quarter | 1 Sample per Plant per Quarter |
| Surface Water with Population 500 – 9,999 | 1 Sample per Plant per Quarter | 1 Sample per Plant per Year |
| Surface Water with Population less than 500 | 1 Sample per Plant per Year | No reduction |
| Groundwater with Population 10,000 & Up | 1 Sample per Plant per Quarter | 1 Sample per Plant per Year |
| Groundwater with Population less than 10,000 | 1 Sample per Plant per Year | 1 Sample per Plant per 3 Year Cycle (Jan 1 – Dec 31) |

Note: Surface water systems are eligible for reduced monitoring frequency when both DBP levels are ≤ to 50% of the MCL and monthly source water TOC running annual average is < 4.0 mg/l. (Once on reduced DBP monitoring, source water TOC can be reduced to quarterly.) Groundwater systems are eligible for reduced monitoring based on disinfection byproduct monitoring alone. A "Plant" can be a treatment facility, entry point, well, or a wellfield and is the point at which a disinfectant is added (refer to your water system info page to view a list of your active treatment plants and which plants include adding a disinfectant as a treatment process).

Monitoring schedules for your particular system will be available in the coming months.

Sample Points

Sample sites for your water system are listed below. DBP_{MAX} refers to the point of maximum residence time in the distribution system and generally, this is the point farthest from the point of disinfection. DBP without the "MAX" designation refers to points within the distribution that represent an average disinfectant level.

DBP Sample Points for PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

| Sample Point ID | Location |
|-----------------------|----------------|
| DBP _{MAX} 01 | 1014 S MAIN ST |
| DBP _{MAX} 02 | 501 LAMB ST |
| DBP _{MAX} 03 | 217 E BROADWAY |
| DBP _{MAX} 04 | CITY HALL |

Results

All Results will be entered and taken into consideration when setting monitoring schedules and will be available in the coming months

Maximum Contaminant Levels

| Disinfection Byproduct | Maximum Contaminant Level (mg/l) |
|--------------------------------|-----------------------------------|
| Total Trihalomethanes (TTHM) | 0.080 as a Running Annual Average |
| Haloacetic Acids (five) (HAA5) | 0.060 as a Running Annual Average |

Determining Compliance with the Maximum Contaminant Levels

A running annual average is the arithmetic average of results and is calculated at the end of every quarter for the previous consecutive four-quarter period. Compliance is achieved when the running annual average of TTHM results are less than 0.080 mg/L and the running annual average of HAA5 results are below 0.060 mg/L.

Fact Sheets

- Trihalomethanes Health Effects *(PDF)*
- Quick Reference Guide (2 pages) *(PDF)*
- General M-DBP Fact Sheet (5 pages) *(PDF)*
- Stage 1 DBPR Fact Sheet (4 pages) *(PDF)*
- EPA Microbial and Disinfectant Byproduct Rules Simultaneous Compliance Guidance Manual (150 pages) *(PDF)*
- Flow Chart For Surface Water or Groundwater Under the Influence of Surface Water Sources *(PDF)*

Educational

- Stage 1 Disinfection Byproduct Monitoring (PowerPoint presentation)

TOC

Applicability

TOC monitoring applies to Community and Non-Transient Non-Community systems using surface water or groundwater under the direct influence of surface water and that add a chemical disinfectant and use conventional filtration (2.5-log) or softening. Monitoring also applies to any system seeking a reduction in DBP monitoring, but does not meet the applicability requirements described above, however, only raw water TOC sampling applies in this case.

NOT REQUIRED

(Raw TOC monitoring must be done quarterly by surface water systems on reduced DBP monitoring)

MILTON-FREEWATER, CITY OF (PWS ID: #00522)

Is not required to sample Raw water TOC, raw water Alkalinity, and Filtered Water TOC

Description

Total Organic Carbon (TOC) is naturally found in water and can react with disinfectants to produce DBPs. Reduction of TOC limits the formation of DBPs.

Monitoring

Community and Non-Transient Non-Community Systems

For Surface Systems with Conventional Treatment Plants (2.5-log) Only

| Parameter | Routine Monitoring | Reduced Monitoring |
|----------------------|--------------------|----------------------|
| Raw water TOC | 1 Sample per month | 1 Sample per quarter |
| Filtered water TOC | 1 Sample per month | 1 Sample per quarter |
| Raw water alkalinity | 1 Sample per month | 1 Sample per quarter |


Note: Water systems are eligible for reduced monitoring frequency when the average treated TOC for 1 year is < 1.0 mg/l or the average treated TOC for 2 years is < 2.0 mg/l.

Sampling for both raw and filtered water parameters should occur on the same day.

Monitoring schedules for your particular system will be available in the coming months.

Sample Points

Sample sites for your water system should include a site at the raw water source coming into the treatment plant and the combined filter effluent. Example:



Results

All Results will be entered and taken into consideration when setting monitoring schedules and will be available in the coming months.

Minimum Treatment Technique Required (Equivalent to Maximum Contaminant Level)

The Minimum Treatment Technique Required is based on whether enhanced coagulation is required and on a ratio of the percent of TOC actually removed to the percent of TOC that should have been removed.

The running annual average of ratios must be greater than or equal to 1.00 (i.e. the amount of TOC that was actually removed must be equal to or greater than the TOC that should have been removed). A running annual average is the arithmetic average of a year's worth of monthly TOC results and is calculated at the end of every quarter.

Determining Compliance with the Minimum Treatment Technique Required

Compliance is based upon if you need enhanced coagulation. Answer the following six questions in the order that they are listed to determine if you need enhanced coagulation. (If you answer any of the questions with "Yes", you do not need to answer the rest of the questions).

| Question # | Question | Answer (Yes/No) |
|------------|--|-----------------|
| 1 | Is the current Raw Water Running Annual Average (RAA) TOC (the average of the prior 12 months worth of raw water TOC data) less than or equal to 2.0 mg/L? | |
| 2 | Is the Filtered Water RAA TOC (average of the prior 12 months worth of combined filter effluent TOC data) less than or equal to 2.0 mg/L? | |
| 3 | Is the current Raw Water RAA TOC ≤ 4.0 mg/L, and the current Raw Water RAA Alkalinity > 60 mg/L, and the current RAA for HAA5 ≤ .030 mg/L, and the current RAA for TTHM ≤ .040 mg/L? | |
| 4 | Is Chlorine the only disinfectant used and is the current RAA for HAA5 ≤ .030 mg/L and current RAA for TTHM ≤ .040 mg/L? | |
| 5 | If you conduct source water specific UV light absorbance (SUVA) monitoring, is the current RAA SUVA < 2.0 L/mg-m? (your answer should be "No" if you do not conduct this monitoring) | |
| 6 | If you conduct filtered water SUVA monitoring, is the current RAA SUVA < 2.0 L/mg-m? (your answer should be "No" if you do not conduct this | |

| | |
|--------------|--|
| [monitoring] | |
|--------------|--|

If you answered "Yes" to any of the previous six questions, you are qualified to opt out of enhanced coagulation and you will not need to comply with the Minimum Treatment Technique Requirements (i.e. you do not need to use the Minimum Treatment Technique Requirement Compliance Calculations described below), however, the monitoring requirements still apply and all results must still be submitted to the Drinking Water Program.

If you did not answer "Yes" to any of the six questions, you cannot opt out of enhanced coagulation and compliance is based on a ratio of the percent of TOC actually removed to the percent of TOC that should have been removed. Use the following compliance calculations to determine compliance with the Minimum Treatment Technique Requirement:

Minimum Treatment Technique Requirement Compliance Calculations

In order to achieve compliance, the running annual average of the ratio of the percent of TOC actually removed to the percent of TOC that should have been removed must be greater than or equal to 1.00 (i.e. the amount of TOC that was actually removed must be equal to or greater than the TOC that should have been removed). A running annual average is the arithmetic average of results and is calculated at the end of every quarter.

Where

TOC Actually Removed = TOC concentration (in mg/L) of raw water before filtration divided by the TOC concentration (in mg/L) of the combined filter effluent water.

TOC that should have been removed is based on the raw water TOC and the raw water alkalinity according to the following:

| Source Water TOC (mg/l) | Source Water Alkalinity, mg/l as CaCO ₃ | | |
|-------------------------|--|----------|--------|
| | 0 - 60 | 61 - 120 | > 120* |
| > 2.0 – 4.0 | 35.0% | 25.0% | 15.0% |
| > 4.0 – 8.0 | 45.0% | 35.0% | 25.0% |
| > 8.0 | 50.0% | 40.0% | 30.0% |

* Systems using enhanced softening must use the TOC removal percentages in this column.

Example: if the raw water alkalinity = 65 mg/L and the raw water TOC = 9.0 mg/L, then the required removal percentage = 40.0%.

Note: It is important to recognize that this percentage can change from month to month depending on the actual raw water TOC and Alkalinity.

Example:

Calculations to Determine Compliance with the Required Removal Ratio of 1.00

| Source of Data | Parameter | Results |
|---|--|---|
| Raw Water Sampling Data | Source (Raw) Water Alkalinity | 65 mg/L |
| Raw Water Sampling Data | Raw Water TOC | 9.0 mg/L |
| Table of Required Removal Percentages (shown above) | Required Removal Percentage | 40.0% |
| Treated Water Sampling Data | Treated Water TOC | 4.0 mg/L |
| Calculated as Shown | TOC Removed (Raw Water TOC – Treated Water TOC) | 9.0 – 4.0 = 5.0 mg/L |
| Calculated as Shown | Actual Removal Percentage (TOC Removed/Raw Water TOC) | 5.0 / 9.0 = 0.556 (or 55.6%) |
| Calculated as Shown | Calculation of Removal Ratio (Actual Removal Percentage / Required Removal Percentage) | 55.6 / 40.0 = 1.39 |
| Calculated as Shown | Ultimate Removal Ratio | 1.39 (which is greater than 1.00 therefore, compliance is achieved) |

☒ Bromate

Applicability

Bromate monitoring applies to Community and Non-Transient Non-Community systems using ozone as a disinfectant or oxidant.

Description

Bromate is disinfectant byproduct that is formed when ozone is used as a disinfectant in the presence of bromide, which is a naturally occurring element found in ground and surface water sources. Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.

Monitoring

Monitoring for Bromate for Systems Using Ozone

| Location | Routine Monitoring | Reduced Monitoring |
|------------------------------------|--------------------|----------------------|
| Entry Point for the WTP with Ozone | 1 Sample per Month | 1 Sample per Quarter |

Note: Water systems are eligible for reduced monitoring frequency when the average source water bromide concentration is < 0.05 mg/l based on monthly bromide samples for one year and verified as a running annual average that is computed quarterly after the initial year.

Monitoring schedules for your particular system will be available in the coming months.

Sample Points

Sampling for your water system should be at the entry point to the distribution system.

Results

All Results will be entered and taken into consideration when setting monitoring schedules and will be available in the coming months.

Maximum Contaminant Level

The maximum contaminant level for Bromate is 0.010 mg/L.

Determining Compliance with the Maximum Contaminant Level

Compliance with the MCL is based on a running annual average. A running annual average is the arithmetic average of results and is calculated at the end of every quarter.

☒ Chlorine Residual Disinfectant Level

Applicability

Chlorine Residual monitoring is applicable to all Community and Non-Transient Non-Community water systems that use chlorine or chloramines as a disinfectant.

Description

Chlorine is a disinfectant that is used to control microbes. Some people who use water containing chlorine well in excess of the Maximum Residual Disinfectant Level could experience irritating effects to their eyes and nose and could experience stomach discomfort and anemia.

Monitoring

Systems must monitor for chlorine and chloramines every time they sample for total coliform - this includes repeat sampling.

Sample Points

Samples must be taken at the same location in the distribution system as those locations used for total coliform sampling. This is a separate requirement from the daily monitoring and recording of the disinfectant residual.

Results

Results may be submitted on the coliform sampling form (or on the coliform sampling summary forms) that each system currently uses. All Results will be entered and taken into consideration when setting monitoring schedules and will be available in the coming

months. Schedules will reflect the current coliform monitoring schedules already available on-line at the following link located at the bottom of your water system's info page: [Sampling Schedule-Coliform](#)

Maximum Residual Disinfectant Level (MRDL)

The MRDL for chlorine is 4.0 mg/L (measured as free chlorine).

Determining Compliance with the MRDL

Compliance with the MRDL is based on a running annual average of monthly averages. Any running annual average that exceeds the MRDL is a violation.

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List for all Oregon Drinking Water Systems in Excel or printable screen format](#)
[SNC Reports for Oregon Drinking Water Systems](#)

[Introduction](#) :: [Data Search Options](#) :: [WS Name Look Up](#) :: [WS ID Look Up](#) :: [DWP Home](#)

Oregon Department of Human Services

Drinking Water Program

ND = Not Detected at the Minimum Reporting Level; [View Gross Alpha, Radium, & Uranium Spreadsheet](#)

Radionuclide Samples - PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF

| Sample ID | Sample Date | Receive Date | Chemical | Source ID | Results | MCL | UOM |
|-----------|-------------|--------------|--|-----------|-----------|---------|------|
| H45XQ | 05/09/06 | 01/14/08 | GROSS ALPHA, EXCLDNG RN & U (EPA 4000) | EP-A | ND | 15.0000 | pCi |
| H45X0 | 05/09/06 | 01/14/08 | GROSS ALPHA, EXCLDNG RN & U (EPA 4000) | EP-A | ND | 15.0000 | pCi |
| H45XQ | 05/09/06 | 01/14/08 | RADIUM, COMBINED (226, 228) (EPA 4010) | EP-A | ND | 5.0000 | pCi |
| H45X0 | 05/09/06 | 01/14/08 | RADIUM, COMBINED (226, 228) (EPA 4010) | EP-A | 0.8600000 | 5.0000 | pCi |
| H45XQ | 05/09/06 | 01/14/08 | URANIUM, COMBINED (EPA 4006) | EP-A | 0.0001100 | 0.0300 | MG/L |
| H45X0 | 05/09/06 | 01/14/08 | URANIUM, COMBINED (EPA 4006) | EP-A | 0.0001200 | 0.0300 | MG/L |
| H450A | 05/09/06 | 01/14/08 | GROSS ALPHA, EXCLDNG RN & U (EPA 4000) | EP-B | ND | 15.0000 | pCi |
| H450A | 05/09/06 | 01/14/08 | RADIUM, COMBINED (226, 228) (EPA 4010) | EP-B | 0.8800000 | 5.0000 | pCi |
| H450A | 05/09/06 | 01/14/08 | URANIUM, COMBINED (EPA 4006) | EP-B | ND | 0.0300 | MG/L |

Archived Results

| Sample Date | Receive Date | Chemical | Source ID | Results | MCL |
|-------------|--------------|------------------------------|-----------|---------|---------|
| 10/25/99 | 11/29/99 | Gross Alpha, Excl. Radon & U | DA | ND | 15.0000 |
| 02/11/98 | 03/23/98 | Gross Alpha, Excl. Radon & U | AA | ND | 15.0000 |
| 02/11/98 | 03/23/98 | Gross Alpha, Excl. Radon & U | AB | ND | 15.0000 |
| 02/11/98 | 03/23/98 | Gross Alpha, Excl. Radon & U | BB | ND | 15.0000 |
| 02/11/98 | 03/23/98 | Gross Alpha, Excl. Radon & U | BC | ND | 15.0000 |
| 02/11/98 | 03/23/98 | Gross Alpha, Excl. Radon & U | CA | ND | 15.0000 |
| 08/30/92 | 11/25/92 | Gross Alpha, Excl. Radon & U | A | ND | 15.0000 |
| 08/29/88 | 10/21/88 | Gross Alpha, Excl. Radon & U | A | ND | 15.0000 |
| 08/29/88 | 10/21/88 | Gross Alpha, Excl. Radon & U | B | ND | 15.0000 |

A blank or a 0 in the MCL column indicates that a MCL has not been set for that chemical.

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format
[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water ProgramFacility Analyte Levels - PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF
Spreadsheet

| source | startDate | endDate | controlLevel | measure | uom | analyte | analyteCode | mdbpFlag |
|---------------------|------------|---------|--------------|-----------|------|-------------------------------|-------------|----------|
| Distribution System | 01/01/2004 | | MAX | 0.0600000 | MG/L | TOTAL HALOACETIC ACIDS (HAA5) | 2456 | |
| Distribution System | 01/01/2004 | | MAX | 0.0800000 | MG/L | TOTAL TRIHALOMETHANES (TTHM) | 2950 | |
| Distribution System | 01/01/2004 | | MAX | 4.0000000 | MG/L | CHLORINE | 0999 | Y |

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for Chemicals](#)
[Single Analyte Results For a System](#) :: [Lead & Copper](#) :: [Corrosion Control\(LCR\)](#) :: [SWTR](#) :: [Nitrates](#) :: [Arsenic](#)
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Bromate/Chlorine Monitoring](#) :: [Radionuclides](#) :: [FANLs](#) :: [MRDL](#) :: [Plan Review](#)

Information by county:

[Inventory](#) :: [Surface Water Systems](#) :: [Water System Surveys](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Cross Connection ASRs](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format
[SNC Reports](#) for Oregon Drinking Water Systems

Oregon Department of Human Services

Drinking Water Program

MRDL

PWS ID: 00522 ---- MILTON-FREEWATER, CITY OF [Spreadsheet](#)

| Monitoring Period | Received | Entry Point | Samples Required | Samples Collected | Period Avg | Annual Avg | Level Compliance | M&R Compliance |
|-------------------|--------------|-------------|------------------|-------------------|------------|------------|------------------|----------------|
| Sep 01, 2007 | Oct 17, 2007 | DIST-A | 7 | 7 | 0.2485 | 0.2313 | Y | YES |
| Aug 01, 2007 | Oct 17, 2007 | DIST-A | 7 | 10 | 0.2580 | 0.2292 | Y | YES |
| Jul 01, 2007 | Oct 17, 2007 | DIST-A | 7 | 6 | 0.2366 | 0.2251 | Y | NMJ |
| Jun 01, 2007 | Jul 17, 2007 | DIST-A | 7 | 8 | 0.2725 | 0.2454 | Y | YES |
| May 01, 2007 | Jul 17, 2007 | DIST-A | 7 | 10 | 0.1590 | 0.2421 | Y | YES |
| Apr 01, 2007 | Jul 17, 2007 | DIST-A | 7 | 8 | 0.1712 | 0.2542 | Y | YES |
| Jan 01, 2007 | Apr 16, 2007 | DIST-A | 7 | 10 | 0.2830 | 0.2453 | Y | YES |
| Dec 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2487 | 0.2375 | Y | YES |
| Nov 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 10 | 0.2040 | 0.2361 | Y | YES |
| Oct 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2500 | 0.2406 | Y | YES |
| Sep 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2400 | 0.2391 | Y | YES |
| Aug 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 10 | 0.3780 | 0.2389 | Y | YES |
| Jul 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 7 | 0.1500 | 0.2035 | Y | YES |
| Jun 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2225 | 0.2218 | Y | YES |
| May 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2300 | 0.2215 | Y | YES |

| | | | | | | | | |
|--------------|--------------|--------|---|----|--------|--------|---|-----|
| Apr 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 7 | 0.2128 | 0.2128 | Y | YES |
| Mar 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2225 | 0.2225 | Y | YES |
| Feb 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2925 | 0.2925 | Y | YES |
| Jan 01, 2006 | Mar 12, 2007 | DIST-A | 7 | 8 | 0.2225 | 0.2225 | Y | YES |
| Dec 01, 2005 | May 16, 2006 | DIST-A | 7 | 7 | 0.1000 | 0.2003 | Y | YES |
| Nov 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.2425 | 0.2174 | Y | YES |
| Oct 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.1462 | 0.2124 | Y | YES |
| Sep 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.3700 | 0.2293 | Y | YES |
| Aug 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.1975 | 0.1834 | Y | YES |
| Jul 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.1650 | 0.1763 | Y | YES |
| Jun 01, 2005 | May 16, 2006 | DIST-A | 7 | 10 | 0.1880 | 0.1880 | Y | YES |
| May 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.1325 | 0.1325 | Y | YES |
| Apr 01, 2005 | May 16, 2006 | DIST-A | 7 | 10 | 0.1740 | 0.1740 | Y | YES |
| Mar 01, 2005 | May 16, 2006 | DIST-A | 7 | 10 | 0.2280 | 0.2280 | Y | YES |
| Feb 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.2425 | 0.2425 | Y | YES |
| Jan 01, 2005 | May 16, 2006 | DIST-A | 7 | 8 | 0.1850 | 0.1850 | Y | YES |
| Nov 01, 2004 | Dec 21, 2004 | DIST-A | 7 | 8 | 0.1875 | 0.1750 | Y | YES |

For further information on this public water system click on the area of interest below.

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#)
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results Archives \(pre 2002\)](#) :: [Sampling Schedule for Coliform](#)
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Chemical Detections](#) :: [Sampling Schedules for](#)

Chemicals

Single Analyte Results For a System :: Lead & Copper :: Corrosion Control(LCR) :: SWTR :: Nitrates :: Arsenic
DBPs :: TOC & Alkalinity :: DBP/TOC/Bromate/Chlorine Monitoring :: Radionuclides :: FANLs :: MRDL :: Plan
Review

Information by county:

Inventory :: Surface Water Systems :: Water System Surveys :: Alerts :: Violations :: Open Enforcements :: Cross Connection
ASRs

Inventory List for all Oregon Drinking Water Systems in Excel or printable screen format

SNC Reports for Oregon Drinking Water Systems

APPENDIX B

Drinking Water Program Sanitary Survey Information



Oregon

Theodore R. Kulongoski, Governor

Department of Human Services
Public Health Division
Drinking Water Program
700 SE Emigrant, Rm. 240

January 16, 2009

RECEIVED
JAN 20 2009

Pendleton, OR 97801
(541) 276-8006
FAX (541) 276-4778

Dave Bradshaw
City of Milton-Freewater
PO Box 6
Milton-Freewater, OR 97862

BY:



RE: Water System Survey, City of Milton-Freewater, PWS ID: 4100522

Thank you for your time and assistance in performing the survey of your water system on January 7, 2009. Please thank Scott for his tour of your water system. His vast knowledge of the system was very helpful. The main purpose of the water system survey is to evaluate the entire water system in terms of supplying safe drinking water to the public. I have enclosed a copy of the report for your records. Please let me know if any corrections need to be made.

I am pleased that all deficiencies noted from the 2004 survey were corrected. **However, it was noted on the previous survey that the Master Plan was being updated by Anderson-Perry. Currently, the Master Plan still has not been completed nor is there a copy of the current Master Plan in our records.** This is a significant deficiency. I encourage you to get in touch with Anderson-Perry to get your Master Plan finalized.

You have done a real nice job maintaining your water system. I have enclosed information about outstanding performer criteria. I think this would be an attainable goal for your system.

If you have any questions or comments regarding this survey please give me a call at 541-966-0901.

Sincerely,

Amy Baker

Drinking Water Specialist

c. Drinking Water Program, Marsha Fox, Portland

Outstanding Performance Criteria

DHS-Drinking Water Program

The Drinking Water Program (DWP) has identified criteria for determining whether a system using surface water should be considered to have outstanding performance. This designation is given at the completion of a water system survey, formerly referred to a sanitary survey. A water system survey is an on-site review of a system's sources, treatment, storage facilities, distribution system, operation and maintenance procedures, monitoring, and management, for the purpose of evaluating the system's capability of providing safe water to the public. Systems that are designated outstanding performers will have their water system survey frequency reduced from every 3 years to every 5 years.

The criteria for outstanding performance are:

- 1) No Maximum Contaminant Level (MCL) or Treatment Technique violations in the last 5 years;
- 2) No more than one Monitoring and Reporting violation in the last 3 years. The one violation must be resolved (results submitted);
- 3) No significant deficiencies identified during the current water system survey; and
- 4) Has not had a waterborne disease outbreak attributable to the water system in the last 5 years.

To check your water system's violation history, go to www.oregon.gov/dhs/ph/dwp, and click on "Data On-Line." Type in your water system name or PWS ID number. The date of the last survey is listed on this page. Towards the bottom of that page, under "For further information..." click on "Violations".

- An MCL violation will have "MCL" in the Violation Type column.
- Treatment Technique violations are for inadequate surface water treatment or corrosion control.
- If the system has one Monitoring and Reporting violation during the last 3 years, there must be a subsequent monitoring result for that contaminant on record in order to meet criterion #2.

We strongly encourage all systems to meet the Outstanding Performance criteria. We will review your system's designation for Outstanding Performance after completion of each sanitary survey. The designation will remain in effect as long as the criteria continue to be met.

If you have any questions relating to compliance with any of these criteria, please contact your regional Drinking Water Program or County Health Department staff person, or contact the DWP Phone Duty person at 971-673-0405.



Sanitary Survey Deficiency Summary

DHS Drinking Water Program
Sanitary Survey

Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2 2

Surveyor: Amy Baker


Date of Survey: 01/07/08

Date Corrective Action Plan is Due: na

County: Umatilla

| Yes | No | Deficiencies | Date to be Corrected | Date Corrected |
|-------------------------------------|-------------------------------------|--|----------------------|----------------|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Source Deficiencies Well Construction | | |
| | | Spring/Other Source | | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Treatment Deficiencies: Surface Water Treatment Deficiencies | | |
| | | Disinfection Deficiencies | | |
| | | Other Treatment Deficiencies | | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Finished Water Storage Deficiencies: | | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Distribution Deficiencies: | | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Monitoring Deficiencies | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Management & Operations Deficiencies: No current Master Plan | | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Operator Certification Deficiencies: | | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Other Rule Violations: | | |


Comments: No current Master Plan on file - Master Plan is being updated by Anderson-Perry.



Quadrangle Map

USGS Map Name - Milton-Freewater, Oreg.

USGS Map Number - N4552.5-W11822.5/7.5



WELL #5
WELL #3
WELL #6

North Pressure Zone

Middle Pressure Zone

North Zone Reservoir
(2,000,000 gallons)

WELL #2
WELL #1

Middle Zone Reservoir
(1,000,000 gallons)

Well #9

South Zone Reservoir
(2,000,000 gallons)

57'30"
5090
T. 6 N.
T. 5 N.
5087
5086
55'
5085

(BOWLUS HILL)
2375 IV NE

UNION
Storage Bin

14


15

LOCATION MAP (USGS QU. HEET)

SUPPLY NAME: M1 -FREEWATER 5 of 14
ID NUMBER : 4100522

Quadrangle Map

USGS Map Name - Bowlus Hill, Oreg.
USGS Map Number - N4552.5-W11815/7.5



Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2 2

| ID | Entry Points <i>(Location where water enters distribution and is sampled)</i> | Source Type | | | | | | Availability | | | | Treatment Codes | |
|----|--|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|--------------------------|--------|------|--------------------------|--------------------------|------|
| | | Ground | Surface | GWUDI | Pur. Ground | Pur. Surface | Permanent | Seasonal | Begins | Ends | Emergency | | None |
| A | Wellfield (Wells 1 & 2) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| B | Wellfield (Wells 3, 5, & 6) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| C | EP for Well 8 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| D | EP for Well 9 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | X421 |

| ID | Individual Sources <i>(Contributing to Entry Point:)</i> | *Land Use* | Capacity (GPM) | Source Type | | | | | | Availability | | | | Treatment Codes |
|----|---|------------|----------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-----------------|
| | | | | Ground | Surface | GWUDI | Pur. Ground | Pur. Surface | Permanent | Seasonal | Emergency | None | | |
| A | A Well 1 (UMAT 3961/3960/5999) | G,E | 1400 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| A | B Well 2 (UMAT 3962) | G | 900 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| B | A Well 3 (UMAT 3930/3924/5786) | G,E | 1300 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| B | B Well 5 (UMAT 3909) | G | 1100 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| B | C Well 6 (UMAT 3929) | G | 1400 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| C | A Well 8 (UMAT 4005/4010) | H,M | 1600 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |
| D | A Well 9 (UMAT 3965, L11021) | G,E | 1000 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X421 |

*Land Use Codes: (A) Pristine Forest (B) Irrigated Crops (C) Non-Irrigated Crops (D) Pasture (E) Light Industry (F) Heavy Industry (G) Urban-Sewered Area (H) Rural On-Site Sewage Disposal (I) Urban On-Site Sewage Disposal (J) Rangeland (K) Managed Forest (L) Commercial (M) Recreational Use

List current operational patterns for all sources (e.g., Well 1 used continuously @ 100 gpm; Wells 2 & 3 used 6 hours/day; Well 1 used 30% of time & Well 2 used 70%; alternate use of Creek A & Creek B every 2 weeks; etc.). Be as specific as possible, and attach water use records if available.

System primarily uses wells 9&6. Wells 2&5 are backups. Wells 1,3,&8 are not used regularly but are exercised monthly. Wells 1,3,5&6 have entrained air in water, so they are pumped to reservoir to relieve air.

- Yes No
- Does the water system have water rights for all sources? (not required) _____
- Has a Source Water Assessment been completed by DWP or DEQ? June 2005
- Delineation (include date) or USGS Location Map (name and number) attached/on file? Milton-Freewater
Date of delineation or last update to delineation: _____ (N/A)
- Have there been any modifications to the existing wells(s) or spring(s), e.g., deepened, change in screened interval, springbox reconstruction: Describe below: _____
- Have there been any new high-use wells, e.g., irrigation, municipal, industrial, etc., added within 1 mile of the existing source(s)? Provide direction and distance from system's well or spring and estimate use. _____

Comments: _____

Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2 2

| | | | | | | | | | | | | |
|-------------|--------|----|--------|----|--------|----|--------|----|--------|----|--------|----|
| Source ID#: | A | A | A | B | B | A | B | B | B | C | C | A |
| Well Name: | Well 1 | | Well 2 | | Well 3 | | Well 5 | | Well 6 | | Well 8 | |
| | Yes | No | Yes | No | Yes | No | Yes | No | Yes | No | Yes | No |

Well Log on File:

| | | | | | | | | | | | |
|--------------------------------------|--|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| Wellhead Construction | Depth of Well (ft.)..... | 656 | 902 | 596 | 502 | 952 | 1051 | | | | |
| | Depth of Grout Seal (ft.) | 84 | 99 | 105 | unk | unk | 78 | | | | |
| | Year of Installation (yr.) | 1937 | 1944 | 1946 | 1936 | 1950 | 1965 | | | | |
| | Casing Diameter (in.) | 12 | 16 | 16 | 12 | 12 | 16 | | | | |
| | • Sanitary Seal & Casing Watertight..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Screened Vent..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Wellhead Protected from Flooding..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Well Meets Setbacks from Hazards..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Water Level Device..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Wellhead Terminates Above Grade..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Control Building | Concrete Slab Around Casing..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Casing Height Above Slab (in.) | 24 | 24 | 24 | 24 | 24 | 24 | | | | |
| | Pitless Adapter..... | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| | Protective Housing..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Flowmeter..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Pressure Gauge..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Pump to Waste Piping..... | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Raw Sample Tap..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Treated Sample Tap..... <input type="checkbox"/> N/A | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Heated/Lighted..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Pump Equipment | Floor Drain..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Pump Removal Provision..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Check Valve..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Air/Vacuum Relief..... | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Pump Type*..... | VT | VT | VT | VT | VT | VT | | | | |
| | Pump Setting..... | unk | unk | unk | unk | unk | unk | | | | |
| | Discharge Pressure (psi)..... | unk | unk | unk | 95 | unk | unk | | | | |
| | Horsepower (hp)..... | 200 | 250 | 200 | 150 | 250 | 400 | | | | |
| | Bearing Lubrication (FG oil/water) | W | O | O | W | W | W | | | | |
| | Pumping Capacity (gpm)..... | 1400 | 900 | 1300 | 1100 | 1400 | 1600 | | | | |
| Static Water Level (swl) (ft.) | 228 | 214 | 185 | 177 | 233 | 235 | | | | | |
| SWL Date..... | 01/09 | 01/09 | 01/09 | 01/09 | 01/09 | 01/09 | | | | | |

* Pump Types: (VT) Vertical Turbine (SU) Submersible (CE) Centrifugal (SJ) Shallow Jet (DJ) Deep Jet (OT) Other

Comments: Well 2 has back-up power supply. If necessary, would have ability to provide water to whole town. Chevron GST ISO 100 oil used for lube, NSF approved

Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2 2

Source ID#: D A
Well Name: Well 9

Well Log on File: Yes No Yes No Yes No Yes No Yes No Yes No

Wellhead Construction

- Depth of Well (ft.).....
- Depth of Grout Seal (ft.)
- Year of Installation (yr.)
- Casing Diameter (in.)
- Sanitary Seal & Casing Watertight.....
- Screened Vent.....
- Wellhead Protected from Flooding.....
- Well Meets Setbacks from Hazards.....
- Water Level Device.....
- Wellhead Terminates Above Grade.....
- Concrete Slab Around Casing.....
- Casing Height Above Slab (in.)
- Pitless Adapter.....
- Protective Housing.....

| | | | | | | | | | | | | |
|-------------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| 918 | | | | | | | | | | | | |
| 290 | | | | | | | | | | | | |
| 1951 | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| --- | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Control Building

- Flowmeter.....
- Pressure Gauge.....
- Pump to Waste Piping.....
- Raw Sample Tap.....
- Treated Sample Tap..... N/A
- Heated/Lighted.....
- Floor Drain.....
- Pump Removal Provision.....
- Check Valve.....
- Air/Vacuum Relief.....

| | | | | | | | | | | | | |
|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Pump Equipment

- Pump Type*.....
- Pump Setting.....
- Discharge Pressure (psi).....
- Horsepower (hp).....
- Bearing Lubrication (FG oil/water)
- Pumping Capacity (gpm).....
- Static Water Level (swl) (ft.)
- SWL Date.....

| | | | | | | | | | | | | |
|-------|--|--|--|--|--|--|--|--|--|--|--|--|
| SU | | | | | | | | | | | | |
| unk | | | | | | | | | | | | |
| unk | | | | | | | | | | | | |
| 200 | | | | | | | | | | | | |
| W | | | | | | | | | | | | |
| 1000 | | | | | | | | | | | | |
| 306 | | | | | | | | | | | | |
| 01/09 | | | | | | | | | | | | |

* Pump Types: (VT) Vertical Turbine (SU) Submersible (CE) Centrifugal (SJ) Shallow Jet (DJ) Deep Jet (OT) Other

Comments: Well 9 has an L tag: L11021. This well also pumps to the south reservoir. Recirculating water is kept flowing through a one-inch line to keep the water from going stagnant.

Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2 2

| No #. | Disinfection Method* | Location | Disinfection Source Water | Residual Maintenance | Proportional to Flow | Dosage Recorded |
|-------|----------------------|-------------------------|---------------------------|-------------------------------------|-------------------------------------|--------------------------|
| 1-7 | Sodium Hypochlorite | all well head locations | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

*Chlorine Gas, Sodium Hypochlorite, On-site Generated Sodium Hypochlorite, Calcium Hypochlorite, Chloramines, Ozone, UV, Mixed-Oxidants, Other

Yes / No

- Is a DPD type test kit used?
- Are residuals recorded as required?
Distribution: Daily # samples: 1 Other: _____
- Entry Point (sw only):** Daily # samples: _____ Continuous if > 3300 pop
- If chlorinating for residual maintenance only, are raw water coliform samples taken? How often? _____

Yes / No

- Chlorine gas:**
- Separate room for gas storage and feeder?
 - Fan with on/off switch outside?
 - Vent located next to the floor?
 - Door with a window?

Yes / No

- Gas cylinders properly secured?
- Door that opens out
- Self-contained breathing apparatus?
- Air scrubber system?

Yes / No

- UV Light**
- Plan Review Approval?
 - Does all water contact UV (no bypass)?

Yes / No

- Is lamp sleeve cleaned?
- Is lamp replaced annually?
- Intensity sensor with alarm or shut-off?

CT Evaluation

Disinfection requirement (check one): (sw) 1.0 log inactivation giardia (sw) 0.5 log inactivation giardia
 (gw) 30 minutes contact time (gw) 4.0 log inactivation viruses

Maximum demand flow: _____

Effective volume calculation: (at lowest water level) _____

Minimum contact time: (estimated) _____

Yes / No

- Does contact chamber have effluent flow meter or adequate alternative?
If no, how is peak flow determined for CT? _____
 - Has tracer study been conducted or adequate alternative?
Tracer Study Date: _____ Demand flow: _____
Volume used: _____ Results: _____ minutes
- Describe alternate method to determine contact time: _____
- Range of chlorine residual at first user: _____

Yes / No

- (SW only) Are PH, Temperature, and chlorine residual measured daily at first user? _____
- (SW only) Are CT values being calculated correctly? _____
- Are CT values met at all times? _____

Comments: _____

Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2 2

| Number | Name | Tank Type* | Tank Material | Year Built | Volume (gal.) |
|--------|------------------------|------------|---------------|----------------------|------------------|
| 1 | North Zone/Golf Course | G | Steel | 1960 | 2,000,000 |
| 2 | Middle Zone/SW 8th | G | Steel | 1956 | 1,000,000 |
| 3 | South Zone/Hwy 11 | G | Steel | 1998 | 2,000,000 |
| | | | | Total Volume: | 5,000,000 |

* (G) Ground (E) Elevated (P) Pressure

| | | Reservoir Number: 1 | | 2 | | 3 | | | | | |
|-------------------------------|---|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| Reservoir Features | | Yes | No | Yes | No | Yes | No | Yes | No | Yes | No |
| Hatch | • Locked | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Watertight | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Shoebox type lid (curbing) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Features | Drain to Daylight | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Overflow | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Flap Valve (on drain and/or overflow) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Screened Vent | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Water Level Gauge | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Bypass Piping | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Fence/Gate | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Cathodic Plates Watertight | <input checked="" type="checkbox"/> | N/A | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Alarm for High/Low Levels | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Maintenance | Exterior in Good Condition | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Approved Interior Coating | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Annual Inspection | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Cleaning Schedule | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Continuously Disinfected • (redwood only) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Plumbing Configuration | Separate Inlet/Outlet | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Baffling | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Used for Contact Time | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

| Hydropneumatic Tank | | Number: | | | | Comments | |
|----------------------------|-----------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|---|--|
| Hydropneumatic Tank | Used for Contact Time | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | South Reservoir kept at 1/2 full. Cleaning schedule is based on annual inspections. | |
| | Accessible for Maintenance | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Separate Inlet/Outlet | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Bypass Piping | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Access Port | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Drain | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Pressure Relief Device with Gauge | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Air Blow Off Valve | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Air Bladder/Diaphragm | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| | Valve for Adding Air | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | |
| Water Level Sight Glass | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | | | |

Name of System: Milton-Freewater, City of PWS ID#: 41 0 0 5 2 2

Service Area and Facility Map

Yes No

Does the system have a Service Area and Facility Map with the following features:

- | | |
|---|---|
| <input checked="" type="checkbox"/> Booster Pumps | <input checked="" type="checkbox"/> Sources-wells & withdrawal points |
| <input type="checkbox"/> Pressure Reducing Valves | <input checked="" type="checkbox"/> Storage Facilities (reservoirs) |
| <input checked="" type="checkbox"/> Pressure Zones | <input type="checkbox"/> Treatment Facilities |
| <input checked="" type="checkbox"/> Sampling Points | <input checked="" type="checkbox"/> Water Lines (including size and material) |

Distribution Data

Yes No

● System pressure >20 psi? pressure ranges from ~58 psi to 70 psi

System metered? (What %?) 100%

Water system leakage <10%? 8-9%

Waterline depth > 30"? 36"-72"

Piping looped? few dead-end lines

Hydrants or adequate blowoffs on all dead ends?

Routine flushing? (How often?) once a year

Adequate valving?

Routine valve turning? once a year

Comments

Comments:

Cross Connection Program (Community Systems Only)

Yes No

● Ordinance or enabling authority?

List of installed devices?

● Are devices tested annually?

● Certified inspector
(if serving more than 300 connections)? Rob Carter

Comments

Comments:

Booster Pumps

| Number | Name (location) | Deficiencies Noted or Comments | HP | GPM | Aux. Power | |
|--------|------------------|--------------------------------|-----|-----|--------------------------|-------------------------------------|
| | | | | | Yes | No |
| 1 | Well #9 building | pumps water to south reservoir | 50 | | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2 | Well #9 building | pumps water to south reservoir | 100 | | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| | | | | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | | <input type="checkbox"/> | <input type="checkbox"/> |

Comments:

Name of System: Milton-Freewater, City of

PWS ID#: 41 0 0 5 2

| Contaminant | N/A | Frequency | Next Tests Due |
|-------------------------------------|-------------------------------------|---------------------------|-------------------------|
| Coliform Bacteria..... | <input type="checkbox"/> | 7/month | on-going |
| Nitrate..... | <input type="checkbox"/> | once/year | 2009 |
| Arsenic..... | <input type="checkbox"/> | once/every 3 years | 2011 |
| Inorganic Chemicals (sw) | <input type="checkbox"/> | once/every 9 years | 2011 |
| Inorganic Chemicals (gw) | <input checked="" type="checkbox"/> | --- | --- |
| SOC's..... | <input type="checkbox"/> | twice/every 3 years | 2011 (consecutive qtrs) |
| VOC's (sw) | <input type="checkbox"/> | once/every 3 years | 2011 |
| VOC's (gw) | <input checked="" type="checkbox"/> | --- | --- |
| Radiologicals..... | <input type="checkbox"/> | see schedule below | --- |
| Asbestos..... | <input type="checkbox"/> | once/every 9 years | Summer 2011 |
| TTHM's and HAA5's..... | <input type="checkbox"/> | four/every 3 years | Summer 2010 |
| Lead and Copper, # Sites: <u>20</u> | <input type="checkbox"/> | every 3 years | Summer 2010 |
| TOC..... | <input checked="" type="checkbox"/> | --- | --- |
| Turbidity..... | <input checked="" type="checkbox"/> | --- | --- |
| Source Water Coliform..... | <input checked="" type="checkbox"/> | --- | --- |
| Other: (Specify) | <input checked="" type="checkbox"/> | --- | --- |

Yes No ● Is all required monitoring current?

Comments:

Yes No Has the system experienced chemical (last 5 years) or bacteriological (last 2 years) detections?
If yes, what contaminant and when?

● Have all MCL violations been addressed?
 Does the system have any monitoring reductions granted? Explain: HAA5&TTHM - every 3 years, Lead & Copper - every 3 years, IOC's - every 9 years

● Does the system have a written coliform sampling plan?
 Does the plan include: **Yes No**

| | | | | | |
|-------------------------------------|--------------------------|------------------------|--------------------------|-------------------------------------|--------------------|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Brief narrative | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Rotation schedule? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Distribution map? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Repeat locations? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Sample site locations? | | | |

Where in the system are the monitoring sites for TTHM and HAA5: (Not required)
 Are TTHM and HAA5 samples taken at location of maximum residence time?

Comments: Radiological schedule

| RAD | EP-A | EP-B | EP-C | EP-D |
|----------------|------|------|------|------|
| Gross Alpha | 2015 | 2015 | 2015 | 2015 |
| Radium 226/228 | 2015 | 2012 | 2012 | 2012 |
| Uranium | 2012 | 2012 | 2015 | 2012 |

Name of System: Milton-Freewater, City of

PWS ID#:

| | | | | | | |
|---|---|---|---|---|---|---|
| 4 | 1 | 0 | 0 | 5 | 2 | 2 |
|---|---|---|---|---|---|---|

Management Operations

- Does system have an operation and maintenance manual?
 • Does system have an emergency response plan?

Operator Certification

Requirements for system: WT: _____ WD: 2

| Name | Certification Number | WT Level | WD Level | FE | Small System |
|-------------------------------------|----------------------|----------|----------|--------------------------|--------------------------|
| DRC:*David Bradshaw see attached | 1845 | 2 | 2 | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> |

*DRC= direct responsible charge. Attach additional sheets if necessary to list all certified personnel.

Yes No

- Is DRC identified?
 • Is DRC certified at appropriate level?
 • Does system have written operating protocols for other operators?

If DRC is a Contract Operator:

Yes No

- Does DWP have contract on file?

How does contract operator work with system: _____

Plan Review/Master Plan

Yes No

- Have all major modifications (since 8/21/81) been approved by DWP?
 Does system have a current plan review exemption for water main extensions?
 • Does the system have a current (<20 yr. old) master plan? (Not required if < 300 connections)
 What year was the plan completed?
 Does the master plan include a water conservation plan?

Compliance Status

Yes No

- Is water system in compliance (all orders resolved and not a significant non-complier)?
 How many violations has the system had in the past two years.
 • Does the system issue Public Notice for Violations as required?

Other

- Has a capacity assessment been completed by DWP?
 If yes, list deficiencies noted:

- Are consumer confidence reports sent to users each year?

Comments: There is no current Master Plan on file. Anderson-Perry is currently updating Master Plan.

Oregon Department of Human Services

Drinking Water Program**Water System #: OR4100522
MILTON-FREEWATER, CITY OF***Certification Level Required*

Distribution: 2

Treatment: None

Filtration: None

Licensed Operators and their certification levels

| Cert Number | Name | Distribution Level | Is DRC* Distribution | Treatment Level | Is DRC* Treatment | Filtration Endorsement | License Expires |
|--------------------|------------------------|---------------------------|-----------------------------|------------------------|--------------------------|-------------------------------|--------------------------|
| D-1790 | Scott D. Amon | 1 | | | | | 12/31/2009 |
| D-1827 | Steve P. Birdwell, Sr. | 2 | | | | | 12/31/2009 |
| T-1845 D-1845 | David L. Bradshaw | 2 | DRC Dist | 2 | | | 12/31/2009 12/31/2009 |
| D-6509 | Murdeth S. Brannan | | | | | | 12/31/2006 |
| D-6511 | Robin W. Burrowes | | | | | | 12/31/2006 |
| D-6558 | David G. Robertson | 1 | | | | | 12/31/2009 |
| D-6559 | Emilio A. Sandoval | 1 | | | | | 12/31/2009 |
| D-6275 | Ken A. Weis | 2 | | | | | 12/31/2009 |
| D-6560 | Richard L. Worden | 1 | | | | | 12/31/2009 |

*Direct Responsible Charge

**Contract Operator

***Only Operators with a current certification will appear.

Distribution Grade 2

| EPA Rule | Requirements |
|--|---|
| 333-061-0235 OPERATOR REQUIREMENTS LEVELS 1-4 | HS/GED and 3 years experience, OR HS/GED and 1 year relevant post-high school education and 2 years experience |

For further information on this public water system click on the area of interest below.



Oregon

Theodore R. Kulongoski, Governor

Department of Human Services

Health Services

Drinking Water Program

700 SE Emigrant, Rm. 240

Pendleton, OR 97801

(541) 276-8006

FAX (541) 276-4778

April 27, 2004

Howard Moss
City of Milton-Freewater
P.O. Box 6
Milton-Freewater, Oregon 97862

Re: Sanitary Survey of the City of Milton-Freewater, PWS ID: 4100522

Please thank Scott for his time and assistance in performing the sanitary survey. I have enclosed a copy of the survey report for your records. The report is based on information collected during the April 20th site visit. Please review the report and let me know if you find any errors.

The following deficiencies need to be addressed to meet public water system standards:

- An emergency response plan must be developed by December 31, 2004. I have enclosed a handout that summarizes the requirements. More detailed instructions are available on the Drinking Water Program website: <http://www.ohd.hr.state.or.us/dwp/erc.cfm> If you do not have internet access or would like a hard copy let me know.
- An Operations and Maintenance manual must be developed. There is information about this on the back of the emergency response plan handout.
- A flap valve needs to be installed on the 8th Street reservoir overflow pipe.

Monitoring:

- To be considered complete, the City's coliform sampling plan needs to include the following elements:
 - a map of the distribution system showing routine and repeat sample sites
 - a narrative description of the plan
 - a sample siting plan and maintenance program that identifies routine and repeat sampling sites and a rotation schedule. I have enclosed a Pipeline article that goes into more detail.

"Assisting People to Become Independent, Healthy and Safe"
An Equal Opportunity Employer

Sanitary Survey Deficiency Summary
 OHU Drinking Water Program Sanitary Survey

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

00522

Operator/Contact: HOWARD MOSS

County: UMATILLA

| Yes No | | Date to be Corrected | Date Corrected |
|--|---|----------------------|----------------|
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Surface Source Deficiencies | | |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Well Construction Deficiencies | | |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Spring / Other Deficiencies | | |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Disinfection Deficiencies | | |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Treatment Deficiencies | | |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | Storage / Pressure Tank Deficiencies <u>NO FLAP VALVE ON 8TH ST. RESERVOIR OVERFLOW</u> | | |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Distribution Deficiencies | | |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | Monitoring Deficiencies <u>ASBESTOS</u> | | |
| <input type="checkbox"/> <input checked="" type="checkbox"/> | Management Deficiencies <u>NO EMERGENCY RESPONSE PLAN / O&M MANUAL</u> | | |

Comments: _____

Surveyor: BILL GOSS

Date of Survey: 4/20/04

Inventory & Narrative
C. Drinking Water Program Sanitary Surve,

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 5 | 2 | 2 |
|---|---|---|---|---|

Inventory

Date of Survey: 4/20/04

County: UMATILLA

- Type**
- Community (C)
 - Non-Transient non-community (P)
 - Transient non-community (N)
 - State-regulated (S)

Size

Population: 6500

Connections: 2400

Service Chars: R I

Ownership: 4

Season

All year Seasonal

Begins: Ends:

Coliform Sampling

Period: Monthly Quarterly

Samples Required: 7

License

Not Lic. HD Ag.

Responsible Agency

State County Dept. of Ag.

Mailing Address:

Contact Name / Phone #: HOWARD MOSS 541-938-5531 x8271

Street Address: P.O. Box 6

City, State, Zip: MILTON-FREEWATER OR 97862

Legal/Owner Address:

Contact Name / Phone #: HOWARD MOSS 541-938-5531 x8271

Street Address: 722 S MAIN

City, State, Zip: MILTON-FREEWATER OR 97862

Supply Address:

Contact Name / Phone #: SAME AS ABOVE

Street Address: _____

City, State, Zip: _____

Emergency Systems available:


Name: N/A PWS ID#: _____

Name: _____ PWS ID#: _____

Name: _____ PWS ID#: _____

Narrative:


The City has seven deep basalt wells for sources. The wells are used in rotation for 1 to 3 week periods based on energy audit recommendations. Wells 1 and 8 are not used as regular sources but are exercised once a month. Wells 3, 5, and 6 pump directly into the 2 MG North Reservoir. Well 2 pumps directly into the 1 MG Middle Reservoir. The 2 MG South Reservoir can be filled by either well 8 or 9. Sodium hypochlorite is injected at each wellhead for residual maintenance. The system is divided into three pressure zones as shown on the attached schematic.



Quadrangle Map

USGS Map Name - Milton-Freewater, Oreg.

USGS Map Number - N4552.5-W11822.5/7.5



North Pressure Zone
 Middle Pressure Zone
 North Zone Reservoir
 (2,000,000 gallons)

WELL #2
 WELL #1


Middle Zone Reservoir
 (1,000,000 gallons)

Well #9

South Zone Reservoir
 (2,000,000 gallons)



Quadrangle Map
USGS Map Name - Bowlus Hill, Oreg.
USGS Map Number - N4552.5-W11815/7.5



Source Information
 OHD Drinking Water Program Sanitary Survey

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

0 0 5 2 2

Entry Points: (Location where water enters distribution and is sampled)

| ID | Name | Source Type | | | | | | Availability | | Treatment Codes | | | |
|----|-------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|--------------------------|--------|-----------------|--------------------------|--------------------------|-------|
| | | Ground | Surface | GWUDI | Pur. Ground | Pur. Surface | Permanent | Seasonal | Bagina | Ends | Emergency | None | |
| A | WELLFIELD (WELLS #1 & #2) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| B | WELLFIELD (WELLS #3, #5 & #6) | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| C | EP FOR WELL #8 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| D | EP FOR WELL #9 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> | |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> | |

Individual Sources contributing at Entry Point:

| ID | Name | Land Use* | Capacity (GPM) | Source Type | | | | | | Availability | | Treatment Codes | |
|-----|----------------------------|-----------|----------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|-------|
| | | | | Ground | Surface | GWUDI | Pur. Ground | Pur. Surface | Permanent | Seasonal | Emergency | | None |
| A A | WELL #1 | G, E | 1400 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| A B | WELL #2 | G | 900 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| B A | WELL #3 | G, E | 1300 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| B B | WELL #5 | G | 1100 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| B C | WELL #6 | G | 1400 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |
| C A | WELL #8 - COUSE CREEK ROAD | H, M | 1600 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X 421 |

*Land Use Codes: (A) Pristine Forest (B) Irrigated Crops (C) Non-Irrigated Crops (D) Pasture (E) Light Industry (F) Heavy Industry (G) Urban-Sewered Area (H) Rural On-Site Sewage Disposal (I) Urban On-Site Sewage Disposal (J) Rangeland (K) Managed Forest (L) Commercial (M) Recreational Use

Comments: (How and when sources are used, etc.) SYSTEM ROTATES SOURCES.

WELLS #1 AND #8 ARE NOT USED REGULARLY, BUT ARE EXERCISED MONTHLY.

WELLS #3, #5, #6 HAVE AIR IN WATER SO ARE PUMPED TO RESERVOIR TO LET AIR COME OUT OF THE WATER.

Yes No

- Does the water system have water rights for all sources? (Not required)
- USGS Location Map (name and number) attached? MILTON-FREEWATER, BOWLUS HILL
- Has a Source Water Assessment been completed by OHD or DEQ?

Yes No

- Delineation attached/on file?
- Hydrogeologic/sensitivity analysis on file?
- Highly sensitive characteristics? Explain: _____

Have there been any changes since the original Source Water Assessment? Explain: _____

Comments on Source Water Assessment: _____

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

0 0 5 2 2

Entry Points: (Location where water enters distribution and is sampled)

| ID | Name | Source Type | | | | | | Availability | | Treatment Codes | |
|----|------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------|--------|--------------------------|--------------------------|
| | | Ground | Surface | GWUDI | Pur. Ground | Pur. Surface | Permanent | Seasonal | Begins | Ends | Emergency |
| A | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> |
| | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | / | / | <input type="checkbox"/> | <input type="checkbox"/> |

Individual Sources contributing at Entry Point:

| ID | Name | Land Use* | Capacity (GPM) | Source Type | | | | | | Availability | | Treatment Codes |
|-----|---------|-----------|----------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|--------------------------|--------------------------|-----------------|
| | | | | Ground | Surface | GWUDI | Pur. Ground | Pur. Surface | Permanent | Seasonal | Emergency | |
| D A | WELL #9 | G,E | 1000 | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | X4Z1 |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | |

*Land Use Codes: (A) Pristine Forest (B) Irrigated Crops (C) Non-irrigated Crops (D) Pasture (E) Light Industry (F) Heavy Industry (G) Urban-Sewered Area (H) Rural On-Site Sewage Disposal (I) Urban On-Site Sewage Disposal (J) Rangeland (K) Managed Forest (L) Commercial (M) Recreational Use

Comments: (How and when sources are used, etc.) _____

Yes No

Does the water system have water rights for all sources? (Not required) _____

USGS Location Map (name and number) attached? _____

Has a Source Water Assessment been completed by OHD or DEQ? _____

Yes No

Delineation attached/on file? _____

Hydrogeologic/sensitivity analysis on file? _____

Highly sensitive characteristics? Explain: _____

Have there been any changes since the original Source Water Assessment? Explain: _____

Comments on Source Water Assessment: _____

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

00522

Source ID: AA AB BA BB BC CA

| | | Yes | No | Yes | No | Yes | No | Yes | No | Yes | No | Yes | No |
|-----------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|--------------------------|
| Well Log on File | | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Wellhead Construction | Depth of Well (ft.) | <u>656</u> | | <u>902</u> | | <u>596</u> | | <u>502</u> | | <u>952</u> | | <u>1051</u> | |
| | Depth of Grout Seal (ft.) | <u>84</u> | | <u>99</u> | | <u>105</u> | | <u>UNK</u> | | <u>UNK</u> | | <u>78</u> | |
| | Year of Installation (yr.) | <u>1937</u> | | <u>1944</u> | | <u>1946</u> | | <u>1936</u> | | <u>1950</u> | | <u>1965</u> | |
| | Casing Diameter (in.) | <u>12</u> | | <u>16</u> | | <u>16</u> | | <u>12</u> | | <u>12</u> | | <u>16</u> | |
| | • Sanitary Seal & Casing Watertight | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Screened Vent | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Wellhead Protected from Flooding | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Well Meets Setbacks from Hazards | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Water Level Device | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Wellhead Terminates Above Grade | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Concrete Slab Around Casing | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Casing Height Above Slab (in.) | <u>24</u> | | <u>24</u> | | <u>24</u> | | <u>24</u> | | <u>24</u> | | <u>24</u> | |
| Pitless Adapter | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |
| • Protective Housing | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Control Building | Flowmeter | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Pressure Gauge | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Pump to Waste Piping | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Raw Sample Tap | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | • Treated Sample Tap | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Heated/Lighted | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Floor Drain | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Pump Removal Provision | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Check Valve | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | Air/Vacuum Relief | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Pumping Equipment | Pump Type* | <u>VT</u> | | <u>VT</u> | | <u>VT</u> | | <u>VT</u> | | <u>VT</u> | | <u>VT</u> | |
| | Pump Setting (ft.) | | | | | | | | | | | | |
| | Discharge Pressure (psi) | | | | | | | <u>95</u> | | | | | |
| | Horsepower (hp) | <u>200</u> | | <u>250</u> | | <u>200</u> | | <u>150</u> | | <u>250</u> | | <u>400</u> | |
| | Bearing Lubrication (FG oil/water) | <u>W</u> | | <u>0</u> | | <u>0</u> | | <u>W</u> | | <u>W</u> | | <u>W</u> | |
| | Pumping Capacity (gpm) | <u>1400</u> | | <u>900</u> | | <u>1300</u> | | <u>1100</u> | | <u>1400</u> | | <u>1600</u> | |
| | Static Water Level (ft.) | <u>228</u> | | <u>200</u> | | <u>182</u> | | <u>177</u> | | <u>160</u> | | <u>235</u> | |

*Pump Types: (VT) Vertical Turbine (SU) Submersible (CE) Centrifugal (SJ) Shallow Jet (DJ) Deep Jet (OT) Other

Comments: AB - WELL #2 CASED TO 99 FT., SEALED TO 99 FT AS SEEN ON VIDEO.

BC - WELL #6 CASED TO 61 FT.

CHEVRON GST 150 CCB OIL USED FOR LUBE, NSF APPROVED.

Source: Well Information

CHD Drinking Water Program Sanitary Survey

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

00522

Source ID: DA

Well Log on File Yes No

| | | | | | | | |
|-----------------------|-------------------------------------|-------------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| Wellhead Construction | Depth of Well (ft.) | 918 | | | | | |
| | Depth of Grout Seal (ft.) | 290 | | | | | |
| | Year of Installation (yr.) | 1951 | | | | | |
| | Casing Diameter (in.) | 18 | | | | | |
| | • Sanitary Seal & Casing Watertight | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Screened Vent | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Wellhead Protected from Flooding | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Well Meets Setbacks from Hazards | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Water Level Device | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Wellhead Terminates Above Grade | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Concrete Slab Around Casing | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

| | | | | | | | |
|------------------|--------------------------------|-------------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| Control Building | Casing Height Above Slab (in.) | 24 | | | | | |
| | Pitless Adapter | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Protective Housing | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Flowmeter | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Pressure Gauge | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Pump to Waste Piping | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Raw Sample Tap | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | • Treated Sample Tap | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Heated/Lighted | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | Floor Drain | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

| | | | | | | |
|-------------------|------------------------------------|------|--|--|--|--|
| Pumping Equipment | Pump Type* | SU | | | | |
| | Pump Setting (ft.) | | | | | |
| | Discharge Pressure (psi) | | | | | |
| | Horsepower (hp) | 200 | | | | |
| | Bearing Lubrication (FG oil/water) | W | | | | |
| | Pumping Capacity (gpm) | 1000 | | | | |
| | Static Water Level (ft..) | 300 | | | | |

*Pump Types: (VT) Vertical Turbine (SU) Submersible (CE) Centrifugal (SJ) Shallow Jet (DJ) Deep Jet (OT) Other

Comments: DA WELL #9 PUMPS TO WASTE FOR 6-7 MINUTES UPON STARTING UP TO HELP WITH TASTE/ODOR. A ONE-INCH LINE AT WELL #9 RECIRCULATES ~30,000 GAL/DAY FROM SOUTH RESERVOIR FOR TURNOVER IN TANK.

Disinfection

OHD Drinking Water Program Sanitary Survey

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 5 | 2 | 2 |
|---|---|---|---|---|

| # | Disinfection Method* | Location | Disinfection Source Water | Residual Maintenance | Proportional to flow | Dosage Recorded |
|-----|----------------------|----------------|---------------------------|-------------------------------------|-------------------------------------|--------------------------|
| 1-7 | SODIUM HYPOCHLORITE | ALL WELL HEADS | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

*Chlorine Gas, Sodium Hypochlorite, On-Site Generated Sodium Hypochlorite, Calcium Hypochlorite, Chloramines, Ozone, UV, Mixed-Oxidants, Other

Yes No

- Is a DPD type test kit used?
- Is free chlorine residual maintained?
- Are residuals recorded at least daily? Daily Continuous Other _____
- Is protective equipment available?

Type of protective equipment: _____

N/A

Chlorine Gas:

- Separate room for gas storage and feeder?
- Fan with on/off switch outside?
- Vent located next to the floor?
- Door with a window?
- Gas cylinders properly secured?
- Door that opens out?
- Self-contained breathing apparatus?
- An air scrubber system?

| # | | # | | # | |
|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| Yes | No | Yes | No | Yes | No |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

N/A

Disinfection with UV light

Yes No

- Plan Review Approval (P.R. # _____)
- Does all water contact UV (no bypass)
- Is lamp sleeve cleaned

Yes No

- Is lamp replaced annually
- Alarm or shut off

Source Water Classification: Ground Filtered Surface Unfiltered Surface GWUDI
(check all that apply)

CT Evaluation

Disinfection requirement: _____ log removal for giardia viruses OR _____ minutes

Maximum demand flow: _____ gpm, Minimum contact time: _____ minutes

Contact time determined by tracer study or estimated? _____

Range of chlorine residuals at first user: _____

Yes No

- Are CT values met at all times?
- Has disinfection benchmark been established? (Not required)

Comments: RESIDUAL KEPT BETWEEN 0.1-0.3 mg/L

Storage & Pressure Tanks

JHD Drinking Water Program Sanitary Survey

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 5 | 2 | 2 |
|---|---|---|---|---|

| Number | Name | Tank Type* | Tank Material | Year Built | Volume (gal.) |
|--------|--------------------------|------------|---------------|------------|---------------|
| 1 | NORTH ZONE / GOLF COURSE | G | STEEL | 1960 | 2,000,000 |
| 2 | MIDDLE ZONE / SW 8TH | G | STEEL | 1956 | 1,000,000 |
| 3 | SOUTH ZONE / HWY 11 | G | STEEL | 1998 | 2,000,000 |
| | | | | | |

Reservoir Features

* (G) Ground (E) Elevated (P) Pressure

Total Volume = 5,000,000

Reservoir Number

| | | | | |
|---|---|---|--|--|
| 1 | 2 | 3 | | |
|---|---|---|--|--|

Hatch: • Locked

| | | | | |
|--------|--------|--------|--------|--------|
| Yes No | Yes No | Yes No | Yes No | Yes No |
|--------|--------|--------|--------|--------|

- Watertight
- Shoebox type lid (curbing)

| | | | | |
|--|--|--|---|---|
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |

Features:

- Drain to Daylight
- Overflow
- Flap Valve (on drain and/or overflow)
- Screened Vent
- Water Level Gauge
- Bypass Piping
- Fence/Gate
- Cathodic Plates Watertight
- Alarm for high/low levels

TEES INTO DRAIN PIPE

CHECK VALVE

ALL HAVE ELEV. CORROSION CONTROL

| | | | | |
|--|--|--|---|---|
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input checked="" type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> | <input type="checkbox"/> <input type="checkbox"/> |
| <input checked="" type="checkbox"/> <input type="checkbox"/> | | | | |

System: MILTON-FREEWATER CITY OF

PWS ID: 41 0 0 5 2 2

Service Area and Facility Map

Yes No

- Does the system have a Service Area and Facility Map with the following features:
- | | |
|--|---|
| <input checked="" type="checkbox"/> Booster Pumps | <input checked="" type="checkbox"/> Sources-wells & withdrawal points |
| <input type="checkbox"/> Pressure Reducing Valves | <input checked="" type="checkbox"/> Storage Facilities (reservoirs) |
| <input checked="" type="checkbox"/> Pressure Zones | <input type="checkbox"/> Treatment Facilities |
| <input type="checkbox"/> Sampling Points | <input checked="" type="checkbox"/> Water Lines (including size and material) |

Distribution Data

Comments

Yes No

- System pressure >20 psi? N ~70 PSI
- System metered? (what %?) _____
- Water system leakage <10%? _____
- Waterline depth >30"? 36" - 72"
- Piping looped? FEW DEAD-END LINES
- Hydrants or adequate blowoffs on all dead ends? _____
- Routine flushing? (how often?) ONCE/TWICE/YR
- Adequate valving? _____
- Routine valve turning? (how often?) YEARLY

Comments: _____

Cross Connection Program (Community systems only)

Comments

Yes No

- Ordinance or enabling authority? _____
- Testing records current? _____
- Approved devices installed? _____
- Annual summary report sent? _____
- If more than 300 Connections:
- Certified inspector? ROB CARTER
- Complete written program plan? _____

Comments: _____

Booster Pumps

| Number | Name (location) | Deficiencies Noted or Comments | HP | GPM | Aux. Power |
|--------|------------------|--------------------------------|-----|-----|--|
| 1 | WELL #3 BUILDING | PUMPS WATER UP TO SOUTH RES. | 50 | | Y <input type="checkbox"/> N <input checked="" type="checkbox"/> |
| 2 | " " " | " " " " | 100 | | Y <input type="checkbox"/> N <input checked="" type="checkbox"/> |
| | | | | | Y <input type="checkbox"/> N <input type="checkbox"/> |
| | | | | | Y <input type="checkbox"/> N <input type="checkbox"/> |
| | | | | | Y <input type="checkbox"/> N <input type="checkbox"/> |
| | | | | | Y <input type="checkbox"/> N <input type="checkbox"/> |

Comments: _____

Water Quality Monitoring
OHD Drinking Water Program Sanitary Survey

System: MILTON-FREEWATER, CITY OF

PWS ID: 41 00522

| Contaminant | N/A | Frequency | Next Tests Due |
|----------------------------------|--------------------------|-----------|----------------|
| Coliform Bacteria | | | |
| Nitrate | | | |
| Inorganic Chemicals (SW) | <input type="checkbox"/> | | |
| Inorganic Chemicals (GW) | <input type="checkbox"/> | | |
| Arsenic | <input type="checkbox"/> | | |
| SOC's-Regulated | <input type="checkbox"/> | | |
| SOC's-Unregulated (>10,000 pop.) | <input type="checkbox"/> | | |
| VOC's-Regulated | <input type="checkbox"/> | | |
| VOC's-Unregulated (>10,000 pop.) | <input type="checkbox"/> | | |
| Radiological | <input type="checkbox"/> | | |
| Asbestos | <input type="checkbox"/> | | |
| TTHM | <input type="checkbox"/> | | |
| HAA5 | <input type="checkbox"/> | | |
| Lead & Copper | <input type="checkbox"/> | | |
| Turbidity | <input type="checkbox"/> | | |
| Source Water Microbiological | <input type="checkbox"/> | | |

SEE FOLLOWING PAGE

For CT calculations (see CPE).

Yes No
 Is all required monitoring current?

Comments: ASBESTOS SAMPLE PAST DUE

Has the system experienced chemical (last 5 years) or bacteriological (last 2 years) detections? If yes, what contaminant and when? _____

Have all MCL violations been addressed? NO MCL VIOLATIONS

Does the system have any monitoring reductions granted? Explain: LEAD & COPPER, IOC'S

Does the system have a written coliform sampling plan?

Does the plan include:

- | | | |
|-------------------------------------|-------------------------------------|------------------------|
| Yes | No | |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Brief narrative? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Distribution map? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Sample site locations? |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Rotation schedule? |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | Repeat locations? |

Where in the system are the monitoring sites for TTHM and HAA5: (Not required)

- At the location of maximum residence time?
- At area(s) of low concentration of users?
- At areas representing different supply sources?

Comments: TTHM & HAA5 SAMPLES DUE FOR FIRST TIME IN SUMMER 2004. SAMPLE LOCATIONS TO BE DETERMINED.

City of Milton-Freewater Monitoring Schedule
Based on a population of 6,500
PWS ID #4100522

| <u>Contaminant</u> | <u>EP-A Wellfield - Wells #1 & #2</u> <u>Frequency</u> | <u>Next Tests Due</u> |
|-------------------------|---|-----------------------|
| Nitrate | annually | Oct. 2004 |
| Inorganic Chemicals | once every nine years | July 2011 |
| Arsenic | once every 3 years | July 2005 |
| SOC's | 2 consecutive qtrs. every three years | July 2005 |
| VOC's | once every 3 years | July 2005 |
| Radiologicals:* | | |
| Gross Alpha | 4 consecutive quarters | starting Jan. 2005 |
| Combined Radium 226/228 | 4 consecutive quarters | starting Jan. 2005 |
| Uranium | 4 consecutive quarters | starting Jan. 2005 |

| <u>Contaminant</u> | <u>EP-B Wellfield - Wells #3, #5, #6</u> <u>Frequency</u> | <u>Next Tests Due</u> |
|-------------------------|--|-----------------------|
| Nitrate | annually | Oct. 2004 |
| Inorganic Chemicals | once every nine years | July 2011 |
| Arsenic | once every 3 years | July 2005 |
| SOC's | 2 consecutive qtrs. every three years | July 2005 |
| VOC's | once every 3 years | July 2005 |
| Radiologicals:* | | |
| Gross Alpha | 4 consecutive quarters | starting Jan. 2005 |
| Combined Radium 226/228 | 4 consecutive quarters | starting Jan. 2005 |
| Uranium | 4 consecutive quarters | starting Jan. 2005 |

| <u>Contaminant</u> | <u>EP-C Well #8</u> <u>Frequency</u> | <u>Next Tests Due</u> |
|-------------------------|---|-----------------------|
| Nitrate | annually | Oct. 2004 |
| Inorganic Chemicals | once every nine years | Dec. 2011 |
| Arsenic | once every 3 years | Dec. 2005 |
| SOC's | 2 consecutive qtrs. every three years | Dec. 2005 |
| VOC's | once every 3 years | Dec. 2005 |
| Radiologicals:* | | |
| Gross Alpha | 4 consecutive quarters | starting Jan. 2005 |
| Combined Radium 226/228 | 4 consecutive quarters | starting Jan. 2005 |
| Uranium | 4 consecutive quarters | starting Jan. 2005 |

| <u>Contaminant</u> | <u>EP-D Well #9</u> <u>Frequency</u> | <u>Next Tests Due</u> |
|-------------------------|---|-----------------------|
| Nitrate | annually | Oct. 2004 |
| Inorganic Chemicals | once every 9 years | Dec. 2005 |
| Arsenic | once every 3 years | Dec. 2005 |
| SOC's | 2 consecutive qtrs. every three years | Dec. 2005 |
| VOC's | once every 3 years | Dec. 2005 |
| Radiologicals:* | | |
| Gross Alpha | 4 consecutive quarters | starting Jan. 2005 |
| Combined Radium 226/228 | 4 consecutive quarters | starting Jan. 2005 |
| Uranium | 4 consecutive quarters | starting Jan. 2005 |

| <u>Contaminant</u> | <u>Distribution System</u> <u>Frequency</u> | <u>Next Tests Due</u> |
|--------------------|--|-----------------------|
| Coliform Bacteria | 7 per month | Nov. 2003 |
| Asbestos | once every nine years | May 2002 - past due |
| TTHM | 4 samples annually | Summer 2004 |
| HAA5 | 4 samples annually | Summer 2004 |
| Lead & Copper | once every three years | Summer 2004 |

*every 9 years if no detections based on results collected between June 2000 and Dec. 8, 2003
every 6 years if < 1/2 MCL
every 3 years if > 1/2 MCL
quarterly if > MCL

System: MILTON-FREEWATER, CITY OF

PWS ID: 41

00522

Management Operations

Identify management structure of water system staff: CITY COUNCIL / CITY MGR / PW DIRECTOR / WTR SUPERVISOR / CREW.

Yes No

- Do water system revenues pay for operation, maintenance and staffing?
- Do water system revenues go into a reserve fund for capital improvement projects?
- Does system have an operation and maintenance manual?
- Does system have an emergency response plan?

Operator/Cross Connection Certification

Requirements for system: WT WD 2

| Name | Certification Number | Water Treatment Level | Water Distribution Level | Filtration Endorsement | Cross Connection Inspection Number | Backflow Assembly Tester # |
|-----------------------|----------------------|-----------------------|--------------------------|--------------------------|------------------------------------|----------------------------|
| DRC: * DAVID BRADSHAW | 1845 | 2 | 2 | <input type="checkbox"/> | | |
| STEVE BIRDWELL | 1827 | | 2 | <input type="checkbox"/> | | |
| SCOTT AMON | 1790 | | 1 | <input type="checkbox"/> | | |
| KEN WEIS | 6275 | | 2 | <input type="checkbox"/> | | |
| MURDOCH BRANNAN | 6509 | | 1 | <input type="checkbox"/> | | |

*DRC = direct responsible charge. Attach additional sheets if necessary to list all certified personnel.

Yes No

- Is there an operator at required certification level?
- Are CEUs being maintained?

Plan Review/Master Plan

- Have all major modifications (since 8/21/81) been approved by OHD?
- Does system have a current plan review exemption for water main extensions?
- Does the system have a current (<20 yr. old) master plan? (Not required if <300 connections)

What year was the plan completed?

Yes No

- Does the master plan include a water conservation plan?

Compliance Status

- Is water system in compliance (all Administrative Orders and Notices of Violation resolved)?
- How many violations has the system had in the past two years?
- Does the system issue Public Notice for Violations as required?

Other

- Has a capacity assessment been completed by OHD?
If yes, list deficiencies noted: _____

- Are consumer confidence reports sent to users each year?

Comments: MASTER PLAN IS BEING PREPARED BY ANDERSON-PERRY.

UMAT
3965

**STATE ENGINEER
SALEM, OREGON**

Application No. U-403
Permit No. U-373
Well No. 1, Umatilla Canning Co.

UMATILLA CO

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report August 22, 1951

1. Location of well: SW 1/4 of SE 1/4 of Section 12 Twp. 5N Rge. 35 E. W. N.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: Approx. 4000 feet.
4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: feet.
5. Date of beginning drilling or digging: January 11, 1951
6. Date well was completed: June 22, 1951

LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | | Thickness of stratum | |
|---|----------------------------|-----|----------------------|-----|
| | At surface | ft. | ft. | ft. |
| Yellow cement gravel | | 0 | 41 | 41 |
| Broken Basalt & Blue Clay | | 41 | 285 | 285 |
| Medium gray basalt & alternate clay & mud | | 285 | 421 | 421 |
| Broken gray basalt | | 421 | 562 | 562 |
| Black basalt & gray basalt | | 562 | 751 | 751 |
| Medium black basalt - (2ft. Hard black basalt 816-818 ft) | | 751 | 878 | 878 |
| Gray hard basalt | | 878 | 881 | 881 |
| Medium black basalt | | 881 | 894 | 894 |
| Hard black basalt | | 894 | 913 | 913 |
| Remarks: Medium black basalt | | 913 | 918 | 918 |

WELL INFORMATION

8. Diameter of well see below inches. Depth of well 918 feet.
9. Depth at which water was first encountered 90 feet.
10. Water level when completed: 205 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: Some caving - 321 ft to 500 ft.

8. 24" from 0 to 104 ft.
- 20" from 104 to 321 ft.
- 16" from 321 to 690 ft.
- 12" from 690 to 918 ft.

CASING REPORTED
18" φ 0 TO 193'
16" φ 193' TO 296'
(15.25" I. D.)

139-140 ENCRUSTED, SEE PAGE
146-147
183-185 "Big"
POSSIBLE WATER REDUCTION 185' ±
- 191
204 - CASING SEPARATION
STATIC LEVEL 294

SN/35-126A)
UMATILLA Co

RECEIVED

AUG 24 1951

STATE ENGINEER
SALEM, OREGON

PUMP INFORMATION

- 12. Manufacturer of pump: A. D. Cook, Inc.
- 13. Address: Lawrenceburg, Indiana
- 14. Data on name or base plate: Serial No. 13254
Cook Rotation Pump
- 15. Data on pump bowl assembly: TR 5107 12 TR 527
26 12 TR 5280
- 16. Size of pump: 8" Turbine
- 17. Rated capacity: 950 gallons per minute.
- 18. Rated speed: 1765 revolutions per minute.
- 19. Number of stages: 8
- 20. Size of intake pipe: 8"
- 21. Size of discharge pipe: 8"
- 22. Length of intake pipe: 290 feet column, 25 feet bowl assembly, suction and strainer
- 23. Length of discharge pipe: 161.65 ft.
- 24. Suction lift: (difference in elevation between water surface in well and pump) 205 feet
- 25. Discharge lift: (difference in elevation between pump and end of discharge line) Hardly any -- pipe runs slightly downhill
- 26. Depth of pump intake below ground surface: 310 feet.
- 27. Remarks: This pump will be exchanged or worked over to that we can pump between 1400 and 1500 g.p.m. next season.

MOTOR OR ENGINE INFORMATION

- 28. Name of manufacturer: General Electric
- 29. Address: 3111 Schenectady, N. Y.
- 30. Type of motor or engine: Electric Induction Motor
- 31. Data on name or base plate: Model 5K445A1A Service Factor 1.15 at Rated Volts
60 cycles 220/440 volts Type K Code F Frame 445 3 phase 60 cy
FL AMP 181/90.5 FL Speed 1765 No. WQJ6873648 TRYCLAD INDUCTION MOTOR
- 32. Rated horsepower: 75 H.P.
- 33. Rated speed of motor or engine: 1765 revolutions per minute.
- 34. Rated Capacity of Pump (with described motor)

| | | | |
|------------|------------------|------------|-----------------|
| <u>950</u> | <u>g.p.m. at</u> | <u>205</u> | <u>ft. head</u> |
| <u>800</u> | <u>g.p.m. at</u> | <u>300</u> | <u>ft. head</u> |
| <u>700</u> | <u>g.p.m. at</u> | <u>350</u> | <u>ft. head</u> |
| | <u>g.p.m. at</u> | | <u>ft. head</u> |
| | <u>g.p.m. at</u> | | <u>ft. head</u> |
- 35. Remarks: We intend to trade this pump and motor or have it worked over next year (before June 1952) so that we can pump 1400-1500 g.p.m.

RECEIVED

AUG 24 1951

STATE ENGINEER
SALEM, OREGON

5/15-1200

CAPACITY TEST

- 36. Date of test: 8/16 & 8/17, 1951. Temperature of water 60°F. or °C.
- 38. Motor speed during test: From 1250 - 1800 R.P.M.
- 39. Test made by (weir, tank or other means): Weir

| WEIR NO. | WEIR | TOTAL HEAD | #Total lift in feet | Gallons per min. | Feet to water level | Draw- down | Time |
|----------|---------------------|---------------|------------------------|---------------------|------------------------|---------------|-------------------|
| 205 | lbs., Gauge at pump | Total 205 ft. | in. | Static | water level | ft. | M. |
| 215 | lbs., Gauge at pump | Total 215 ft. | in. | 936 | 215 | 10 ft. | 7:15 AM. |
| 244 | lbs., Gauge at pump | Total 244 ft. | in. | 795 | 244 | 39 ft. | 8:30 AM. |
| 266 | lbs., Gauge at pump | Total 266 ft. | in. | 1220 | 266 | 61 ft. | 10:30 AM. |
| 287 | lbs., Gauge at pump | Total 287 ft. | in. | 1407 | 287 | 82 ft. | 12:30 PM. |
| 287 | lbs., Gauge at pump | Total 287 ft. | in. | 1407 | 287 | 82 ft. | 5:30 PM. |
| 270 | lbs., Gauge at pump | Total 270 ft. | in. | 1220 | 270 | 65 ft. | 7:30 PM. |
| 285 | lbs., Gauge at pump | Total 285 ft. | in. | 1407 | 285 | 80 ft. | 9:00 PM. |
| 285 | lbs., Gauge at pump | Total 285 ft. | in. | 1407 | 285 | 80 ft. | 12:00 M. Midnight |
| 285 | lbs., Gauge at pump | Total 285 ft. | in. | 1407 | 285 | 80 ft. | 4:00 AM. 8/17 |
| 270 | lbs., Gauge at pump | Total 270 ft. | in. | 1312 | 270 | 65 ft. | 4:10 AM. |
| 263 | lbs., Gauge at pump | Total 263 ft. | in. | 1220 | 263 | 58 ft. | 4:20 AM. |
| 264 | lbs., Gauge at pump | Total 264 ft. | in. | 1220 | 264 | 59 ft. | 6:00 AM. |
| 295 | lbs., Gauge at pump | Total 295 ft. | in. | 1501 | 295 | 90 ft. | 6:10 AM. |
| 295 | lbs., Gauge at pump | Total 295 ft. | in. | 1501 | 295 | 90 ft. | 6:18 AM. |
| 209 | lbs., Gauge at pump | Total ft. | in. | (Previous) | ft. | ft. | 6:23 AM. |
| | lbs., Gauge at pump | Total ft. | in. | | ft. | ft. | M. |

* Difference in elevation between water level in well and outlet of pump test line.

- ° Distance from ground level to water surface in well.
- ∓ Distance water level is lowered during time interval.
- + Hour and minute at which observation was made.

- 11. Installation will work efficiently under normal head of 325 ft.
- 12. Water is discharged into: Main lines, Umatilla Canning Company Plant.
- 13. Was water lowered to pump intake by test? Yes - deliberately.
- 14. Remarks: Didn't have enough column on to go beyond 1501 P.M. on test.
Had only 90 feet of column beyond static water level of 205 feet.
Well recovered to static water level from 6:18 a.m. to 6:23 a.m. 8/17/51.
Recovery rate of 5 minutes.

GENERAL INFORMATION

- 15. Name of contractor or other party who drilled or dug well: A. A. Durand & Son
Address: 115 Rees Avenue, Walla Walla, Washington
- 16. Pump and motor were installed by: Pump, Pipe, & Power Co., Portland, Oregon
Address: _____
- 17. Capacity test was made by: A. A. Durand & Son, Walla Walla, Washington
Address: _____
- 18. General remarks: _____

STATE OF OREGON
WATER SUPPLY WELL REPORT
(as required by ORS 537.765)

AUG 07 1998

WATER RESOURCES DEPT.
SALEM, OREGON

(START CARD) # 097107

Instructions for completing this report are on the last page of this report.

(1) OWNER:
Name City Milton - Free Water
Address P.O. Box 6 222 S. Main
City Milton-Freewater State Ore. Zip 97167

(2) TYPE OF WORK
 New Well Deepening Alteration (repair/recondition) Abandonment

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Auger
 Other Reverse Rotary

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Livestock Other

(5) BORE HOLE CONSTRUCTION:
Special Construction approval Yes No Depth of Completed Well 290'
Explosives used Yes No Type _____ Amount _____

HOLE SEAL
Diameter From To Material From To Sacks or pounds
18" #2 290 gravel #2 290 2 yds
Packer set at 290' to 18" x 12"
How was well placed: Method A B C D E
 Other _____
Backfill placed from _____ ft. to _____ ft. Material _____
Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING LINER:

| Diameter | From | To | Gauge | Material | | | |
|------------|-------------|-------------|-------------|-------------------------------------|--------------------------|-------------------------------------|--------------------------|
| | | | | Steel | Plastic | Welded | Threaded |
| <u>12"</u> | <u>#2</u> | <u>462'</u> | <u>.315</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <u>10"</u> | <u>462'</u> | <u>692'</u> | <u>.365</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Liner: _____

(7) PERFORATIONS/SCREENS:
 Perforations Method Factory cut
 Screens Type _____ Material _____
From To Slot size Number Diameter
462' 692' 5/16" 40 4 1/4" 10"
40 slots per foot

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Baller Air Flowing Artesian
Yield (gpm) Drawdown Drill stem at Time
None Done 1 hr.

Temperature of water _____ Depth Artesian Flow Found _____
Was a water analysis done? Yes By whom _____
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
Depth of strata: _____

(9) LOCATION OF WELL by legal description:
County Umatilla Latitude _____ Longitude _____
Township 5 N or S Range 35 E or W
Section 12 SW 1/4 SE 1/4
Tax Lot 1104 Lot _____ Block _____ Subdivision _____
Street Address of Well (or nearest address) Hwy 11

(10) STATIC WATER LEVEL:
292 ft. below land surface. Date 7-16-98
Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
Depth at which water was first found _____

| From | To | Estimated Flow Rate | SWL |
|--------------------|----|---------------------|-----|
| <u>No Drilling</u> | | | |

(12) WELL LOG:
Ground Elevation _____

| Material | From | To | SWL |
|---|------|----|-----|
| <u>Did NO Drilling just installed liner in existing well.</u> | | | |

Date started 7-10-98 Completed 7-28-98

(unbonded) Water Well Constructor Certification:
I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.
Signed _____ WWC Number _____ Date _____


(bonded) Water Well Constructor Certification:
I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.
Signed [Signature] WWC Number 1506 Date 8-5-98




South Zone/Hwy 11 Two Million Gallon Reservoir



Middle Zone/SW 8th Street One Million Gallon Reservoir




North Zone/Golf Course Two Million Gallon Reservoir



Well #6 Undergoing Pump Replacement




Well #9 Wellhead with Pitless Adapter Unit



Well #9 Wellhead, Booster Pump Station and Chlorination Room



Well #9 Chlorination Room



Well #9 Booster Pumps

APPENDIX C

ISO Fire Protection Report

RECEIVED MAR 28 1989

ISO COMMERCIAL RISK SERVICES, INC.

3000 EXECUTIVE PARKWAY SUITE 510 P.O. BOX 5126 SAN RAMON, CA 94583 (415) 830-8776 FAX (415) 830-4691

510-830-8778

March 15, 1989

Honorable Dale Courtney, Mayor
City of Milton-Freewater
City Hall
P.O. Box 6
Milton-Freewater, Oregon 97862

*Received May 1 - 1989 4/11/89 DSO
ISO reevaluation occurs
every 15 years with our population.
2004 will be our next.*

Dear Mayor Courtney:

We wish to thank you, James Swayne, Howard Paulson, Bill Saager and others for the cooperation given to our representative during our survey. We have completed our evaluation of the fire insurance classification for your city and advise that the protection class improved to 4.

Formerly Class 6 applied; the new classification will result in a decrease in the property insurance premium calculations for many insured commercial properties within the City of Milton-Freewater. The new class will be effective May 1, 1989.

The purpose of our visit was to gather information needed to determine a fire insurance classification which may be used in the calculations of property insurance premium. This survey was not conducted for property loss prevention or life safety purposes and no life safety or property loss prevention recommendations will be made.

The change from Class 6 to Class 4 does not affect property insurance premium calculations for residential occupancies insured under Homeowners type policies and some other special schedule rated property. The property insurance premium calculations for sprinklered properties will decrease by about 10 percent. The change will affect typical mercantile properties to a degree depending upon the type of building construction, the hazard of occupancy and other property insurance premium calculations factors. The overall effect is usually about -22% for wood frame buildings, -25% for masonry buildings and -19% for fire-resistive buildings. However, variations in construction, occupancy and private protection can result in increases or decreases from this average.

The above estimates apply only for insurance companies using ISO property insurance premium calculations. However, numerous insurance companies use other than ISO property insurance premium calculations so that the effect of the change in class may be different for their policy holders.

RECEIVED MAR 26 1977


- 2 -

The city classification applies to properties with a needed fire flow of 3500 gpm or less. The private and public protection at properties with larger needed fire flows are individually evaluated, and may vary from the district classification.

We are attaching a copy of our Grading Sheet and the results of the hydrant flow tests witnessed during our survey. Extra copies of this letter and attachments are also enclosed so that you may distribute them to other interested parties, if you desire to do so.

If you have any questions concerning the new classification, or the resulting change in premium calculations, please let us know.

Very truly yours,



FOR JBCT

Joseph B.C. Twyman
Supervisor - Survey Services

Enclosures

jbct:vs

RECEIVED MAR 28 1989

Grading Sheet for MILTON-FREEWATER, OREGON

Public Protection Class: 4

Surveyed: 4/87

| | Grading Credits | Maximum Schedule Credits |
|---|--------------------|--------------------------------|
| Receiving and Handling Fire Alarms..... | % 6.80 | 10% |
| Fire Department..... | % 26.72 | 50% |
| Water Supply..... | % 38.03 | 40% |
| *Divergence..... | % <u>- 8.33</u> | |
| Total: | % 63.22 | 100% |

The Public Protection Class is based on the total percentage credit as follows:

| <u>Class</u> | <u>%</u> |
|--------------|----------------|
| 1 | 90.00 or more |
| 2 | 80.00 to 89.99 |
| 3 | 70.00 to 79.99 |
| 4 | 60.00 to 69.99 |
| 5 | 50.00 to 59.99 |
| 6 | 40.00 to 49.99 |
| 7 | 30.00 to 39.99 |
| 8 | 20.00 to 29.99 |
| 9 | 10.00 to 19.99 |
| 10 | 0 to 9.99 |

*Divergence is a reduction in credit to reflect a difference in the relative credits for Fire Department and Water Supply.

The above classification has been developed for use in property insurance premium calculations.

RECEIVED MAR 28 1989

ISO COMMERCIAL RISK SERVICES, INC.

HYDRANT FLOW DATA SUMMARY

City Milton-Freewater State Ca Zip 97862 Witnessed by J. Mothershead Date April 8, 1987

| TEST NO. | TYPE DIST. | TEST LOCATION | SERVICE | FLOW-GPM | | PRESSURE PSI | | FLOW AT 20 PSI | | REMARKS |
|----------|--------------|---------------------------|---------|---------------------|-------|--------------|--------|----------------|--------|---------|
| | | | | INDIVIDUAL HYDRANTS | TOTAL | STATIC | RESID. | NEEDED ** | AVAIL. | |
| 1 | Comm | S. 15th & Main | South | 800 | 790 | 89 | 53 | 6000 2500 | 4400 | |
| 2 | Res | S. 13th & Davis | South | 500 | 530 | 42 | 37 | 1000 | 2300 | |
| 3 | Comm | S. 6th & Main | South | 980 | 840 | 77 | 70 | 1750 | 5600 | |
| 4 | Comm | S. 2nd & Dehaven | South | 980 | 1060 | 89 | 80 | 3000 | 6100 | |
| 5 | Comm | Broadway E. of Main | North | 820 | 870 | 68 | 60 | 4000 2250 | 4400 | |
| 6 | Comm | N. 6th & Evans | North | 1030 | 1060 | 80 | 78 | 5500 3000 | 13100 | |
| 7 | Comm | N. 7th & Lamb | North | 980 | 1020 | 80 | 75 | 2500 | 7700 | |
| 8 | Res | N. Lamb s. of Powell Rd. | North | 920 | 950 | 89 | 74 | 1250 | 4300 | |
| 9 | Comm | N. 8th & Main | North | 530 | 560 | 83 | 79 | 3000 | 4800 | |
| 10 | Comm Comm | N. 5th & Russell | North | 650 | 750 | 73 | 70 | 1750 4500 | 6600 | |
| 11 | Res | N. Elizabeth S. of 6th Ct | North | 1060 | 990 | 76 | 71 | 1000 | 7600 | |
| 12 | Comm | N. 10th & Elizabeth | North | 290 | 290 | 81 | 78 | 2500 | 3000 | |
| 13 | Comm | N. Columbia N. of 1st | North | 800 | 840 | 65 | 58 | 2500 | 4500 | |
| | | | | | | | | | | |
| | | | | | | | | | | |

THE ABOVE LISTED NEEDED FIRE FLOWS ARE FOR PROPERTY INSURANCE PREMIUM CALCULATIONS ONLY AND ARE NOT INTENDED TO PREDICT THE MAXIMUM AMOUNT OF WATER REQUIRED FOR A LARGE SCALE FIRE CONDITION. THE AVAILABLE FLOWS ONLY INDICATE THE CONDITIONS THAT EXISTED AT THE TIME AND AT THE LOCATION WHERE TESTS WERE WITNESSED.

* Comm = Commercial; Res = Residential.
 ** Needed is the rate of flow for a specific duration for a full credit condition. Needed Fire Flows greater than 3,500 gpm are not considered in determining the classification of the city when using the Fire Suppression Rating Schedule.

APPENDIX D

City Well Log and Pump Data

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

Umat
 5999

RECEIVED

APR 11 1994

5N/35E/1266
 5333.8

WATER RESOURCES DEPT.

(START CARD) #

(1) OWNER: Well Number #1
 Name City of Milton Freewater
 Address PO Box 60
 City Milton Freewater State OR Zip 97062

SALEM, OREGON
 LOCATION OF WELL by legal description:
 County Umatilla Latitude _____ Longitude _____
 Township 5 N or S. Range 35 E or W. WM.
 Section 13 NW 1/4 NW 1/4
 Tax Lot 06500 Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) SE 9th
Central St.

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable
 Other _____

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other Municipal

(5) BORE HOLE CONSTRUCTION:
 Special Construction approval Yes No Depth of Completed Well 584 ft.
 Explosives used Yes No Type _____ Amount _____

| HOLE Diameter | From To | | SEAL Material | From To | | Amount sacks or pounds |
|---------------|---------|-----|---------------|---------|--|------------------------|
| | | | | | | |
| 12 | 0 | 584 | NA | | | |

How was seal placed: Method A B C D E
 Other _____

Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) CASING/LINER:

| Diameter | From To | | Gauge | Steel | Plastic | Welded | Threaded |
|----------|---------|--|-------|--------------------------|--------------------------|--------------------------|--------------------------|
| | | | | | | | |
| Casing: | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Liner: | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Final location of shoe(s) _____

(7) PERFORATIONS/SCREENS:
 Perforations Method _____
 Screens Type _____ Material _____

| From | To | Slot size | Number | Diameter | Tele/pipe size | Casing | Liner |
|------|----|-----------|--------|----------|----------------|--------------------------|--------------------------|
| | | | | | | <input type="checkbox"/> | <input type="checkbox"/> |

(8) WELL TESTS: Minimum testing time is 1 hour

| Yield gal/min | Drawdown | Drill stem at | Time |
|---------------|----------|---------------|-------|
| | | | 1 hr. |
| | | | |

Temperature of Water _____ Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____

Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____

Depth of strata: _____

(10) STATIC WATER LEVEL:
228 ft. below land surface. Date 3-29-94
 Artesian pressure _____ lb. per square inch. Date _____

(11) WATER BEARING ZONES:
 Depth at which water was first found 228

| From | To | Estimated Flow Rate | SWL |
|------|----|---------------------|-----|
| | | | |

(12) WELL LOG:
 Ground elevation _____

| Material | From | To | SWL |
|--|------|----|-----|
| Ran 12" stabilizers down well to straighten for lowering of turbine pump | | | |
| Cleaned well out to 584 ft. | | | |
| Stabilizers cramed off side of well at 584 ft. is starting new hole | | | |

Date started 3-8-94 Completed 3-29-94

(unbonded) Water Well Constructor Certification:
 I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
 Signed _____ WWC Number _____
 Date _____

(bonded) Water Well Constructor Certification:
 I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.
 Signed ST Brown WWC Number 259
 Date 3-31-94


RECEIVED

APR 11 1994

WATER RESOURCES DEPT
SALEM, OREGON

Milton Flood

53358



31-29X

well

SW351200

See Map 5N 35 12AC

IVED

3961

OBSERVATION WELL

5N/35-12-~~77~~^{F11}
UMATILLA

1938
S1 ENGINEER
SALEM, OREGON

Milton Freewater # 1

Application No. U 109
Permit No. U 102
Well No. #1

G 5389

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report _____, 193

- #. 40' of Lot 5, Block 7, McCoy's Addition to Milton City, Oregon.
- 1. Location of well: S. W. 1 of Section 12 Twp. 5 NBge. 35 E. W. M.
- 2. Name of nearest natural surface stream Walla Walla River
- 3. Distance from well to that stream: 1000 feet.
- 4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: 9.5 feet.
- 5. Date of beginning drilling or digging January 2, 1937
- 6. Date well was completed March 1, 1938

7. LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | Thickness of stratum |
|-----------------------|----------------------------|----------------------|
| | At surface | ft. |
| | ft. | ft. |
| (SEE SHEET ATTACHED) | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |

Remarks: _____

WELL INFORMATION

- 8. Diameter of well 12" inches. Depth of well 652 feet.
- 9. Depth at which water was first encountered 90' feet.
- 10. Water level when completed: 87' feet below ground surface.
- 11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: See log attached.
This well for "standby" service only.

RECEIVED

F(1)
SN/35-12 #7
UMATILLA

JUL 1 1938
STATE ENGINEER
SALEAS C. L. COOK

PUMP INFORMATION

- 12. Manufacturer of pump: Fairbanks-Morse & Company
- 13. Address: 1220 First Avenue South, Seattle, Washington
- 14. Data on name or base plate: #32523 - Seattle No. 7310
o Stage 12" Imp. 7472, Figure o920, 1750 R.P.M.
Outside column 9" O. D., Length 150', Shaft 1 5/8" Dia.
- 15. Data on pump bowl assembly: _____
- 16. Size of pump: 12"
- 17. Rated capacity: 1000 gallons per minute. 80 pounds pressure
- 18. Rated speed: 1800 revolutions per minute. water to water hd.
- 19. Number of stages: o
- 20. Size of intake pipe: 9"
- 21. Size of discharge pipe: 12"
- 22. Length of intake pipe: 150'
- 23. Length of discharge pipe: Direct into 12" city main
- 24. Suction lift: (difference in elevation between water surface in well and pump) _____
- 25. Discharge lift: (difference in elevation between pump and end of discharge line) _____
- 26. Depth of pump intake below ground surface: 187' feet.
- 27. Remarks: 187' to bottom of intake pipe

MOTOR OR ENGINE INFORMATION

- 28. Name of manufacturer: Fairbanks-Morse & Co.
- 29. Address: 1220 First Avenue South, Seattle, Washington
- 30. Type of motor or engine: 100 H.P., Morse Type, 1750 R.P.M., 3 phase,
o 0 cy., 440 volts, vertical ball bearing, hollow shaft squirrel cage.
- 31. Data on name or base plate: _____
- 32. Rated horsepower: 100
- 33. Rated speed of motor or engine: 1750 revolutions per minute.

| | | | | |
|--|------|-----------|-----|----------|
| 34. Rated Capacity of Pump (with described motor) | 1000 | g.p.m. at | 305 | ft. head |
| | 1200 | g.p.m. at | 250 | ft. head |
| | 1250 | g.p.m. at | 240 | ft. head |
| | | g.p.m. at | | ft. head |
| | | g.p.m. at | | ft. head |

35. Remarks: _____

G 5384

U-102

F11

5N/35-12~~11~~

UMATILLA CO

LOG OF MILTON WELL - UMATILLA COUNTY

From 1 to 30 ft. gravel
30 to 37 " Cement & Gravel
37 to 40 " Gravel & Clay
40 to 60 " Black Rock
60 to 98 " Rock & Clay
98 to 115 " Black Rock
115 to 122 " Hard Black Rock
122 to 140 " Medium Rock
140 to 145 " " " Soft Red Brown
145 to 180 " " " Black
180 to 186 " Hard Black Rock
186 to 202 " Medium Grey Rock
202 to 212 " Soft " "
212 to 249 " Medium Brown Rock
249 to 256 " Hard Brown "
256 to 280 " Soft Brown Rock
280 to 367 " Medium Grey Rock
367 to 416 " " Black Rock
416 to 440 " " Grey "
440 to 450 " " Black "
450 to 651 " " Grey "


RECEIVED
JUN 4 1935
STATE GEOLOGICAL
SURVEY

MILTON CITY, OREGON

APRIL 22, 1938

Test made Fairbanks, Morse Turbine Pump
Pump #32523, Seattle No. 7316
6 Stage 12" Imp. -747-E Fig 6920 - 1750 R.P.M.
Outside column 9" O.D. Length 150 ft. shaft 1-5/8" Dia.
Capacity 1000 G.P.M. at Water to Water head 300 Ft.
Motor Fairbanks, Morse 100 H.P. Type HSZU - 1800 R.P.M.
Motor No.324047 - Fr.JL163B - 3 ph. 60 cycle 440 Volt.
118 Amps. F.Load Speed 1755 R.P.M.
Test Data:-Pump Started at 2:55 P.M.; Stopped at 5:30 P.M.
Length of air line below pump floor level 177' + 5'7" =182'7"
Draw down gauge before pumping = 37 lbs. = 85.5 ft.
Pumping at no pressure on discharge.
Draw gauge 10# = 23.1 Ft.
Pumping level 140 Ft.
Capacity thru 9.5" orifice in 12" O.D. Pipe 10" = 1400 G.P.M.
K. W. demand at power 1 mile distance 90 K.W. X 1.34 = 1201 H.P.
Discharge pressure 30# = 69.3 Ft.
Draw down gauge reading 14# = 32.25 Ft.
Capacity thru 9.5" orifice 8" = 1200 G.P.M.
Discharge pressure 50# = 115.5 Ft.
Draw down gauge 16 lbs = 36.98 Ft.
Discharge thru 9.5" orifice 7" = 1150 G. P. M.
Motor Speed 1762 - 1775 - 1760 R.P.M.
Motor In Put 127 Amps - 121 - 125 - P.Factor 90%
Discharge pressure 80 lbs. = 184.8 Ft.
Draw down gauge = 21 lbs. = 48.5 Ft.
Discharge thru 9.5" orifice 5-1/4" = 1000 G.P.M.
Motor Speed 1752 - 1754 - 1760 R. P. M.
Motor In Put 125 Amps - 124 - 122. P. Factor 88%

RECEIVED
JUN 4 1938
STATE ENGINEER
SARAH GILLES



UMAT
3962
OBSERVATION WELL

5N/35-12 R(2)
UMATILLA

Application No. U 159
Permit No. U 150
Well No. 2

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report October 10, 1945

1. Location of well: SE 1/4 of NW 1/4 of Section 12 Twp. 5 N Rge. 35E, W. M.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: 1,500 feet.
4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: _____ feet.
5. Date of beginning drilling or digging May 6, 1944
6. Date well was completed _____

7. LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | Thickness of stratum |
|------------------------------------|----------------------------|----------------------|
| Gravel | At surface | ft. |
| Gravel (cement) | 28 ft. | 12 ft. |
| Black Basalt | 70 ft. | 146 ft. |
| Brown Rock | 216 ft. | 14 ft. |
| Black & Brown Basalt | 230 ft. | 331 ft. |
| Gray Basalt | 561 ft. | 93 ft. |
| Black & Gray Basalt | 654 ft. | 67 ft. |
| Brown Basalt | 721 ft. | 40 ft. |
| Red & Gray Rock | 761 ft. | 4 ft. |
| Black & Gray Basalt | 765 - 902' | 137 ft. |

Remarks: 902' total depth of well. From 230' - 902' static water level was 105'

WELL INFORMATION

8. Diameter of well _____ inches. Depth of well 902' feet.
9. Depth at which water was first encountered 230 feet.
10. Water level when completed: 105 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: Water first encountered at 57' depth of well with water level 17' 6" below ground level. Cased out, casing extending to a depth of 99'.

PUMP INFORMATION

- 12. Manufacturer of pump: Peerless Pump Company - Los Angeles, Calif.
- 13. Address: _____
- 14. Data on name or base plate: Serial No. 24875 Bottom bowls 260' column Size 12" MA, Stage 10., Type head 1/B., Suction 10" Standard, Size discharge 10" Std.
- 15. Data on pump bowl assembly: _____
- 16. Size of pump: 12" MA
- 17. Rated capacity: 1,000 gallons per minute.
- 18. Rated speed: 1,800 RPM revolutions per minute.
- 19. Number of stages: 10
- 20. Size of intake pipe: 12
- 21. Size of discharge pipe: 10"
- 22. Length of intake pipe: 260' (Column)
- 23. Length of discharge pipe: 30'
- 24. Suction lift: (difference in elevation between water surface in well and pump) 170'
- 25. Discharge lift: (difference in elevation between pump and end of discharge line) Pumping against 65 lb. main pressure.
- 26. Depth of pump intake below ground surface: 260' feet.
- 27. Remarks: _____

MOTOR OR ENGINE INFORMATION

- 28. Name of manufacturer: U. S. Electric
- 29. Address: Los Angeles, Calif.
- 30. Type of motor or engine: C. F. U.
- 31. Data on name or base plate: Serial No. 494345., HP - 125., RPM - 1800., Frame 984A., Volts 2300., Phase 3., Cycle 60.
- 32. Rated horsepower: 125
- 33. Rated speed of motor or engine: 1800 revolutions per minute.
- 34. Rated Capacity of Pump (with described motor)

| | | | | |
|--|------|-----------|-------|----------|
| | 1000 | g.p.m. at | 400 | ft. head |
| | | g.p.m. at | _____ | ft. head |
| | | g.p.m. at | _____ | ft. head |
| | | g.p.m. at | _____ | ft. head |
| | | g.p.m. at | _____ | ft. head |

35. Remarks: _____

5/35-12 F/2
 UMATILLA
 #2

CAPACITY TEST

36. Date of test: 9-21-45 37. Temperature of water 55 °F. or °C.
 38. Motor speed during test: 1780 & 1785
 39. Test made by (weir, tank or other means): 6" Orifice - calibrated.

| 40. Pounds pressure | TOTAL HEAD | *Total lift in feet | Gallons per min. | °Feet to water level | ± Draw-down | +Time |
|-------------------------|------------|---------------------|------------------|----------------------|-------------|---------------|
| 101 lbs., Gauge at pump | Total | 178 ft. in. | 986 | 107 ft. | 71 ft. | 11:30 M. A.M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| 60 lbs., Gauge at pump | Total | 195 ft. in. | 1135 | 107 ft. | 88 ft. | 11:40 M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| 100 lbs., Gauge at pump | Total | 172 ft. in. | 990 | 107 ft. | 65 ft. | 1:30 P.M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |
| lbs., Gauge at pump | Total | ft. in. | | ft. | ft. | M. |

* Difference in elevation between water level in well and outlet of pump test line. 107'
 ° Distance from ground level to water surface in well. 105' Static
 ± Distance water level is lowered during time interval.
 + Hour and minute at which observation was made.

41. Installation will work efficiently under normal head of 400 ft.
 42. Water is discharged into: City water mains.
 43. Was water lowered to pump intake by test? Drawn down to depth of 178'
 44. Remarks: While running only. Returned to 107' static level when stopped.

GENERAL INFORMATION

45. Name of contractor or other party who drilled or dug well: A. A. Durand & Son
 Address: Walla Walla, Wash.
 46. Pump and motor were installed by: A. A. Durand & Son under supervision of
B.M.Kunes Address: Peerless Pump Co. Los Angeles Calif.
 47. Capacity test was made by: B. M. Kunes, Peerless Pump Co.
 Address: Los Angeles, Calif.
 48. General remarks: _____

Report made by _____ (sign here)

STATE ENGINEER
Salem, Oregon

State Well No. 5N/35-12F(2)

County UMATILLA

Application No. _____

Water Level Record

OWNER: MILTON FREEWATER OWNER'S NO. # 2

Description of measuring point: _____

| Date | Water Level Feet (above) (below) Land Surface | DATE | WATER LEVEL | Date | Water Level Feet (above) (below) Land Surface | DATE | WATER LEVEL |
|---------|---|-------|----------------|-------|---|---------|----------------|
| 9-21-45 | 105 | 11-55 | 140 | 10-58 | 152 | 2-62 | 167 |
| 9-17-51 | 132 | 12 | 140 | 3-59 | 142 | 3 | 167 |
| 3-54 | 138 | 1-56 | 140 | 5 | 152 | 6 | 182 |
| 4 | 138 | 2 | 142 | 7 | 170 | 8 | 187 |
| 5 | 135 | 3 | 140 | 8 | 165 | 12 | 183 |
| 6 | 147 | 5 | 144 | 12 | 165 | 1-63 | 176 |
| 7 | 155 | 6 | 155 | 2-60 | 175 | 2 | 178 |
| 9 | 136 | 7 | 164 | 4 | 160 | 3 | 176 |
| 10 | 132 | 8 | 155 | 6 | 175 | 4 | 172 |
| 11 | 135 | 10 | 160 | 7 | 184 | 6 | 197 |
| 12 | 148 | 10-57 | 163 | 11 | 173 | 8 | 202 |
| 1-55 | 136 | 11 | 160 | 12 | 170 | 9 | 203 |
| 2 | 133 | 12 | 158 | 1-61 | 168 | 11-18 | 185 |
| 3 | 134 | 4-58 | 165 | 3 | 165 | 12-21 | 180 |
| 4 | 134 | 5 | 166 | 6 | 180 | 1-20-64 | 178 |
| 5 | 150 | 7 | 170 | 7 | 175 | 2-24 | 175 |
| 6 | 147 | 8 | 165 | 11 | 170 | 3-17 | 175 |
| 9 | 142 | 9 | 165 | 1-62 | 169 | 4-27 | 170 |

REMARKS: _____

STATE ENGINEER
Salem, Oregon

State Well No. 5/35-1272

County Umatilla

Application No. _____

Chemical Analysis

OWNER City of Milton-Freewater OWNER'S NO. 2

ANALYST U S G S Address _____

Date of Collection Nov. 18, 1946

Point of Collection _____

| | P.P.M. | P.P.M. |
|--|--------|--------|
| Silica (SiO ₂) | | |
| Iron (Fe) Total | 0.0 | |
| Manganese (Mn) | | |
| Calcium (Ca) | 17. | |
| Magnesium (Mg) | 7.4 | |
| Sodium (Na) | 33. | |
| Potassium (K) | | |
| Bicarbonate (HCO ₃) | 104. | |
| Carbonate (CO ₃) | | |
| Sulfate (SO ₄) | 9.9. | |
| Chloride (Cl) | 5.8 | |
| Fluoride (F) | 0.3 | |
| Nitrate (NO ₃) | 0.2 | |
| Boron (B) | | |
| Dissolved Solids | 106. | |
| Hardness as CaCO ₃ | 73. | |
| Specific Conductance (Micromhos at 25°C) | 18. | |
| pH | | |
| Percent Sodium | 30. | |
| Sodium Absorption Ratio (S.A.R.) | | |
| CLASS | | |

RECEIVED

DEC 30 1946

STATE ENGINEER
SALEM, OREGON

5N/35-2J(1)
UMATILLA

Application No. U 101
Permit No. U 172
Well No. 3

Milton Freewater

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report December 28, 1946

1. Location of well: N.W. 1/4 of S. 1/4 of Section 2 Twp. 5 Rge. 35 E., W. M.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: 2670 feet.
4. If the well is less than 1500 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: _____ feet.
5. Date of beginning drilling or digging January 27, 1946
6. Date well was completed June 1, 1946

LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | | Thickness of stratum | |
|--------------------------|----------------------------|-----|----------------------|-----|
| | At surface | | | |
| Gravel | | | 40 | ft. |
| Solid Rock | 40 | ft. | 3 | ft. |
| Black Basalt | 43 | ft. | 17 | ft. |
| Black Basalt green shale | 177 | ft. | 6 | ft. |
| Black Basalt | 219 | ft. | 16 | ft. |
| Brown Rock | 229 | ft. | 14 | ft. |
| Black Basalt | 263 | ft. | 24 | ft. |
| Brown Rock | 287 | ft. | 20 | ft. |
| Black Basalt | 288 | ft. | 3 | ft. |
| Loose grey Stone | 334 | ft. | 4 | ft. |
| Hard Black Basalt | | | | |
| Black Basalt Rocky | | | | |

Remarks: Some cavings at 209, 218 feet; brown rock caved at 285 feet.

WELL INFORMATION

8. Diameter of well 16" I.D. inches. Depth of well 550 feet.
9. Depth at which water was first encountered 60 feet.
10. Water level when completed: 50 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: 20" casing to depth of 43 feet. 16" casing inside of 20" and to depth of 100 feet below surface. Cement seal between 20" and 16" casing at 40-42 feet. Balance filled with cuttings.

5

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

RECEIVED Umat 5-786 MAR - 8 1993

(START CARD) # U-26405

(1) OWNER: Name CITY OF MILTON - FREEWATER, OREGON Address 722 MAIN City MILTON - FREEWATER State OR. Zip 98762

(9) LOCATION OF WELL by legal description: County UMATILLA Latitude Longitude Township 5 N or S. Range - 35 E or W. WM. Section 2 NE 4 SE 4 Tax Lot 3401 Lot Block Subdivision Street Address of Well (or nearest address) NE ST KRUSSELL

(2) TYPE OF WORK: TROUBLESHOOT - TEST New Well Deepen Recondition Abandon

(10) STATIC WATER LEVEL: 182 ft. below land surface. Date 2-12-93 Artesian pressure lb. per square inch. Date

(3) DRILL METHOD: Rotary Air Rotary Mud Cable Other

(11) WATER BEARING ZONES: Depth at which water was first found

(4) PROPOSED USE: Domestic Community Industrial Irrigation Thermal Injection Other

Table with 4 columns: From, To, Estimated Flow Rate, SWL. Rows are empty.

(5) BORE HOLE CONSTRUCTION: Special Construction approval Yes No Depth of Completed Well 596 ft. Explosives used Yes No Type Amount

Table with 6 columns: HOLE Diameter From To, SEAL Material From To, Amount sacks or pounds. Rows are empty.

(12) WELL LOG: Ground elevation

How was seal placed: Method A B C D E Other

Table with 4 columns: Material, From, To, SWL. Contains handwritten log text: A BRIDGE COMPOSED OF ROCK-CEMENT BLOCKS... AT 560' TO ISOLATE THE GAS AND WATER H2O ZONE... PUMPER FOR 4 HRS AT 450 GPM... WE HAD STEADY DRAWDOWN TO 233' AND CONTINUOUS GAS IN DISCHARGE. BRIDGE WAS THEN DRILLED OUT AND HOLE CLEANED TO BOTTOM, 596'.

Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns for Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Rows for Casing and Liner.

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: Perforations Method Screens Type Material

Table with 8 columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Rows are empty.

(8) WELL TESTS: Minimum testing time is 1 hour

Table with 4 columns: Pump/Bailer/Air/Artesian, Yield gal/min, Drawdown, Drill stem at, Time. Contains handwritten data: 450 GPM, 51', 4 HRS.

Date started 2-5-93 Completed 2-26-93

Temperature of Water 58° Depth Artesian Flow Found Was a water analysis done? Yes By whom Did any strata contain water not suitable for intended use? Too little Salty Muddy Odor Colored Other GAS. Depth of strata: 260' - 300'

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed _____ Date _____ WWC Number _____

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon well construction standards. This report is true to the best of my knowledge and belief.

Signed [Signature] Date 3-1-93 WWC Number 1608

STATE ENGINEER
Salem, Oregon

UMAT
3930

OBSERVATION WELL
Well Record

STATE WELL NO. 5/35-271 dad
COUNTY UMATILLA
APPLICATION NO. _____

OWNER: Milton-Freewater MAILING ADDRESS: _____

LOCATION OF WELL: Owner's No. 3 CITY AND STATE: _____


..... $\frac{1}{4}$ $\frac{1}{4}$ Sec. T. N. E.
S, R. W, W.M.

Bearing and distance from section or subdivision corner _____

Altitude at well 1,010⁺

TYPE OF WELL: Drilled Date Constructed _____

Depth drilled 550 Depth cased 100



Section _____

CASING RECORD:

20-16 inch

FINISH:

AQUIFERS:

Basalt

WATER LEVEL:

50 feet below land surface, June, 1946

PUMPING EQUIPMENT: Type Turbine H.P. _____
Capacity 1,500 G.P.M.

WELL TESTS:

Drawdown ft. after hours G.P.M.
Drawdown ft. after hours G.P.M.

USE OF WATER Public Supply Temp. °F., 19....

SOURCE OF INFORMATION USGS

DRILLER or DIGGER _____

ADDITIONAL DATA:

Log X Water Level Measurements Chemical Analysis Aquifer Test

REMARKS:

STATE ENGINEER
Salem, Oregon

State Well No. 5/35-2J(1)

County UMATILLA

Application No. _____

Water Level Record

OWNER: MILTON FREEWATER OWNER'S NO. #3

Description of measuring point: _____

| Date | Water Level Feet (above) Land Surface | DATE | WATER LEVEL | Date | Water Level Feet (above) Land Surface | Remarks |
|---------|---|-------|----------------|---------|---|---------|
| 6-46 | 50 | 10-55 | 80 | 7-61 | 83 | |
| 2-26-53 | 78 | 2-56 | 82 | 2-24-54 | 114 | |
| 2-54 | 98 | 5 | 78 | 3-17 | 109 | |
| 3-15 | 84 | 6 | 92 | 4-20 | 108 | |
| 3-30 | 105 | 7 | 105 | 5-18 | 106 | |
| 4 | 80 | 8 | 96 | 6-19 | 119 | |
| 5 | 78 | 11 | 85 | 7-6 | 129 | |
| 6 | 85 | 12 | 95 | 9-21 | 133 | |
| 8 | 90 | 1-57 | 88 | 10-26 | 132 | |
| 10-10 | 90 | 2 | 88 | 11-23 | 123 | |
| 10-30 | 86 | 3 | 84 | 12-11 | 116.6 | |
| 2-55 | 78 | 5-58 | 99 | | | |
| 3 | 78 | 10 | 98 | | | |
| 4 | 75 | 11 | 90 | | | |
| 5 | 78 | 12 | 86 | | | |
| 6 | 90 | 3-59 | 80 | | | |
| 8 | 92 | 5 | 90 | | | |
| 9 | 85 | 4-61 | 99 | | | |

REMARKS: _____

STATE ENGINEER
Salem, Oregon

UMAT
3934

Well Record

STATE WELL NO. 5N/35-2H(1)
COUNTY Umatilla
APPLICATION NO. U- 808

OWNER: Milton-Freewater

MAILING
ADDRESS: _____


LOCATION OF WELL: Owner's No. 4

CITY AND
STATE: _____

Milton-Freewater, Oregon

SE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 2 T. 5 N. 35 E. XX, W.M.

Bearing and distance from section or subdivision
corner N.58°52'W. 917' from E $\frac{1}{4}$ cor. of sec. 2



Section 2

Altitude at well _____

TYPE OF WELL: Drilled Date Constructed 1928

Depth drilled 374' Depth cased _____

CASING RECORD:
8 inch

FINISH: _____

AQUIFERS:

Basalt

WATER LEVEL: _____

PUMPING EQUIPMENT: Type Turbine H.P. _____
Capacity _____ G.P.M.

WELL TESTS:

Drawdown _____ ft. after _____ hours _____ G.P.M.

Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Municipal Temp. _____ °F. _____, 19____

SOURCE OF INFORMATION U- 717

DRILLER or DIGGER _____

ADDITIONAL DATA:

Log NA Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS: _____

Umatilla

SN/35-21K

Oregon State Board of Health
SANITARY ENGINEERING LABORATORY

REPORT OF MINERAL ANALYSIS OF WATER

Location of source Milton-Freswater Description of source Pump 1

Analysis by MHP Date 11/12/51 Collected by _____ Date 6/25/51

RESULTS

| | Parts per million |
|--|-------------------|
| Turbidity _____ | 5 |
| Color: Apparent _____ True _____ | 4 |
| Odor: Hot _____ Cold _____ | |
| Total Solids _____ | 150 |
| Loss on Ignition _____ | 65 |
| Silicon (SiO ₂) _____ | 11 |
| Chloride (Cl) _____ | 35 |
| Sulfate (SO ₄) _____ | 5.4 |
| Calcium (Ca) _____ | 11 |
| Magnesium (Mg) _____ | 8.5 |
| Aluminum (Al) _____ | 0 |
| Orthophosphates (PO ₄) _____ | .55 |
| Metaphosphates (PO ₃) ₆ _____ | |
| Alkalinity (as CaCO ₃): Carbonate _____ | 0 |
| Bicarbonate _____ | 49 |
| Hardness (as CaCO ₃) _____ | 61 |
| Sodium and Potassium (as Na) _____ | 10 |
| Iron (Fe) _____ | .55 |
| Manganese (Mn) _____ | 0 |
| Fluoride (F) _____ | .1 |
| Carbon Dioxide (CO ₂) _____ | 1.6 |
| pH <u>7.8</u> | |
| Remarks _____ | |

STATE ENGINEER
Salem, Oregon



Well Record

STATE WELL NO. 5N/35-1E(2)
COUNTY Umatilla
APPLICATION NO. U-809

OWNER: City of Milton-Freewater

MAILING ADDRESS:

LOCATION OF WELL: Owner's No. 5

CITY AND STATE:

Milton-Freewater, Oregon

SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 1 T. 5 N. 35 E. XX, R. XX, W.M.

Bearing and distance from section or subdivision

corner N. 32°2'E. 365.5' from W $\frac{1}{4}$ cor. of sec. 1
to a 2" iron pipe, thence S. 50°35'W. 31.5'
to the well.

| | | | |
|------|--|--|--|
| | | | |
| E(2) | | | |
| o | | | |
| | | | |

Section 1

Altitude at well 995'

TYPE OF WELL: Drilled Date Constructed 1936

Depth drilled 502' Depth cased 212'

CASING RECORD:

- 18 inch set from 0 to 40 feet
- 12 inch set from 40 to 212 feet

FINISH:

AQUIFERS:

Basalt from 435 to 502 feet

WATER LEVEL:

67 feet (10/5/54)
120 feet (5/1/57)

PUMPING EQUIPMENT: Type Peerless turbine H.P. 150
Capacity 1200 G.P.M.

WELL TESTS:

Drawdown 47 ft. after 750 hours 750 G.P.M.
Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Municipal Temp. _____ °F. _____, 19____

SOURCE OF INFORMATION USGS U-718

DRILLER or DIGGER A.A. Durand & Son

ADDITIONAL DATA:

Log Water Level Measurements Chemical Analysis _____ Aquifer Test _____

REMARKS:

SANITARY ENGINEERING LABORATORY

REPORT OF MINERAL ANALYSIS OF WATER

Location of source Milton-Freswater Description of source Pool 65

Analysis by MIP Date 11/12/53 Collected by _____ Date 6/25/53

RESULTS

| | Parts per million |
|--|-------------------|
| Turbidity _____ | 5 |
| Color: Apparent _____ True _____ | 3 |
| Odor: Hot _____ Cold _____ | |
| Total Solids _____ | 11.9 |
| Loss on Ignition _____ | .9 |
| Silicon (SiO ₂) _____ | .8 |
| Chloride (Cl) _____ | 7.8 |
| Sulfate (SO ₄) _____ | 3.7 |
| Calcium (Ca) _____ | 15 |
| Magnesium (Mg) _____ | 8.5 |
| Aluminum (Al) _____ | 0 |
| Orthophosphates (PO ₄) _____ | .15 |
| Metaphosphates (PO ₃) ₆ _____ | |
| Alkalinity (as CaCO ₃): Carbonate _____ | 0 |
| Bicarbonate _____ | 70 |
| Hardness (as CaCO ₃) _____ | 65 |
| Sodium and potassium (as Na) _____ | 14 |
| Iron (Fe) _____ | .33 |
| Manganese (Mn) _____ | 0 |
| Fluoride (F) _____ | .1 |
| Carbon Dioxide (CO ₂) _____ | 2.3 |
| pH _____ | 7.8 |
| Remarks _____ | |

STATE ENGINEER
Salem, Oregon

State Well No. 5N/35-1B(2)

County UMATILLA

Application No. U-809

Water Level Record

OWNER: MILTON-FREEWATER OWNER'S NO. _____

Description of measuring point: MOUNT. HOLE ON NE CORNER OF WELL 1.5' ABOVE L.S.D.

| Date | Water Level Feet (above) (below) Land Surface | Remarks | Date | Water Level Feet (above) (below) Land Surface | DATE | Remarks | WATER LEVEL |
|---------|--|---------|------|--|------|---------|----------------|
| 11-9-61 | 101.21 | RD #158 | 1-56 | 80 | 3-58 | | 95 |
| 5-54 | 65 | | 2 | 74 | 4 | | 95 |
| 6 | 83 | | 3 | 80 | 7 | | 102 |
| 8 | 85 | | 4 | 82 | 8 | | 100 |
| 9 | 67 | | 5 | 79 | | | |
| 10 | 73 | | 10 | 89 | | | |
| 11 | 76 | | 11 | 80 | | | |
| 12 | 72 | | 12 | 80 | | | |
| 1-55 | 75 | | 1-57 | 80 | | | |
| 2 | 70 | | 2 | 81 | | | |
| 3 | 70 | | 3 | 76 | | | |
| 4 | 68 | | 4 | 80 | | | |
| 5 | 71 | | 9 | 102 | | | |
| 8 | 86 | | 10 | 98 | | | |
| 9 | 76 | | 11 | 95 | | | |
| 10 | 74 | | 12 | 86 | | | |
| 11 | 74 | | 1-58 | 95 | | | |
| 12 | 82 | | 2 | 95 | | | |

REMARKS: _____

STATE ENGINEER
Salem, Oregon



OBSERVATION WELL Well Record


STATE WELL NO. 5N/35-2L(1)
COUNTY UMATILLA
APPLICATION NO. U-511

OWNER: CITY OF MILTON FREEWATER MAILING ADDRESS: MILTON FREEWATER

LOCATION OF WELL: Owner's No. #6 CITY AND STATE: _____

NE 1/4 SW 1/4 Sec. 2 T. 5 N. 35 E. W.M.

Bearing and distance from section or subdivision corner _____



Section 2

Altitude at well _____

TYPE OF WELL: DRILLED Date Constructed 12-22-50

Depth drilled 952' Depth cased 61'

CASING RECORD:

16 INCH
12 INCH

FINISH:

AQUIFERS:

BASALT

WATER LEVEL:

71' (12-22-50)

PUMPING EQUIPMENT: Type Cook H.P. 125
Capacity 1500 G.P.M.

WELL TESTS:

Drawdown _____ ft. after _____ hours _____ G.P.M.
Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER MUNICIPAL Temp. _____ °F. _____, 19____

SOURCE OF INFORMATION U-511
DRILLER or DIGGER Geo. Scott

ADDITIONAL DATA:

Log Water Level Measurements Chemical Analysis Aquifer Test _____

REMARKS:

Umatilla

5M/35-24

Oregon State Board of Health 338

SANITARY ENGINEERING LABORATORY

REPORT OF MINERAL ANALYSIS OF WATER

Location of source Milton, Oregon Description of source

Analysis by MHP Date 11/12/51 Collected by Date 6/25/51

RESULTS

| | Parts per million |
|--|---------------------------|
| Turbidity | 2 |
| Color: Apparent | 1 |
| True | |
| Odor: Hot | 0 |
| Cold | |
| Total Solids | 170 |
| Loss on Ignition | 50 |
| Silicon (SiO ₂) | 50 |
| Chloride (Cl) | 4.8 |
| Sulfate (SO ₄) | 5.6 |
| Calcium (Ca) | 36 |
| Magnesium (Mg) | 6.5 |
| Aluminum (Al) | Trace (less than .05 ppm) |
| Orthophosphates (PO ₄) | .63 |
| Metaphosphates (PO ₃) ₆ | |
| Alkalinity (as CaCO ₃): Carbonate | 0 |
| Bicarbonate | 22 |
| Hardness (as CaCO ₃) | 19 |
| Sodium and Potassium (as Na) | 19 |
| Iron (Fe) | .36 |
| Manganese (Mn) | 0 |
| Fluoride (F) | .2 |
| Carbon Dioxide (CO ₂) | 1.0 |
| pH | 8.0 |

Remarks

STATE ENGINEER
Salem, Oregon

State Well No. SN/35-2L(1) ^{caa}

County UMATILLA

Application No. _____

Water Level Record

OWNER: MILTON FREEWATER OWNER'S NO. *6

Description of measuring point: _____

| Date | Water Level Feet (below) Land Surface | DATE | WATER LEVEL | Date | Water Level Feet (below) Land Surface | Remarks |
|------|---|------|----------------|------|---|---------|
| 4-54 | 78 | 5-57 | 76 | 8-60 | 95 | |
| 10 | 95 | 9 | 82 | 8 | 85 | |
| 11 | 88 | 10 | 80 | 10 | 82 | |
| 12 | 85 | 11 | 72 | 3-61 | 97 | |
| 1-55 | 85 | 12 | 78 | 4 | 95 | |
| 2 | 82 | 1-58 | 80 | 11 | 100 | |
| 3 | 82 | 4 | 74 | 12 | 95 | |
| 4 | 78 | 9 | 85 | 1-62 | 100 | |
| 5 | 74 | 4-59 | 97 | 2- | 98 | |
| 7 | 82 | 8 | 88 | 9 | 110 | |
| 12 | 86 | 9 | 85 | 11 | 105 | |
| 1-56 | 80 | 10 | 85 | 12 | 105 | |
| 2 | 76 | 11 | 84 | 1-63 | 100 | |
| 3 | 76 | 12 | 85 | 2 | 98 | |
| 4 | 73 | 1-60 | 87 | 5 | 110 | |
| 5 | 70 | 2 | 80 | 6 | 113 | |
| 8 | 80 | 3 | 100 | 8 | 119 | |
| 9 | 74 | 4 | 92 | | | |

REMARKS: _____

STATE ENGINEER
Salem, Oregon

State Well No. 5N/36-18M
County Umatilla
Application No. G-2502

Well Log

Owner: City of Milton-Freewater Owner's No. #8

Driller: R. J. Strasser, Portland, Oregon Date Drilled April 14, 1965

| CHARACTER OF MATERIAL | (Feet below 'and surface) | | Thickness (feet) |
|------------------------------|---------------------------|-----|------------------|
| | From | To | |
| Fill | 0 | 9 | 9 |
| Gravel and boulders | 9 | 31 | 22 |
| Weathered rock | 31 | 38 | 7 |
| Medium hard black rock | 38 | 47 | 9 |
| Broken rock | 47 | 50 | 3 |
| Hard black basalt | 50 | 81 | 31 |
| Medium hard basalt | 81 | 83 | 2 |
| Hard black basalt | 83 | 96 | 13 |
| Broken black rock | 96 | 105 | 9 |
| Hard black basalt | 105 | 112 | 7 |
| Broken gray basalt | 112 | 121 | 9 |
| Porous black rock | 121 | 144 | 23 |
| Porous dark brown rock | 144 | 163 | 19 |
| Broken black rock | 163 | 180 | 17 |
| Medium hard gray basalt | 180 | 201 | 21 |
| Black and reddish brown rock | 201 | 209 | 8 |
| Porous black basalt | 209 | 316 | 7 |
| Hard gray basalt | 316 | 341 | 25 |
| Medium hard dark gray basalt | 341 | 352 | 11 |
| Hard gray basalt | 352 | 358 | 6 |
| Porous black basalt | 358 | 386 | 28 |
| Medium hard gray basalt | 386 | 398 | 12 |
| Medium soft black basalt | 398 | 437 | 39 |
| Medium hard gray basalt | 437 | 447 | 10 |

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

RECEIVED
MAR 18 1970
STATE ENGINEER OF OREGON
SALEM, OREGON
(Do not write above this line)

5N/26-18-cb
G-2502
State Well No. _____
G-2212
State Permit No. _____

(1) OWNER:
Name CITY OF MILTON-FREEWATER ORE.
Address MILTON-FREEWATER ORE.

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):
Rotary Driven Domestic Industrial Municipal
Cable Jetted Irrigation Test Well Other
Plug Bored

(5) CASING INSTALLED: Threaded Welded
SEE PREVIOUS LOG
Diam. from _____ ft. to _____ ft. Casing _____
Diam. from _____ ft. to _____ ft. Casing _____
Diam. from _____ ft. to _____ ft. Casing _____

(6) PERFORATIONS: Perforated? Yes No.
Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.
Static level 5.69 ft. below land surface Date 2/24/70
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No. If yes, by whom? C. S. DIXON
Yield: 1520 gal./min. with 107 ft. drawdown after 2 1/2 hrs.

Barrier test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ s.p.m. Date _____
Temperature of water 14 Was a chemical analysis made? Yes No

(10) CONSTRUCTION: SEE PREVIOUS LOG
Well seal—Material used _____
Depth of seal _____ ft.
Diameter of well bore to bottom of seal _____ in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:
County UMATILA Driller's well number 8
NW 1/4 SW 11 Section 18 T. 5N R. 36 E W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG: Diameter of well below casing 1 1/2 ID
Depth drilled 1051 ft. Depth of completed well 1051 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

| MATERIAL | From | To | SWL |
|--------------------|------|------|------|
| SEE PREVIOUS LOG | 0 | PER | 21.9 |
| BLACK BASALT | 895 | 962 | 26.9 |
| BROWN-BLACK BASALT | 965 | 965 | 21.9 |
| BLACK BASALT | 965 | 973 | 26.9 |
| GREY BASALT | 973 | 1021 | 26.9 |
| RED BASALT | 1021 | 1025 | 26.9 |
| RED-BLACK BASALT | 1025 | 1025 | 26.9 |
| BLACK-BASALT | 1025 | 1025 | 26.9 |
| GREY-BASALT | 1030 | 1051 | 21.9 |

Work started 12-1 1969 Completed 7-9 1970
Date well drilling machine moved off of well 7-2 1970

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
(Signed) Charles J. S. Dixon Date 3-10 1970
(Drilling Machine Operator)

Drilling Machine Operator's License No. 361

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME CHARLES J. S. DIXON DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 115 REIS AVE. W. W. WASH.
(Signed) Charles J. S. Dixon
(Water Well Contractor)

Contractor's License No. 934 Date 3-10 1970

(USE ADDITIONAL SHEETS IF NECESSARY)

Attachment

City Well No. 9
5/35 - 126(A)

RECEIVED

AUG 24 1951

STATE ENGINEER
SALEM, OREGON

Application No. U -403
Permit No. U -373
Well No. 1, Umatilla Canning Co.
UMATILLA CO

UMAT
3965

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report August 22, 1951

1. Location of well: SW 1/4 of SE 1/4 of Section 12 Twp. 5N Rge. 35 E, W. M.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: Approx. 4000 feet.
4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: _____ feet.
5. Date of beginning drilling or digging: January 11, 1951
6. Date well was completed June 22, 1951

LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | Thickness of stratum |
|---|----------------------------|----------------------|
| Yellow cement gravel | At surface 0 ft. | 41 ft. |
| Broken Basalt & Blue Clay | 41 ft. | 285 ft. |
| Medium gray basalt & alternate clay & mud | 285 ft. | 421 ft. |
| Broken gray basalt | 421 ft. | 562 ft. |
| Black basalt & gray basalt | 562 ft. | 751 ft. |
| Medium black basalt - (2ft. Hard black basalt 816-818 ft) | 751 ft. | 878 ft. |
| Gray hard basalt | 878 ft. | 881 ft. |
| Medium black basalt | 881 ft. | 894 ft. |
| Hard black basalt | 894 ft. | 913 ft. |
| Remarks: Medium black basalt | 913 ft. | 918 ft. |

WELL INFORMATION

8. Diameter of well see below inches. Depth of well 918 feet.
9. Depth at which water was first encountered 90 feet.
10. Water level when completed: 205 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: Some caving - 321 ft to 500 ft.

8. 24" from 0 to 104 ft.
- 20" from 104 to 321 ft.
- 16" from 321 to 690 ft.
- 12" from 690 to 918 ft.

SN/35-120A)
UMATILLA Co

RECEIVED

AUG 24 1951
STATE ENGINEER
SALEM, OREGON

PUMP INFORMATION

- 12. Manufacturer of pump: A. D. Cook, Inc.
- 13. Address: Lawrenceburg, Indiana
- 14. Data on name or base plate: Serial No. 13254
Cook Rotation Pump
- 15. Data on pump bowl assembly: TR 5107 12 TR 527
26 12 TR 5280
- 16. Size of pump: 8" Turbine
- 17. Rated capacity: 950 gallons per minute.
- 18. Rated speed: 1765 revolutions per minute.
- 19. Number of stages: 8
- 20. Size of intake pipe: 8"
- 21. Size of discharge pipe: 8"
- 22. Length of intake pipe: 290 feet column, 25 feet bowl assembly, suction and strainer
- 23. Length of discharge pipe: 161.65 ft.
- 24. Suction lift: (difference in elevation between water surface in well and pump) 205 feet
- 25. Discharge lift: (difference in elevation between pump and end of discharge line) Hardly any -- pipe runs slightly downhill
- 26. Depth of pump intake below ground surface: 310 feet.
- 27. Remarks: This pump will be exchanged or worked over to that we can pump between 1400 and 1500 g.p.m. next season.

MOTOR OR ENGINE INFORMATION

- 28. Name of manufacturer: General Electric
- 29. Address: Schenectady, N. Y.
- 30. Type of motor or engine: Electric Induction Motor
- 31. Data on name or base plate: Model 5K445A1A Service Factor 1.15 at Rated Volts
60 cycles 220/440 volts Type K Code F Frame 445 3 phase 60 cy
FL AMP 181/90.5 FL Speed 1765 No. WQJ6873648 TRYCLAD INDUCTION MOTOR
- 32. Rated horsepower: 75 H.P.
- 33. Rated speed of motor or engines: 1765 revolutions per minute.
- 34. Rated Capacity of Pump (with described motor)

| |
|--|
| <u>950</u> g.p.m. at <u>205</u> ft. head |
| <u>800</u> g.p.m. at <u>300</u> ft. head |
| <u>700</u> g.p.m. at <u>350</u> ft. head |
| g.p.m. at _____ ft. head |
| g.p.m. at _____ ft. head |
- 35. Remarks: We intend to trade this pump and motor or have it worked over next year (before June 1952) so that we can pump 1400-1500 g.p.m.

RECEIVED

AUG 24 1951

STATE ENGINEER
SALEM, OREGON

54/75-1204

CAPACITY TEST

- 36. Date of test: 8/16 & 8/17, 1951 37. Temperature of water 60°F. or °C.
- 38. Motor speed during test: From 1250 - 1800 R.P.M.
- 39. Test made by (weir, tank or other means): Weir

| DIRECT READING GAUGE | WEIR | TOTAL HEAD | *Total lift in feet | Gallons per min. | °Feet to water level | Draw-down | +Time |
|----------------------|---------------------|---------------|---------------------|------------------|----------------------|-----------|-----------|
| 205 | lbs., Gauge at pump | Total 205 ft. | in. 205 ft. | 336 | 215 ft. | 10 ft. | 7:15 AM. |
| 215 | lbs., Gauge at pump | Total 215 ft. | in. 215 ft. | 795 | 244 ft. | 39 ft. | 8:30 AM. |
| 244 | lbs., Gauge at pump | Total 244 ft. | in. 244 ft. | 1220 | 266 ft. | 61 ft. | 10:30 AM. |
| 266 | lbs., Gauge at pump | Total 266 ft. | in. 266 ft. | 1407 | 287 ft. | 82 ft. | 12:30 PM. |
| 287 | lbs., Gauge at pump | Total 287 ft. | in. 287 ft. | 1407 | 287 ft. | 82 ft. | 5:30 PM. |
| 287 | lbs., Gauge at pump | Total 287 ft. | in. 287 ft. | 1220 | 270 ft. | 65 ft. | 7:30 PM. |
| 270 | lbs., Gauge at pump | Total 270 ft. | in. 270 ft. | 1407 | 285 ft. | 80 ft. | 9:00 PM. |
| 285 | lbs., Gauge at pump | Total 285 ft. | in. 285 ft. | 1407 | 285 ft. | 80 ft. | 12:00 M. |
| 285 | lbs., Gauge at pump | Total 285 ft. | in. 285 ft. | 1407 | 285 ft. | 80 ft. | 4:00 AM. |
| 285 | lbs., Gauge at pump | Total 285 ft. | in. 285 ft. | 1312 | 270 ft. | 65 ft. | 4:10 AM. |
| 270 | lbs., Gauge at pump | Total 270 ft. | in. 270 ft. | 1220 | 263 ft. | 58 ft. | 4:20 AM. |
| 263 | lbs., Gauge at pump | Total 263 ft. | in. 263 ft. | 1220 | 264 ft. | 59 ft. | 6:00 AM. |
| 264 | lbs., Gauge at pump | Total 264 ft. | in. 264 ft. | 1501 | 295 ft. | 90 ft. | 6:10 AM. |
| 295 | lbs., Gauge at pump | Total 295 ft. | in. 295 ft. | 1501 | 295 ft. | 90 ft. | 6:18 AM. |
| 295 | lbs., Gauge at pump | Total 295 ft. | in. 295 ft. | (RECOVERY) | ft. | ft. | 6:23 AM. |
| 209 | lbs., Gauge at pump | Total ft. | in. ft. | | ft. | ft. | M. |

8/16

Midnight
8/17

- * Difference in elevation between water level in well and outlet of pump test line.
- Distance from ground level to water surface in well.
- Distance water level is lowered during time interval.
- + Hour and minute at which observation was made.

- 41. Installation will work efficiently under normal head of 325 ft.
- 42. Water is discharged into: Main lines, Umatilla Canning Company Plant.
- 43. Was water lowered to pump intake by test? Yes - deliberately.
- 44. Remarks: Didn't have enough column on to go beyond 1501 G.P.M. on test.
Had only 90 feet of column beyond static water level of 205 feet.
Well recovered to static water level from 6:18 a.m. to 6:23 a.m. 8/17/51.
Recovery rate of 5 minutes.

GENERAL INFORMATION

- 45. Name of contractor or other party who drilled or dug well: A. A. Durand & Son
Address: 115 Rees Avenue, Walla Walla, Washington
- 46. Pump and motor were installed by: Pump, Pipe, & Power Co., Portland, Oregon
Address: _____
- 47. Capacity test was made by: A. A. Durand & Son, Walla Walla, Washington
Address: _____
- 48. General remarks: _____

May 8, 1989

James A. Swayne
City Manager
Milton-Freewater City Hall
Milton-Freewater, OR 97862

Attn: Jack King, Director - Public Works

Re: Pump Test - Umatilla (Hendricks) Well
May 3, 1989 (0900 - 1700 hours)

Dear Mr. Swayne;

The purpose of this report and of this pump test is to establish the present conditions of the Umatilla (Hendricks) water well. Knowing these conditions, make a recommendation to the City of Milton-Freewater with regard to acquiring the water well.

History - The water well was drilled in 1951, and was used from that date until November 1978. The well is 913 feet deep, and has casing installed and hole sizes drilled as follows:

| | |
|-----------------|---|
| 0 to 104 feet | 24 inch diameter hole |
| 104 to 321 feet | 20 inch diameter hole |
| 0 to 193 feet | 18 inch diameter casing |
| 193 to 296 feet | 16 inch diameter casing (15.25" ID - 16" O.D.) |
| 296 to 321 feet | concrete wall, 16" nominal |
| 321 to 695 feet | 16" nominal rock wall hole |
| 695 to 724 feet | cemented to stabilize hole |
| 695 to 913 feet | 12" nominal rock wall hole |

A log of the materials penetrated is provided. The original static water level (SWL) was 202 ft. depth - 1951, measured from the collar. The original reported yield was 920 gpm with a drawdown of 46 feet. This is a specific capacity of 20 gallons per minutes per foot of drawdown.

The water well is located in the SW 1/4 SE 1/4 Section 12T5N R35E Wm. The ground elevation, taken from the Milton-Freewater City one foot contour map is 1152 feet. Two feet were added for the concrete slab and ring, so elevation 1154 was used for the collars.

No aquifers or changes in the SWL were recorded on the daily drilling log.

The presently installed pump was used for the pumping test. The pump is a General Electric turbine pump with a 125 horse power electric motor. Furnished data says original installation was 33 pieces of 10 feet length; 8 inch diameter pipe, plus 2 - 5 feet length; plus 74 inches of bowl section. Original length was 340 feet plus 6 feet of bowls. In 1968, 20 feet of column was added at the top for 360 feet plus bowls. The air line was also set to the 360 feet depth. A note also says that the pump was last pulled in 1972.

Considerable effort was expended to rotate the driveshaft after non-use since 1979. The equipment was operational on May 3, 1989. The City crew had installed a discharge line for the pumped water into the commercial sewage line. In the discharge line was installed a meter reading in gallons times 1000 and a discharge control valve. The air line was equipped with pressure gauge (PSI) having two pound increments and pressure gauge direct reading in feet with one foot increments. The pressure gauge prior to pumping read 19.5 psi which is 45 feet of head. The direct reading gauge was 44 feet of head.

The pump test started at 0847 hours and concluded 1700 hours on May 3, 1989. See test data on Table 1.


Conclusion - The yield to drawdown characteristics, are of the same magnitude as the original data. See pump curve.

The acquisition of this well is recommended. If the intent is to pump this well at greater than 800 gpm, then a pump test covering the range of use, 800 to 1200 gpm, should be conducted to establish drawdown to yield rates for pump design.

Respectfully,

Dick Gullixson

cc: Jack D. King
✓ Howard Moss
John Hendricks
Dick Gullixson



APPENDIX E

Water Right Data

Water Rights Information Query Results

| | Contacts | Application | Permit | Certificate | Claim | Decree | Transfers | Status |
|--------|--|-------------|--------|-------------|-------|--------|-----------|--------|
| Select | OWNER: CITY OF MILTON FREEWATER PO BOX 106 MILTON FREEWATER, OR 97862 | G5389 | G4924 | | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER PO BOX 6 MILTON FREEWATER, OR 97862 | G13494 | G12582 | | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER DAVID BRADSHAW 722 S MAIN MILTON FREEWATER, OR 97862 | G14665 | G13488 | | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER PO BOX 6 MILTON FREEWATER, OR 97862 | R69553 | R11219 | | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER 722 S MAIN ST MILTON FREEWATER, OR 97862 | S69266 | S50962 | | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER MILTON FREEWATER, OR 97862 | U511 | U462 | 23519 | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER MILTON FREEWATER, OR 97862 | U808 | U717 | 23532 | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER MILTON FREEWATER, OR 97862 | U809 | U718 | 23533 | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER BOX 108 MILTON FREEWATER, OR 97862 | G2502 | G2312 | 41011 | | | | NC |
| Select | OWNER: CITY OF MILTON FREEWATER 722 S MAIN MILTON FREEWATER, OR 97862 | G4667 | G4391 | 41022 | | | | NC |

WELL NO. 1

WELL NO. 9

WELL NO. 6

WELL NO. 4

WELL NO. 5

WELL NO. 8

1 2

Help understanding and working with the Water Rights Information System

Download: [Point of diversion data](#), [Place of use data](#), [Stakeholder data](#)

[Return to WRIS Query](#)

Water Rights Information Query Results

| | Contacts | Application | Permit | Certificate | Claim | Decree | Transfers | Status |
|--------|--|-------------|--------|-------------|-------|-------------------|----------------------|--------|
| Select | APPLICANT: CITY OF MILTON FREEWATER PO BOX 6 MILTON FREEWATER, OR 97862 | | | | | WALLA WALLA RIVER | ▶ T8626 (Confirming) | NC |
| Select | APPLICANT: CITY OF MILTON FREEWATER PO BOX 6 MILTON FREEWATER, OR 97862 | | | | | WALLA WALLA RIVER | ▶ T8626 (Confirming) | NC |
| Select | APPLICANT: CITY OF MILTON FREEWATER PO BOX 6 MILTON FREEWATER, OR 97862 | | | | | WALLA WALLA RIVER | ▶ T8626 (Confirming) | NC |
| Select | OWNER: CITY OF MILTON FREEWATER ▶ 722 S MAIN PO BOX 6 MILTON FREEWATER, OR 97862 | S55136 | S41598 | 82171 | | | | NC |

12

[Help understanding and working with the Water Rights Information System](#)

Download: [Point of diversion data](#), [Place of use data](#), [Stakeholder data](#)

[Return to WRIS Query](#)

| Water Right Information Query Results | |
|---|---|
| Contact Information | Documents <small>View All Documents</small> |
| <p>▼ Current contact information</p> <p>OWNER: CITY OF MILTON FREEWATER PO BOX 106 MILTON FREEWATER, OR 97862</p> | <p>▶ Application: G 5389 digital map</p> <p>▶ Permit: G 4924 document, digital map, paper map</p> <p>▶ Order(s)</p> <p>▶ View right with New Web Mapping (beta)</p> |
| Water Right Information | |
| <p>Status: Non-Cancelled</p> <p>County: Umatilla</p> <p>File Folder Location: Salem</p> <p>Watermaster District: 5</p> | |
| Point(s) of Diversion | |
| ▶ POD 1 - CITY OF M.F. WELL 1 > WALLA WALLA RIVER | |
| Place(s) of Use <small>View All Records</small> | |
| ▶ Use - MUNICIPAL USES (Primary); Priority Date: 1/4/1971 | |
| Water Right Genealogy | |
| -----No genealogy records available for this water right, try the family link below instead. | |

[View Water Rights in same Family](#)

[Help understanding and working with the Water Rights Information System](#)

[Report Errors with Water Right Data](#)

[Return to WRIS Query](#)

RECEIVED
JAN 4 1970
STATE ENGINEER
SALEM, OREGON

WELL NO. 1

Permit No. G- 4924

APPLICATION FOR A PERMIT

To Appropriate the Ground Waters of the State of Oregon

I, City of Milton-Freewater
(Name of applicant)
of P. O. Box 108, Milton-Freewater, Oregon, county of Umatilla
(Postoffice Address)

state of Oregon, do hereby make application for a permit to appropriate the following described ground waters of the state of Oregon, **SUBJECT TO EXISTING RIGHTS:**

If the applicant is a corporation, give date and place of incorporation

1. Give name of nearest stream to which the well, tunnel or other source of water development is situated Walla Walla River
(Name of stream)

tributary of Columbia River

2. The amount of water which the applicant intends to apply to beneficial use is 2.0 cubic feet per second or 900 gallons per minute.

3. The use to which the water is to be applied is domestic, industrial, commercial and municipal use.

4. The well or other source is located 850 ft. N. and 250 ft. W. from the S.E. corner of S.E. 1/4 of the N.W. 1/4 of Section 12 T. 5N. R. 35 E. W. M.
(N. or S.) (E. or W.) (Section or subdivision)

The S.E. corner of the S.E. 1/4 of the N.W. 1/4 of Section 12 T. 5N. R. 35 E. W. M. is also the center of said Sec. 12
(If there is more than one well, each must be described. Use separate sheet if necessary)

being within the S.E. 1/4 N.W. 1/4 of Sec. 12, Twp. 5 N., R. 35 E., W. M., in the county of Umatilla

5. The (We intend to use existing pipeline to ~~xxx~~ existing well) xxx miles (Canal or pipe line) in length, terminating in the S.E. 1/4 N.W. 1/4 of Sec. 12, Twp. 5 N., R. 35 E., W. M., the proposed location being shown throughout on the accompanying map. (Smallest legal subdivision)

6. The name of the well or other works is City of Milton-Freewater Well No. 1 old permit No. U-102

DESCRIPTION OF WORKS

7. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

8. The development will consist of redeveloping one (1) well (Give number of wells, tunnels, etc.) having a diameter of 12 inches and an estimated depth of 800 feet. It is estimated that 0 feet of the well will require 112 casing. (Kind) (Feet) Depth to water table is estimated 112 feet of 12" steel casing in already installed in well, perforations are recorded in the casing at 50'. Perforations will be sealed by pressure grouting.

CANAL SYSTEM OR PIPE LINE—

G 4924

9. (a) Give dimensions at each point of canal where materially changed in size, stating miles from headgate. At headgate: width on top (at water line) feet; width on bottom feet; depth of water feet; grade feet fall per one thousand feet.

(b) At miles from headgate: width on top (at water line) feet; width on bottom feet; depth of water feet; grade feet fall per one thousand feet.

(c) Length of pipe, ft.; size at intake in.; in size at ft. from intake in.; size at place of use in.; difference in elevation between intake and place of use, ft. Is grade uniform? Estimated capacity, sec. ft.

10. If pumps are to be used, give size and type 1500 G. P. M. turbine

Give horsepower and type of motor or engine to be used 200 H. P. electric

11. If the location of the well, tunnel, or other development work is less than one-fourth mile from a natural stream or stream channel, give the distance to the nearest point on each of such channels and the difference in elevation between the stream bed and the ground surface at the source of development

Walla Walla River is 1000' to East. River channel is approximately 9' lower than well site.

12. Location of area to be irrigated, or place of use

| Township N. or S. | Range E. or W. of Willamette Meridian | Section | Forty-acre Tract | Number Acres To Be Irrigated |
|-------------------|---------------------------------------|---------|------------------|------------------------------|
| 5 North | Range 35 E. | Sec. 12 | | Municipal |
| 5 North | Range 35 E. | Sec. 1 | | Municipal |
| 5 North | Range 35 E. | Sec. 11 | | Municipal |
| 5 North | Range 35 E. | Sec. 2 | | Municipal |
| 5 North | Range 35 E. | Sec. 13 | | Municipal |
| 5 North | Range 36 E. | Sec. 18 | | Municipal |
| 6 North | Range 35 E. | Sec. 35 | | Municipal |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

(If more space required, attach separate sheet)

Character of soil Gravel

Kind of crops raised

MUNICIPAL SUPPLY--

G 4924

13. To supply the city of Milton-Freewater in Umatilla county, having a present population of 4,510 and an estimated population of 5,000 in 1980.

ANSWER QUESTIONS 14, 15, 16, 17 AND 18 IN ALL CASES

14. Estimated cost of proposed works, \$ 20,000

15. Construction work will begin on or before January 15, 1971

16. Construction work will be completed on or before May 15, 1971

17. The water will be completely applied to the proposed use on or before October 1, 1971

18. If the ground water supply is supplemental to an existing water supply, identify any application for permit, permit, certificate or adjudicated right to appropriate water, made or held by the applicant. Permit No. U-102 allows a water right for 1.5 C.F.S. on Well No. 1 dated January 18, 1937

[Handwritten signature]

Remarks: It is the intent of this Application for water right to allow the City of Milton-Freewater to rework existing Well No. 1. Permit No. U-102 and develop additional water up to a capacity of 3.5 c. f. s. or 1573 G.P.M. The City Of Milton-Freewater does not wish to change the priority date of the existing Permit No. U-102, for 1.5 c. f. s. dated Jan. 18, 1937.

Work to be done on the well includes sealing recorded perforations at 50', checking seal into basalt and deepening well in an attempt to improve the capacity of the well. Also when a pump is installed after reworking the discharge flange will be installed above ground and well casing will be extended above ground level to meet State of Oregon requirements.

STATE OF OREGON, } ss.
County of Marion, }

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for

In order to retain its priority, this application must be returned to the State Engineer, with corrections on or before, 19

WITNESS my hand this day of, 19

STATE ENGINEER
By ASSISTANT

STATE OF OREGON, }
County of Marion, } ss.

PERMIT

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 2.0 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from Well No. 1

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer

The well shall be cased as necessary in accordance with good practice and if the flow is artesian the works shall include proper capping and control valve to prevent the waste of ground water.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is January 4, 1971

Actual construction work shall begin on or before November 23, 1972 and shall

thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1973
Extended to Oct. 1, 1974 Extended to Oct. 1979

Complete application of the water to the proposed use shall be made on or before October 1, 1974
Extended to Oct. 1, 1974 Extended to Oct. 1979

WITNESS my hand this 23rd day of November, 1971

Chris L. Wheeler
STATE ENGINEER

Application No. G-5389
Permit No. G-4924

PERMIT

TO APPROPRIATE THE GROUND
WATERS OF THE STATE
OF OREGON

This instrument was first received in the office of the State Engineer at Salem, Oregon, on the 4th day of January 1971, at 8:00 o'clock A. M.

Returned to applicant:

Approved: November 23, 1971

Recorded in book No. of Ground Water Permits on page G-4924

CHRIS L. WHEELER
STATE ENGINEER
Drainage Basin No. 7 page 68

\$ 27.00

BC- Extended to October 1, 1981 (10-1-81) 66-1-01

| Water Right Information Query Results | |
|---|---|
| Contact Information | Documents <small>View all associated documents</small> |
| <p>▼ Current contact information</p> <p>OWNER: ▶ CITY OF MILTON FREEWATER PO BOX 6 MILTON FREEWATER, OR 97862</p> | <p>▶ Application: G 13494 digital map</p> <p>▶ Permit: G 12582 document, digital map, paper map</p> <p>▶ View right with New Web Mapping (beta)</p> |
| Water Right Information | |
| <p>Status: Non-Cancelled</p> <p>County: Umatilla</p> <p>File Folder Location: Salem</p> <p>Watermaster District: 5</p> | |
| Point(s) of Diversion | |
| ▶ POD 1 - A WELL > WALLA WALLA RIVER | |
| Place(s) of Use <small>View all associated places of use</small> | |
| ▶ Use - MUNICIPAL USES (Primary); Priority Date: 8/16/1993 | |
| Water Right Genealogy | |
| ---No genealogy records available for this water right, try the family link below instead. | |

[View Water Rights in same Family](#)

[Help understanding and working with the Water Rights Information System](#)

[Report Errors with Water Right Data](#)

[Return to WRIS Query](#)

STATE OF OREGON

COUNTY OF UMATILLA

PERMIT TO APPROPRIATE THE PUBLIC WATERS

THIS PERMIT IS HEREBY ISSUED TO

CITY OF MILTON-FREEWATER
PO BOX 6
MILTON-FREEWATER, OREGON 97862

(541) 938-5531

The specific limits for the use are listed below along with conditions of use.

APPLICATION FILE NUMBER: G-13494

SOURCE OF WATER: A WELL IN WALLA WALLA RIVER BASIN

PURPOSE OR USE: MUNICIPAL USE

RATE OF USE: 3.34 CUBIC FEET PER SECOND

PERIOD OF USE: YEAR ROUND

DATE OF PRIORITY: FEBRUARY 27, 1996

POINT OF DIVERSION LOCATION: SW 1/4 SE 1/4, SECTION 12, T5N, R35E, W.M.;
840 FEET NORTH AND 2020 FEET WEST FROM THE SE CORNER OF SECTION 12

THE PLACE OF USE IS LOCATED AS FOLLOWS:

SERVICE AREA OF THE CITY OF MILTON-FREEWATER

Measurement, recording and reporting conditions:

- A. Before water use may begin under this permit, the permittee shall install a meter or other suitable measuring device as approved by the Director. The permittee shall maintain the meter or measuring device in good working order, shall keep a complete record of the amount of water used each month and shall submit a report which includes the recorded water use measurements to the Department annually or more frequently as may be required by the Director. Further, the Director may require the permittee to report general water use information, including the place and nature of use of water under the permit.
- B. The permittee shall allow the watermaster access to the meter or measuring device; provided however, where the meter or measuring device is located within a private structure, the watermaster shall request access upon reasonable notice.

Application G-13494 Water Resources Department

PERMIT G-12582

PAGE 2

The water user shall develop a plan to monitor and report the impact of water use under this permit on water levels within the aquifer that provides water to the permitted well(s). The plan shall be submitted to the Department within one year of the date the permit is issued and shall be subject to the approval of the Department. At a minimum, the plan shall include a program to periodically measure static water levels within the permitted well(s) or an adequate substitute such as water levels in nearby wells. The plan shall also stipulate a reference water level against which any water-level declines will be compared. If a well listed on this permit (or replacement well) displays a total static water-level decline of 25 or more feet over any period of years, as compared to the reference level, then the water user shall discontinue use of, or reduce the rate or volume of withdrawal from, the well(s). Such action shall be taken until the water level recovers to above the 25-foot decline level or until the Department determines, based on the water user's and/or the Department's data and analysis, that no action is necessary because the aquifer in question can sustain the observed declines without adversely impacting the resource or senior water rights. The water user shall in no instance allow excessive decline, as defined in Commission rules, to occur within the aquifer as a result of use under this permit.

Within TWO YEARS of permit issuance, the permittee shall submit a water management and conservation plan consistent with Oregon Administrative Rules Chapter 690, Division 86.

If at any time the well or its use:

- a) acts as a conduit for groundwater contamination,
- b) allows loss of artisan pressure,
- c) allows waste of groundwater,
- d) interferes with senior groundwater users or
- e) interferes with surface water sources,

the Department may require that the well be repaired in accordance with current well construction standards.

STANDARD CONDITIONS

The wells shall be constructed in accordance with the General Standards for the Construction and Maintenance of Water Wells in Oregon. The works shall be equipped with a usable access port, and may also include an air line and pressure gauge adequate to determine water level elevation in the well at all times.

The use shall conform to such reasonable rotation system as may be ordered by the proper state officer.

Prior to receiving a certificate of water right, the permit holder shall submit the results of a pump test meeting the department's standards, to the Water Resources Department. The Director may require water level or pump test results every ten years thereafter.

PAGE 3

Failure to comply with any of the provisions of this permit may result in action including, but not limited to, restrictions on the use, civil penalties, or cancellation of the permit.

This permit is for the beneficial use of water without waste. The water user is advised that new regulations may require the use of best practical technologies or conservation practices to achieve this end.


By law, the land use associated with this water use must be in compliance with statewide land-use goals and any local acknowledged land-use plan.

The use of water shall be limited when it interferes with any prior surface or ground water rights.

The Director finds that the proposed use(s) of water described by this permit, as conditioned, will not impair or be detrimental to the public interest.

Actual construction of the well shall begin within one year from permit issuance and shall be completed on or before October 1, 1998. Complete application of the water to the use shall be made on or before October 1, 1999.

Issued July 8, 1996


for Martha O. Pagel Director
Water Resources Department

Application G-13494 Water Resources Department
Basin 07 Volume 1, Walla Walla River & Misc.
MGMT.CODES 7AG, 7AR

PERMIT G-12582
District 05

WELL NO.6

| Water Right Information Query Results | |
|--|---|
| Contact Information | Documents <small>View All Related Documents</small> |
| ▼ Current contact information OWNER: ▶ CITY OF MILTON FREEWATER MILTON FREEWATER, OR 97862 | ▶ Application: U 511 digital map ▶ Permit: U 462 document, digital map ▶ Certificate: 23519 document, digital map, paper map ▶ View right with New Web Mapping (beta) |
| Water Right Information | |
| Status: Non-Cancelled County: Umatilla File Folder Location: Salem Watermaster District: 5 | |
| Point(s) of Diversion | |
| ▶ POD 1 - MILTON FREEWATER WE > WALLA WALLA RIVER | |
| Place(s) of Use <small>Add ITIS grouping</small> | |
| ▶ Use - MUNICIPAL USES (Primary); Priority Date: 7/16/1952 | |
| Water Right Genealogy | |
| ---No genealogy records available for this water right, try the family link below instead. | |

[View Water Rights in same Family](#)

[Help understanding and working with the Water Rights Information System](#)

[Report Errors with Water Right Data](#)

[Return to WRIS Query](#)

23519

Permit No. 12-1177
APPLICATION FOR A PERMIT

Appropriate the Underground Waters of the State of Oregon

I, City of Milton-Freewater, Oregon
(Name of applicant)
of Milton
(Postoffice), county of Umatilla
state of Oregon, do hereby make application for a permit to appropriate the

following described underground waters of the state of Oregon, **SUBJECT TO EXISTING RIGHTS:**
If the applicant is a corporation, give date and place of incorporation. Charter
Milton-Freewater January 1, 1951

1. Give name of nearest stream to which the well, tunnel or other source of water development is situated Walla Walla River
(Name of stream)
tributary of Columbia River

2. The amount of water which the applicant intends to apply to beneficial use is 3.5 cubic feet per second.

3. The use to which the water is to be applied is City Water Supply
(Domestic and Industrial)

4. The place where the water is to be pumped or developed is located
2^d I.P. = S 86° 44' W - 527. feet from center Section 2 Twp 5 N. Range 35 E W
(Give distance and bearing from section corner)
and Well is S. 22° 37' E. - 39 from Iron Pipe

being within the N.E. 1/4 of S.W. 1/4 of Sec. 2 Twp. 5 N R. 35 E.
W. M., in the county of Umatilla

5. The 8" Pipe Line (Cased or pipe line) to be 15 feet ~~XXXX~~
in length, terminating in the N.E. 1/4 of S.W. 1/4 (Show that legal subdivisions) of Sec. 2 Twp. 5 N
R. 35 E, W. M., the proposed location being shown throughout on the accompanying map.

6. The name of the well or other works is Milton-Freewater Well No. 6

DESCRIPTION OF WORKS

7. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.
.....
.....
.....

8. The development will consist of one (Give number of wells, tunnels, etc.) having a diameter of 12 inches and an estimated depth of 952 feet.

_____ (Give distance in rise, stating miles from _____ feet; width on bottom _____ feet; depth of water _____ feet; _____ feet fall per one _____ miles from headgate: width on top (at water line) _____ feet; width on bottom _____ feet; depth of water _____ feet; _____ feet fall per one thousand feet.

(2) Length of pipe, _____ ft.; size at intake, _____ in.; in size at _____ ft. _____ in.; size at place of use _____ in.; difference in elevation between intake and place of use, _____ ft. Is grade uniform? _____ Estimated capacity, _____ sec. ft.

10. If pumps are to be used, give size and type Cook Deep Well Turbine Pump -
7 stages; 2" shaft; 150 feet of 10" Column & 1300 GPM 305 Ft.

Give capacity and type of motor or engine to be used 125 HP General Electric
Motor - 220/440

11. If the location of the well, tunnel, or other development work is less than one-fourth mile from a natural stream or stream channel, give the distance to be the nearest point on each of such channels and the difference in elevation between the stream bed and the ground surface at the source of development

12. Location of area to be irrigated, or place of use in water system of former city of Freewater

| Township | Range | Section | Forty-acre Tract | Number Acres To Be Irrigated |
|----------|--------|---------|---|------------------------------|
| 5 N | 35 EWM | 1 | N.W. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | S.W. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | 2 | N $\frac{1}{2}$ of N.E. $\frac{1}{4}$ of S.W. $\frac{1}{4}$ | |
| | | | N.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | S.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | N.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | N.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | S.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | S.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | | |
| | | | | |

(If more space required, attach separate sheet)

(a) Character of soil _____
 (b) Kind of crops raised _____

MUNICIPAL SUPPLY—

13. (a) To supply the city of Milton-Freewater
Dematilla county, having a present population of 3851
 (Name of) and an estimated population of _____ in 19_____

4-483

Well drilled in 1950

Installation completed on or before July, 1952

Water will be completely applied to the proposed use on or before August 1, 1952

City of Milton-Freewater
 by: Robert L. [unclear]
 Robert E. Brunton
 City Manager

Remarks: This well was drilled by the former City of Freewater in 1950 and abandoned as being dry. The City of Milton-Freewater has been running test on this well for sometime and has found an adequate water supply. The water was tested by the State and found to conform to standards of purity for drinking water. However, the well is now in the process of being sealed off.

STATE OF OREGON, }
 County of Marion, } ss.

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for

In order to retain its priority, this application must be returned to the State Engineer, with corrections on or before, 19.....

WITNESS my hand this day of 19.....

STATE ENGINEER

That I have examined the foregoing application and do hereby grant the same, **PERMITTING RIGHTS** and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 3.50 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from Milton-Fraswater Well No. 6

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be so cased as to prevent the loss of underground water.

The priority date of this permit is July 16, 1952

Actual construction work shall begin on or before August 29, 1953 and shall

thereafter be prosecuted with reasonable diligence and be completed on or before

October 1, 1954

Complete application of the water to the proposed use shall be made on or before

October 1, 1955

WITNESS my hand this 29th day of August, 1952

Chas E Stricklin
STATE ENGINEER

Application No. 41-5711
Permit No. 11-462

PERMIT
TO APPROPRIATE THE UNDER-
GROUND WATERS OF THE
STATE OF OREGON

This instrument was first received in the
office of the State Engineer at Salem, Oregon,
on the 16th day of July,
1952 at 1:00 o'clock P. M.

Returned to applicant:

Corrected application received:

Approved:

August 29, 1952
Recorded in book No. 2 of
Permits on page 462

CHAS. E. STRICKLIN
STATE ENGINEER

Drainage Basin No. 7 Page 4 of 4

Fees Paid \$26.00

State Printing Dept. 31196

STATE OF OREGON
COUNTY OF WATILLA
CERTIFICATE OF WATER RIGHT

This Is to Certify, That CITY OF MILTON-FREEWATER

of Milton-Freewater, State of Oregon, has made proof to the satisfaction of the STATE ENGINEER of Oregon, of a right to the use of the waters of Milton-Freewater Well No. 6 for the purpose of a tributary of Walla Walla River municipal under Permit No. U-462 of the State Engineer, and that said right to the use of said waters has been perfected in accordance with the laws of Oregon; that the priority of the right hereby confirmed dates from July 16, 1952; that the amount of water to which such right is entitled and hereby confirmed, for the purposes aforesaid, is limited to an amount actually beneficially used for said purposes, and shall not exceed 3.50 cubic feet per second

or its equivalent in case of rotation, measured at the point of diversion from the stream. The point of diversion is located in the NE 1/4 SW 1/4 Section 2, Township 5 North, Range 35 East, W.M.

The amount of water used for irrigation, together with the amount secured under any other right existing for the same lands, shall be limited to _____ of one cubic foot per second per acre.

and shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the place of use under the right hereby confirmed, and to which such right is appurtenant, is as follows:

- NW 1/4 NW 1/4
- SW 1/4 NW 1/4
- N 1/2 NE 1/4 SW 1/4
- Section 1
- NE 1/4 NW 1/4
- SE 1/4 NW 1/4
- NE 1/4 NE 1/4
- NW 1/4 NE 1/4
- SW 1/4 NE 1/4
- SE 1/4 NE 1/4

Section 2
Township 5 North, Range 35 East, W.M.

The right to the use of the water for the purposes aforesaid is restricted to the lands or place of use herein described.

WITNESS the signature of the State Engineer, affixed

this 20th day of December, 1957

LEWIS A. STANLEY State Engineer

WELL NO. 4

| Water Right Information Query Results | |
|---|--|
| Contact Information | Documents <small>View all associated documents</small> |
| <p>▼ Current contact information</p> <p>OWNER: ▶ CITY OF MILTON FREEWATER MILTON FREEWATER, OR 97862</p> | <p>▶ Application: U 808 digital map</p> <p>▶ Permit: U 717 document, digital map</p> <p>▶ Certificate: 23532 document, digital map, paper map</p> <p>▶ View right with New Web Mapping (beta)</p> |
| Water Right Information | |
| <p>Status: Non-Cancelled</p> <p>County: Umatilla</p> <p>File Folder Location: Salem</p> <p>Watermaster District: 5</p> | |
| Point(s) of Diversion | |
| ▶ POD 1 - WELL 4 > LITTLE WALLA WALLA RIVER | |
| Place(s) of Use <small>Add IRIS drawings</small> | |
| ▶ Use - MUNICIPAL USES (Primary); Priority Date: 4/13/1955 | |
| Water Right Genealogy | |
| ---No genealogy records available for this water right, try the family link below instead. | |

[View Water Rights in same Family](#)

[Help understanding and working with the Water Rights Information System](#)

[Report Errors with Water Right Data](#)

[Return to WRIS Query](#)

U-717

CANAL SYSTEM OR PIPE LINE—

9. (a) Give dimensions at each point of canal where materially changed in size, stating miles from headgate. At headgate: width on top (at water line) feet; width on bottom feet; depth of water feet; grade feet fall per one thousand feet.

(b) At miles from headgate: width on top (at water line) feet; width on bottom feet; depth of water feet; grade feet fall per one thousand feet.

(c) Length of pipe, ft.; size at intake, in.; in size at ft. from intake in.; size at place of use in.; difference in elevation between intake and place of use, ft. Is grade uniform? Estimated capacity, sec. ft.

10. If pumps are to be used, give size and type Pearless Turbine Rated ⁴⁶⁰ ~~200~~ P.H.M

Give capacity and type of motor or engine to be used U.S. Motor 55 H.P.

11. If the location of the well, tunnel, or other development work is less than one-fourth mile from a natural stream or stream channel, give the distance to be the nearest point on each of such channels and the difference in elevation between the stream bed and the ground surface at the source of development 880 ft. to Little Walla Walla River (difference in elevation 8 ft.)

12. Location of area to be irrigated, or place of use in water system of former City of Freewater

| Township | Range | Section | Part-acre Tract | Number Acres To Be Irrigated |
|----------|--------|---------|--|------------------------------|
| 5 N | 35 EWM | 1 | N.W. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | S.W. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | N.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | S.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | N.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | S.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | 2 | N.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | S.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ | |
| | | | N.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | N.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | S.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |
| | | | S.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |

(If more space required, attach separate sheet)

(a) Character of soil

(b) Kind of crops raised

MUNICIPAL SUPPLY—

13. (a) To supply ~~quantity~~ portion of City of Hilton-Freewater

Umatilla county, having a present population of 3851

and an estimated population of in 19 50

V-717

- N. Estimated cost of proposed work: \$ 1,702.00 Approved value
- O. Construction work will begin on or before August 14, 1954
- P. Construction work will be completed on or before _____
- Q. The water will be completely supplied to the proposed use on or before May 1954 in operation since 1954.

Robert S. Buntow
(Signature of applicant)

City Manager

Remarks: This installation was placed in June 1954.
There is no available log of this well. The driller said that no
log was kept at that time. No known record of casing.

STATE OF OREGON, }
 County of Marion, } ss.

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for _____

In order to retain its priority, this application must be returned to the State Engineer, with corrections on or before _____, 19_____.

WITNESS my hand this _____ day of _____, 19_____.

STATE ENGINEER

STATE OF OREGON,

PERMIT

County of Marion, } ss.

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 1.0 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from Well No. 4

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be so cased as to prevent the loss of underground water.

The priority date of this permit is April 13, 1955

Actual construction work shall begin on or before July 20, 1956 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1957

Complete application of the water to the proposed use shall be made on or before October 1, 1958

WITNESS my hand this 20th day of July, 1955

Lewis A. Stanley STATE ENGINEER

Application No. U-808 Permit No. M-717

PERMIT

TO APPROPRIATE THE UNDERGROUND WATERS OF THE STATE OF OREGON

This instrument was first received in the office of the State Engineer at Salem, Oregon, on the 13th day of April 1955, at 1:00 o'clock P. M.

Returned to applicant:

Corrected application received:

Approved:

July 20, 1955 Recorded in book No. 3 Permits on page U-717

LEWIS A. STANLEY STATE ENGINEER

Drainage Basin No. 7 Page 246

Fees Paid \$ 2 0 00

State Printing Dept. 31175

Permit A-7-201-54

State Printing Dept. 1957

STATE OF OREGON
COUNTY OF UMATILLA

CERTIFICATE OF WATER RIGHT

This Is to Certify, That CITY OF MILTON-FREEWATER

of Milton-Freewater, State of Oregon, has made proof to the satisfaction of the STATE ENGINEER of Oregon, of a right to the use of the waters of Well No. 4 a tributary of Little Walla Walla River, trib. of Columbia River for the purpose of municipal under Permit No. U-717 of the State Engineer; and that said right to the use of said waters has been perfected in accordance with the laws of Oregon; that the priority of the right hereby confirmed dates from April 13, 1955

that the amount of water to which such right is entitled and hereby confirmed, for the purposes aforesaid, is limited to an amount actually beneficially used for said purposes, and shall not exceed 1.0 cubic foot per second

or its equivalent in case of rotation, measured at the point of diversion from the stream. The point of diversion is located in the SW 1/4 NE 1/4, Section 2, Township 5 North, Range 35 East, W.M.

The amount of water used for irrigation, together with the amount secured under any other right existing for the same lands, shall be limited to of one cubic foot per second per acre,

and shall conform to such reasonable rotation system as may be ordered by the proper state officer. A description of the place of use, under the right hereby confirmed, and to which such right is appurtenant, is as follows:

- NW 1/4 NW 1/4
- SW 1/4 NW 1/4
- NE 1/4 NE 1/4 SW 1/4
- Section 1
- NE 1/4 NW 1/4
- SE 1/4 NW 1/4
- NE 1/4 NE 1/4
- NW 1/4 NE 1/4
- SW 1/4 NE 1/4
- SE 1/4 NE 1/4

Section 2
Township 5 North, Range 35 East, W.M.

The right to the use of the water for the purposes aforesaid is restricted to the lands or place of use herein described.

WITNESS the signature of the State Engineer, affixed

this 20th day of December, 1957.

LEWIS A. STANLEY, State Engineer

WELL NO. 5

| Water Right Information Query Results | |
|--|---|
| Contact Information | Documents <small>View Miscellaneous Documents</small> |
| ▼ Current contact information OWNER: ▶ CITY OF MILTON FREEWATER MILTON FREEWATER, OR 97862 | ▶ Application: U 809 digital map ▶ Permit: U 718 document, digital map ▶ Certificate: 23533 document, digital map, paper map ▶ View right with New Web Mapping (beta) |
| Water Right Information | |
| Status: Non-Cancelled County: Umatilla File Folder Location: Salem Watermaster District: 5 | |
| Point(s) of Diversion | |
| ▶ POD 1 - WELL 5 > LITTLE WALLA WALLA RIVER | |
| Place(s) of Use <small>View Miscellaneous</small> | |
| ▶ Use - MUNICIPAL USES (Primary); Priority Date: 4/13/1955 | |
| Water Right Genealogy | |
| No genealogy records available for this water right, try the family link below instead. | |

[View Water Rights in same Family](#)

[Help understanding and working with the Water Rights Information System](#)

[Report Errors with Water Right Data](#)

[Return to WRIS Query](#)

23935

RECEIVED
APR 8 1955
STATE ENGINEER
SALEM, OREGON

Permit No. L-718

APPLICATION FOR A PERMIT

To appropriate the Underground Waters of the State of Oregon

I, Milton-Fresswater
(Name of applicant)
of Milton-Fresswater
(Postoffice), county of Umatilla
state of Oregon, do hereby make application for a permit to appropriate the following described underground waters of the state of Oregon, SUBJECT TO EXISTING RIGHTS:

If the applicant is a corporation, give date and place of incorporation

Milton-Fresswater, Oregon January 1, 1953

1. Give name of nearest stream to which the well, tunnel or other source of water development is situated Little Walla Walla River
(Name of stream)

tributary of Columbia River

2. The amount of water which the applicant intends to apply to beneficial use ~~is~~ 2.7 cubic feet per second.

3. The use to which the water is to be applied is Domestic and Commercial

4. The place where the water is to be pumped or developed is located 2" Iron Pipe is
N 32° - 2' E 365.5 ft. of 1/4 corner between sections 1 & 2 T 5 N. R. 35 EWM
2" pipe is S. 50° - 35' ^{37.5} W. of well in S.W. 1/4 of N.W. 1/4 sec. 1 Twp. 5NR. 35 EWM
S.W. 1/4

being within the _____ of Sec. _____, Twp. _____, R. _____
W. M., in the county of Umatilla

5. The _____ to be _____ miles
(Diameter or pipe size)
in length, terminating in the _____ of Sec. _____, Twp. _____
(Smallest legal subdivision)
R. _____, W. M., the proposed location being shown throughout on the accompanying map.

6. The name of the well or other works is Well No. 5

DESCRIPTION OF WORKS

7. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

8. The development will consist of one well having a
(Give number of wells, tunnels, etc.)
diameter of 8" O.D. pipes and an estimated depth of 502 feet.
This well pumps directly into the water system.

U-718

CANAL SYSTEM OR PIPE LINE—

9. (a) Give dimensions at each point of canal where materially changed in size, stating miles from headgate. At headgate: width on top (at water line) feet; width on bottom feet; depth of water feet; grade feet fall per one thousand feet.

(b) At miles from headgate: width on top (at water line) feet; width on bottom feet; depth of water feet; grade feet fall per one thousand feet.

(c) Length of pipe, ft.; size at intake, in.; in size at ft. from intake in.; size at place of use in.; difference in elevation between intake and place of use, ft. Is grade uniform? Estimated capacity, sec. ft.

10. If pumps are to be used, give size and type 1200
Frictionless turbine Q.P.M.

Give capacity and type of motor or engine to be used 150 H.P. U.S. Motor

11. If the location of the well, tunnel, or other development work is less than one-fourth mile from a natural stream or stream channel, give the distance to be the nearest point on each of such channels and the difference in elevation between the stream bed and the ground surface at the source of development

35 feet to Little Walla Walla River (no difference in elevation)
Little Walla Walla River in reality is a power canal to operate flour mill

12. Location of area to be irrigated, or place of use Water system of former City of Freewater

| Township | Range | Section | Forty-acre Tract | Number Acres To Be Irrigated |
|----------|---------------------|---------|---|------------------------------|
| 5 N | WILLAMETTE MERIDIAN | 35 EWM | 1 N.W. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ S.W. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ N $\frac{1}{2}$ of N.E. $\frac{1}{4}$ of S.W. $\frac{1}{4}$ | |
| 5 N | | 35 EWM | 2 N.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ S.E. $\frac{1}{4}$ of N.W. $\frac{1}{4}$ N.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ N.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ S.W. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ S.E. $\frac{1}{4}$ of N.E. $\frac{1}{4}$ | |

(If more space required, attach separate sheet)

(a) Character of soil

(b) Kind of crops raised

MUNICIPAL SUPPLY—

13. (a) To supply the city of To supply portion of City of Milton-Freewater

Umatilla county, having a present population of 3851
(Name of)
and an estimated population of in 1950

U-718

Appraised value

- 14. Estimated cost of proposed work \$ 11,220.00
- 15. Construction work will begin on or before Completed in 1954
- 16. Construction work will be completed on or before _____
- 17. The water will be completely applied to the proposed use on or before this well has been in operation since 1936

Robert S. Dunton
(Signature of applicant)

City Manager

Remarks: In Item 2, the amount requested is slightly higher than we are now using because some time in the future we may want to put in larger pumps. This was accomplished in June 1954 and the above notes are the status of the present setting.

In case you do not have the log of this well, below is a copy:

Well #5 Drilled by A. A. Durand & Son 1936
Altitude of top of ground above sea level 995

Log

Recent alluvium and old gravel

| | Thickness Ft. | Depth Ft. |
|----------------------------|---------------|-----------|
| Soil | 3 | 3 |
| Gravel, loose | 77 | 80 |
| Clay | 10 | 90 |
| Boulders & Gravel | 45 | 135 |
| Clay & Sand | 10 | 145 |
| Gravel & Loose Boulders | 15 | 160 |
| Basalt Block, Hard | 82 | 242 |
| Basalt Bed, Porous | 48 | 290 |
| Basalt Bed, Black | 115 | 405 |
| Basalt Bed | 30 | 435 |
| Basalt Black Water Bearing | 67 | 502 |

Casing 18" set to 40 ft.
12" set to 172 ft.

STATE OF OREGON, }
County of Marion, } ss.

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for _____

In order to retain its priority, this application must be returned to the State Engineer, with corrections on or before _____, 19_____

WITNESS my hand this _____ day of _____, 19_____

STATE ENGINEER

STATE OF OREGON,

PERMIT

County of Marion,

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 2.70 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from Well No. 5

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to of one cubic foot per second

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be so cased as to prevent the loss of underground water.

The priority date of this permit is April 13, 1955

Actual construction work shall begin on or before July 20, 1956 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1957

Complete application of the water to the proposed use shall be made on or before October 1, 1958

WITNESS my hand this 20th day of July, 1955

Lewis A. Stanley STATE ENGINEER

Application No. U-809 Permit No. M-718

PERMIT TO APPROPRIATE THE UNDERGROUND WATERS OF THE STATE OF OREGON

This instrument was first received in the office of the State Engineer at Salem, Oregon, on the 19th day of April, 1955, at 1:00 o'clock P. M.

Returned to applicant:

Corrected application received:

Approved:

July 20, 1955 Recorded in book No. 3 of Permits on page U-718

LEWIS A. STANLEY STATE ENGINEER

Drainage Basin No. 7 Page 24C Fees Paid \$ 24.00

STATE OF OREGON
COUNTY OF UMATILLA
CERTIFICATE OF WATER RIGHT

This Is to Certify, That CITY OF MILTON-FREEWATER

of Milton-Freewater, State of Oregon, has made proof to the satisfaction of the STATE ENGINEER of Oregon, of a right to the use of the waters of Well No. 5, a tributary of Little Walla Walla River, trib. of Columbia River for the purpose of municipal under Permit No. U-718 of the State Engineer, and that said right to the use of said waters has been perfected in accordance with the laws of Oregon; that the priority of the right hereby confirmed dates from April 13, 1955

that the amount of water to which such right is entitled and hereby confirmed, for the purposes aforesaid, is limited to an amount actually beneficially used for said purposes, and shall not exceed 2.70 cubic feet per second

or its equivalent in case of rotation, measured at the point of diversion from the stream. The point of diversion is located in the SW $\frac{1}{4}$ SW $\frac{1}{4}$ NW $\frac{1}{4}$, Section 1, Township 5 North, Range 35 East, W.M.

The amount of water used for irrigation, together with the amount secured under any other right existing for the same lands, shall be limited to ----- of one cubic foot per second per acre,

and shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the place of use under the right hereby confirmed, and to which such right is appurtenant, is as follows:

NW $\frac{1}{4}$ NW $\frac{1}{4}$
SW $\frac{1}{4}$ NW $\frac{1}{4}$
N $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$
Section 1
NE $\frac{1}{4}$ NW $\frac{1}{4}$
SE $\frac{1}{4}$ NW $\frac{1}{4}$
NE $\frac{1}{4}$ NE $\frac{1}{4}$
NW $\frac{1}{4}$ NE $\frac{1}{4}$
SW $\frac{1}{4}$ NE $\frac{1}{4}$
SE $\frac{1}{4}$ NE $\frac{1}{4}$
Section 2

Township 5 North, Range 35 East, W.M.

The right to the use of the water for the purposes aforesaid is restricted to the lands or place of use herein described.

WITNESS the signature of the State Engineer, affixed

this 20th day of December, 1957.

LEWIS A. STANLEY
State Engineer

WELL NO. 8

| Water Right Information Query Results | |
|--|---|
| Contact Information | Documents <small>View all documents</small> |
| <p>▼ Current contact information</p> <p>OWNER: CITY OF MILTON FREEWATER BOX 108 MILTON FREEWATER, OR 97862</p> | <p>▶ Application: G 2502 digital map</p> <p>▶ Permit: G 2312 document, digital map</p> <p>▶ Certificate: 41011 document, digital map, paper map</p> <p>▶ Order(s)</p> <p>▶ View right with New Web Mapping (beta)</p> |
| Water Right Information | |
| <p>Status: Non-Cancelled</p> <p>County: Umatilla</p> <p>File Folder Location: Salem</p> <p>Watermaster District: 5</p> | |
| Point(s) of Diversion | |
| ▶ POD 1 - WELL 8 > WALLA WALLA RIVER | |
| Place(s) of Use <small>Add this record</small> | |
| ▶ Use - MUNICIPAL USES (Primary); Priority Date: 12/13/1962 | |
| Water Right Genealogy | |
| ... No genealogy records available for this water right, try the family link below instead. | |

[View Water Rights in same Family](#)

[Help understanding and working with the Water Rights Information System](#)

[Report Errors with Water Right Data](#)

[Return to WRIS Query](#)

41211

DEC 1 1967

Permit No. G-2312

APPLICATION FOR A PERMIT

To appropriate the Ground Waters of the State of Oregon

I, City of Milton-Freewater, a municipal corporation of Box 108 Milton-Freewater, county of Umatilla state of Oregon, do hereby make application for a permit to appropriate the following described ground waters of the state of Oregon, SUBJECT TO EXISTING RIGHTS:

If the applicant is a corporation, give date and place of incorporation

December 27, 1950 at Milton-Freewater, Oregon

1. Give name of nearest stream to which the well, tunnel or other source of water development is situated Walla Walla River tributary of Columbia River

2. The amount of water which the applicant intends to apply to beneficial use is 6.6 cubic feet per second or 3000 gallons per minute.

3. The use to which the water is to be applied is Municipal Supply

4. The well or other source is located ... ft. and ... ft. from the corner of ... (Section or subdivision)

The well lies N. 33°35' East a distance of 2143' from the S. W. corner of Section 18, Township 5 North, Range 36 East of Willamet Meridian. being within the S. W. 1/4 (NW 1/4 SW 1/4) of Sec. 18, Twp. 5 N., R. 36 E., W. M., in the county of Umatilla

5. The Pipeline to be 0.9 miles in length, terminating in the S. W. 1/4 of S. E. 1/4 of Sec. 12, Twp. 5 N., R. 35 E., W. M., the proposed location being shown throughout on the accompanying map.

6. The name of the well or other works is Milton-Freewater Well No. 8

DESCRIPTION OF WORKS

7. If the flow to be utilized is artesian, the works to be used for the control and conservation of the supply when not in use must be described.

Capped well with discharge tee and gate valve

8. The development will consist of a well having a diameter of 16 inches and an estimated depth of 1000 feet. It is estimated that 30 feet of the well will require Steel casing. Depth to water table is estimated 10 feet

G-2312

CANAL SYSTEM OR PIPE LINE—

9. (a) Give dimensions at each point of canal where materially changed in size, stating miles from headgate. At headgate: width on top (at water line) _____ feet; width on bottom _____ feet; depth of water _____ feet; grade _____ feet fall per one thousand feet.

(b) At _____ miles from headgate: width on top (at water line) _____ feet; width on bottom _____ feet; depth of water _____ feet; grade _____ feet fall per one thousand feet.

(c) Length of pipe, 4800 ft.; size at intake, 12" in.; in size at 2500 ft. from intake 12 in.; size at place of use 12 in.; difference in elevation between intake and place of use, 165 ft. Is grade uniform? Approximate Estimated capacity, 8 sec. ft.

10. If pumps are to be used, give size and type 3000 GPM vertical turbine

Give horsepower and type of motor or engine to be used 150 HP VHS squirrel cage electric

11. If the location of the well, tunnel, or other development work is less than one-fourth mile from a natural stream or stream channel, give the distance to the nearest point on each of such channels and the difference in elevation between the stream bed and the ground surface at the source of development 100 ft. from channel or Walla Walla River. Stream bed is approximately 10 ft. below elevation of ground at well site.

12. Location of area to be irrigated, or place of use City of Milton-Freewater

| Township N. or S. | Range E. or W. of Willamette Meridian | Section | Partly-acre Tract | Number Acres To Be Irrigated |
|-------------------|---------------------------------------|--------------|---|------------------------------|
| 5 North | 35 East | 1, 2, 11, 12 | | 2500 |
| | | 1 | NW ¹ / ₄ and SW ¹ / ₄ | Municipal |
| | | 2 | NE ¹ / ₄ and SE ¹ / ₄ | " |
| | | | E ¹ / ₂ NW ¹ / ₄ | " |
| | | | NE ¹ / ₄ SW ¹ / ₄ | " |
| | | 11 | NE ¹ / ₄ NE ¹ / ₄ | " |
| | | 12 | N ¹ / ₂ NE ¹ / ₄ | " |
| | | | NW ¹ / ₄ | " |
| | | | E ¹ / ₂ SW ¹ / ₄ | " |
| | | | NW ¹ / ₄ SW ¹ / ₄ | " |
| | | | SE ¹ / ₄ | " |

(If more space required, attach separate sheet)

Character of soil gravel

Kind of crops raised

G- 2312

MUNICIPAL SUPPLY--

II. To supply the city of Milton-Freewater
in Wasilla county, having a present population of 4110 per 1960 census
and an estimated population of 5654 in 1980.

ANSWER QUESTIONS 14, 15, 16, 17 AND 18 IN ALL CASES

- 14. Estimated cost of proposed works, \$ 50,000
- 15. Construction work will begin on or before July 1, 1963
- 16. Construction work will be completed on or before July 1, 1964
- 17. The water will be completely applied to the proposed use on or before July 1, 1964

18. If the ground water supply is supplemental to an existing water supply, identify any application for permit, permit, certificate or adjudicated right to appropriate water, made or held by the applicant. Permit #7830, #2391 - Well Permits: U-462, U-150, U-717, U-718 U-102, U-172.

[Handwritten Signature]
(Signature of applicant) City Recorder

Remarks: _____

STATE OF OREGON, }
County of Marion, } ss.

This is to certify that I have examined the foregoing application, together with the accompanying maps and data, and return the same for _____

In order to retain its priority, this application must be returned to the State Engineer, with corrections on or before _____, 19_____.

WITNESS my hand this _____ day of _____, 19_____.

STATE ENGINEER
By _____
ASSISTANT

STATE OF OREGON, }
County of Marion, } ss. PERMIT

This is to certify that I have examined the foregoing application and do hereby grant the same, SUBJECT TO EXISTING RIGHTS and the following limitations and conditions:

The right herein granted is limited to the amount of water which can be applied to beneficial use and shall not exceed 6.6 cubic feet per second measured at the point of diversion from the well or source of appropriation, or its equivalent in case of rotation with other water users, from well No. 8

The use to which this water is to be applied is municipal

If for irrigation, this appropriation shall be limited to - - of one cubic foot per second or its equivalent for each acre irrigated and shall be further limited to a diversion of not to exceed - - acre feet per acre for each acre irrigated during the irrigation season of each year;

and shall be subject to such reasonable rotation system as may be ordered by the proper state officer.

The well shall be cased as necessary in accordance with good practice and if the flow is artesian the works shall include proper capping and control valve to prevent the waste of ground water.

The works constructed shall include an air line and pressure gauge or an access port for measuring line, adequate to determine water level elevation in the well at all times.

The permittee shall install and maintain a weir, meter, or other suitable measuring device, and shall keep a complete record of the amount of ground water withdrawn.

The priority date of this permit is December 13, 1962

Actual construction work shall begin on or before March 15, 1964 and shall thereafter be prosecuted with reasonable diligence and be completed on or before October 1, 1964

Complete application of the water to the proposed use shall be made on or before October 1, 1965

WITNESS my hand this 15th day of March, 1963

Charles L. Wheeler
STATE ENGINEER

Application No. G. 2502
Permit No. G. 2312

PERMIT
TO APPROPRIATE THE GROUND
WATERS OF THE STATE
OF OREGON

This instrument was first received in the office of the State Engineer at Salem, Oregon, on the 13th day of December, 1962, at 1:00 o'clock P. M.

Returned to applicant:

Approved: March 15, 1963
Recorded in book No. 9 of 2312
Ground Water Permits on page 2312

CARL S. L. WHEELER
STATE ENGINEER
Drainage Basin No. 7 page 52
State Printing

Permit A-4M-770

SP-1965-119

STATE OF OREGON
COUNTY OF UMATILLA
CERTIFICATE OF WATER RIGHT

This Is to Certify, That CITY OF MILTON-FREEWATER

of Box 108, Milton-Freewater, State of Oregon, has made proof to the satisfaction of the STATE ENGINEER of Oregon, of a right to the use of the waters of Well No. 8

a tributary of Walla Walla River for the purpose of municipal

under Permit No. G-2312 of the State Engineer, and that said right to the use of said waters has been perfected in accordance with the laws of Oregon; that the priority of the right hereby confirmed dates from December 13, 1962

that the amount of water to which such right is entitled and hereby confirmed, for the purposes aforesaid, is limited to an amount actually beneficially used for said purposes, and shall not exceed 3.90 cubic feet per second

or its equivalent in case of rotation, measured at the point of diversion from the stream. The point of diversion is located in the NW 1/4 SW 1/4, Section 18, T. 5 N., R. 36 E., W. M., 1620 feet North and 1170 feet East from SW Corner, Section 18.

The amount of water used for irrigation, together with the amount secured under any other right existing for the same lands, shall be limited to ----- of one cubic foot per second per acre,

and shall conform to such reasonable rotation system as may be ordered by the proper state officer.

A description of the place of use under the right hereby confirmed, and to which such right is appurtenant, is as follows:

W 1/2
Section 1

N 1/2
NE 1/4 SW 1/4
SE 1/4
Section 2

NE 1/4 NE 1/4
Section 11

W 1/2 NE 1/4
NW 1/4
N 1/2 SW 1/4
SE 1/4 SW 1/4
SE 1/4

Section 12
T. 5 N., R. 35 E., W. M.

NE 1/4 NE 1/4
Section 13
T. 5 N., R. 35 E., W. M.

SW 1/4 NW 1/4
NW 1/4 SW 1/4
Section 18
T. 5 N., R. 36 E., W. M.

SE 1/4 SW 1/4
SE 1/4
Section 35

SW 1/4 SW 1/4
Section 36
T. 6 N., R. 35 E., W. M.

The right to the use of the water for the purposes aforesaid is restricted to the lands or place of use herein described.

WITNESS the signature of the State Engineer, affixed

this date. October 24, 1974

Chris L. Wheeler

State Engineer

APPENDIX F

Area Well Logs

STATE ENGINEER
Salem, Oregon

UMAT
3908

OBSERVATION WELL Well Record

STATE WELL NO. 5N/35-1E(1)
COUNTY UMATILLA
APPLICATION NO. U-165

OWNER: KEY EQUIPMENT Co. (UTAH CO.) MAILING ADDRESS: MILTON FREEWATER

LOCATION OF WELL: Owner's No. #1 CITY AND STATE: _____

SW 1/4 NW 1/4 Sec. 1 T. 5 N. S. R. 35 E. W.M.

Bearing and distance from section or subdivision corner _____


Altitude at well _____

TYPE OF WELL: DRILLED Date Constructed 2-16-45

Depth drilled 528' Depth cased 109'3"

CASING RECORD:

16 INCH



Section 1

FINISH: _____

AQUIFERS:

BASALT

WATER LEVEL:

49' (2-16-45)

PUMPING EQUIPMENT: Type _____ Capacity _____ G.P.M. H.P. _____

WELL TESTS: SEE PUMP TEST INFO
Drawdown _____ ft. after _____ hours _____ G.P.M.
Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER MUNICIPAL Temp. _____ °F. _____, 19____

SOURCE OF INFORMATION U-158

DRILLER or DIGGER A.A. DURAND & Son

ADDITIONAL DATA:

Log Water Level Measurements Chemical Analysis Aquifer Test _____

REMARKS: _____

STATE ENGINEER
Salem, Oregon

State Well No. 5N/35-1E(1)

County UMATILLA

Application No. U-165

Water Level Record

OWNER: KEY EQUIPMENT Co. (UTAH CANNING Co.) OWNER'S NO. _____

Description of measuring point: OWNER'S AIRLINE & GAGE (197' LINE)

| Date | Water Level Feet (above) (below) Land Surface | Remarks | Date | Water Level Feet (above) (below) Land Surface | Remarks |
|---------|--|---------|------|--|---------|
| 11-9-61 | 105' | ROFWSB. | | | |
| 11-4-63 | 121 | | | | |
| 11-18 | 120 | | | | |
| 12-2 | 120 | | | | |
| 12-21 | 112 | | | | |
| 1-6-64 | 112 | | | | |
| 1-20 | 114 | | | | |
| 2-3 | 113 | | | | |
| 2-17 | 112 | | | | |
| 3-3 | 107 | | | | |
| 3-17 | 107 | | | | |
| 4-7 | 105 | | | | |
| 4-27 | 105 | | | | |
| 5-4 | 103 | | | | |
| 6-1 | 103 | | | | |
| 9-29 | 132 | | | | |
| 10-12 | 132 | | | | |
| 11-16 | 130 | | | | |

REMARKS: _____

UMAT
6509

MAR 5 1945
STATE ENGINEER
SALEM, OREGON

21/3-1211

Application No. U-165
Permit No. U-158
Well No. 1

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Utah Canning Co.

Date of Report Feb. 28, 1945

1. Location of well: SW $\frac{1}{4}$ of NW $\frac{1}{4}$ of Section 1 Twp. 5N Rge. 35 E, W. M.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: 1800 feet.
4. If the well is less than 1800 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: ----- feet.
5. Date of beginning drilling or digging Nov. 21, 1944
6. Date well was completed Feb. 16, 1945

7. LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | Thickness of stratum |
|----------------------------------|----------------------------|----------------------|
| | At surface | ft. |
| | ft. | ft. |
| | ft. | ft. |
| See attached Chronology of Well. | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |

Remarks: _____

WELL INFORMATION

8. Diameter of well 16 inches. Depth of well 528 feet.
9. Depth at which water was first encountered 22 feet.
10. Water level when completed: 49 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: _____

Note: You will find attached Test Pumping Record of this well.

The Utah Canning Company

By Geo. M. Martin
Geo. M. Martin

Utah Canning Company, Brewster, Oregon,
 Drilled during period November 21, 1944 to
 February 16, 1945

Plant No. 1
 Located 1 1/2 mi. S.W. of NW 1/4
 of Sec. 1, T20N, R3E

Sketch No. 7070
 Scale 1/8" = 10'

WELL CHRONOLOGY

| G.S. | Depth | | Formation | S.W.L. | Comments |
|------|----------------|------|---|--------|-----------------------------------|
| | From | To | | | |
| | Ground Surface | 20' | Gravel & boulders | | |
| | 20' | 30' | Gravel | 22' | |
| | 30' | 55' | Clay & Gravel | | |
| | 55' | 64' | Pure Gravel | | |
| | 64' | 92' | Yellow Clay & Gravel | | |
| | 92' | 107' | Solid Black Basalt | | End of 20" drilling. |
| | 107' | 114' | Black Basalt & Blue shale | | 18" O.D. casing set at 109' 3" |
| | 114' | 118' | Black Basalt | | |
| | 118' | 125' | Gray & Brown Basalt and Blue Shale | | |
| | 125' | 145' | Gray Basalt & Blue Shale | | |
| | 145' | 158' | Gray, Red & Brown Basalt and Blue Shale | 22' | |
| | 158' | 159' | Gray & Brown Basalt with Blue Clay | 18' | |
| | 159' | 186' | Black Basalt | | |
| | 186' | 193' | Black & Red Basalt with little Yellow Clay | | |
| | 193' | 198' | Black Basalt | | |
| | 198' | 205' | Black Basalt & Blue Shale | | |
| | 205' | 213' | Black & Red Basalt with Yellow Clay | | |
| | 213' | 221' | Hard Black Basalt | | |
| | 221' | 228' | Black Basalt with little Yellow Clay | | |
| | 228' | 235' | Hard Black Basalt | 16' | |
| | 235' | 255' | Gray Basalt | 16' 6" | |
| | 255' | 282' | Hard Blue Basalt | | |
| | 282' | 401' | Hard Gray Basalt | | |
| | 401' | 437' | Hard Black Basalt | | |
| | 437' | 468' | Hard Gray Basalt | | |
| | 468' | 528' | Soft & Hard Black Basalt | | |

16" casing +
 cement seal
 @ 109' 3"

open hole
 from 109' 3" to 528' = 418' 9"

Well
 Bottom 528'

Pump Test #1 conducted Feb. 16 and 17,
 1945, 24 hours continuous. S.W.L. 49'

Mean Pumping Points as follows:

| Dynamic W.L. | G.P.M. |
|--------------|--------|
| 70' | 1029 |
| 75 1/2' | 1040 |
| 79 1/2' | 1265 |
| 81' | 1550 |

Cement seal (1504#)
 set at the bottom of
 18" by bridging below
 16" pipe, filling sar
 with cement and driv-
 ing wood plug down an
 forcing cement around
 behind 16" casing.
 Was done when well wa
 drilled to 496' level
 then cement & cement
 bridge drilled out at
 which time S.W.L.
 changed from 16' 6"
 to 41' 5"

STATE ENGINEER
Salem, Oregon

State Well No. 5/351E1

County Umatilla

Application No. _____

Chemical Analysis

OWNER Utah Canning Co. OWNER'S NO. _____

ANALYST Ore. State Board of Health Address _____

Date of Collection 1945

Point of Collection _____

| | P.P.M. | F.P.M. |
|--|--------|--------|
| Silica (SiO ₂) | | |
| Iron (Fe) Total | | |
| Manganese (Mn) | | |
| Calcium (Ca) | 16. | |
| Magnesium (Mg) | 8.5 | |
| Sodium (Na) | 14. | |
| Potassium (K) | | |
| Bicarbonate (HCO ₃) | 90. | |
| Carbonate (CO ₃) | | |
| Sulfate (SO ₄) | | |
| Chloride (Cl) | | |
| Fluoride (F) | | |
| Nitrate (NO ₃) | | |
| Boron (B) | | |
| Dissolved Solids | | |
| Hardness as CaCO ₃ | 74. | |
| Specific Conductance (Micromhos at 25°C) | | |
| pH | | |
| Percent Sodium | | |
| Sodium Absorption Ratio (S.A.R.) | | |
| CLASS | | |

The Utah Canning Company

GENERAL OFFICE
OGDEN, UTAH

PLANTS AT
OGDEN, UTAH
FREEWATER, OREGON

Freewater, Oregon

May 24, 1950

RECEIVED

MAY 26 1950

STATE ENGINEER
SALEM, OREGON

Mr. Chas. E. Stricklin, State Engineer
State of Oregon,
Salem, Oregon

Dear Sir:

Re: File No. 165

We are holder of Water Right Certificate No. 1551 under Permit No. U-158.

Due to the drop in water tables in this area last year we have been checking the water level in our well for depth below ground level weekly since Feb. 13, 1950 and find the following;

| | | | |
|--------------|--------------|--------------|------------|
| Feb. 13 -70' | Mar. 20 -65' | Apr. 17 -59' | May 15 -63 |
| Feb. 27 -70' | Mar. 27 -62 | Apr. 24 -59' | May 22 -65 |
| Mar. 6 -68 | Apr. 3 -62 | May 1 -57' | |
| Mar. 13 -65 | Apr. 10 -60 | May 8 -57' | |

You will note that we had a build up for awhile and now the table is lowering.


When we started using our well in the 1949 season about June 10th the level was 59' below ground level and after pumping for 8 hours we had dropped somewhere below 100', how far below that we do not know as our gauge is only set for 100'.

It is very evident that there are too many wells on the same basin that we are on.

What we would like to know is, does a well that was proven at a certain time have priority over wells that were proven at later dates.

Very truly yours,

Utah Canning Company


Geo. M. Martin
Manager

5N/35-1E1
UMATILLA

Water level from ground surface. Utah Canning Company, Freewater,
Oregon well - Permit No. U-165/58

| <u>Date</u> | <u>Feet</u> |
|----------------|----------------------|
| Feb. 13, 1950 | 70 - Not Pumping |
| Feb. 27, 1950 | 70 - Not Pumping |
| March 6, 1950 | 68 - Not Pumping |
| March 13, 1950 | 65 - Not Pumping |
| March 20, 1950 | 65 - Not Pumping |
| March 27, 1950 | 62 - Not Pumping |
| April 3, 1950 | 62 - Not Pumping |
| April 10, 1950 | 60 - Not Pumping |
| April 17, 1950 | 59 - Not Pumping |
| April 24, 1950 | 59 - Not Pumping |
| May 1, 1950 | 57 - Not Pumping |
| May 8, 1950 | 57 - Not Pumping |
| May 15, 1950 | 63 - Not Pumping |
| May 16, 1950 | 63 - Not Pumping |
| May 17, 1950 | 63 - Not Pumping |
| May 22, 1950 | 65 - Not Pumping |
| May 31, 1950 | 70 - Not Pumping |
| June 5, 1950 | 70 - Not Pumping |
| June 12, 1950 | 74 - Not Pumping |
| June 13, 1950 | 73 - Not Pumping |
| June 14, 1950 | 75 - Not Pumping |
| June 15, 1950 | 73 - Not Pumping |
| June 16, 1950 | 73 - Not Pumping |
| June 19, 1950 | 73 - Not Pumping |
| June 20, 1950 | 74 - Started Pumping |
| June 21, 1950 | 95 - Pumping |
| June 22, 1950 | 93 - Pumping |
| June 23, 1950 | 93 - Pumping |
| June 24, 1950 | 94 - Pumping |
| June 25, 1950 | 98 - Pumping |
| June 26, 1950 | 100 - Pumping |
| June 27, 1950 | 100 - Pumping |
| June 28, 1950 | 98 - Pumping |
| June 29, 1950 | 99 - Pumping |
| June 30, 1950 | 103 - Pumping |
| July 1, 1950 | 100 - Pumping |
| July 2, 1950 | 103 - Pumping |
| July 3, 1950 | 105 - Pumping |
| July 4, 1950 | 107 - Pumping |
| July 5, 1950 | 109 - Pumping |
| July 6, 1950 | 106 - Pumping |
| July 7, 1950 | 110 - Pumping |
| July 8, 1950 | 103 - Pumping |
| July 9, 1950 | 105 - Pumping |
| July 10, 1950 | 105 - Pumping |
| July 11, 1950 | 102 - Pumping |
| July 12, 1950 | 103 - Pumping |
| July 13, 1950 | 110 - Pumping |
| July 14, 1950 | 110 - Pumping |

RECEIVED
JAN 9 1951
STATE ENGINEER
SALEM, OREGON

5N/35-1E1
UMATILLA

Water level from ground surface. Utah Canning Company, Freewater,
Oregon well - Permit No. U-155158

| <u>Date</u> | <u>Feet</u> |
|----------------|-----------------------|
| July 15, 1950 | 105 - Pumping |
| July 16, 1950 | 103 - Pumping |
| July 17, 1950 | 103 - Pumping |
| July 18, 1950 | 100 - Stopped Pumping |
| July 19, 1950 | 105 - Not Pumping |
| July 20, 1950 | 100 - Not Pumping |
| July 21, 1950 | 98 - Not Pumping |
| July 24, 1950 | 95 - Not Pumping |
| July 25, 1950 | 88 - Not Pumping |
| July 26, 1950 | 88 - Not Pumping |
| July 27, 1950 | 87 - Not Pumping |
| Aug. 3, 1950 | 87 - Not Pumping |
| Aug. 9, 1950 | 85 - Not Pumping |
| Aug. 11, 1950 | 85 - Not Pumping |
| Aug. 14, 1950 | 84 - Not Pumping |
| Aug. 18, 1950 | 83 - Not Pumping |
| Aug. 22, 1950 | 82 - Not Pumping |
| Aug. 30, 1950 | 78 - Not Pumping |
| Sept. 7, 1950 | 78 - Not Pumping |
| Sept. 12, 1950 | 79 - Not Pumping |
| Sept. 20, 1950 | 80 - Not Pumping |
| Sept. 26, 1950 | 80 - Not Pumping |
| Oct. 2, 1950 | 76 - Not Pumping |
| Oct 12, 1950 | 73 - Not Pumping |
| Oct. 17, 1950 | 73 - Not Pumping |
| Oct. 24, 1950 | 72 - Not Pumping |
| Nov. 1, 1950 | 72 - Not Pumping |
| Nov. 8, 1950 | 72 - Not Pumping |
| Nov. 20, 1950 | 72 - Not Pumping |
| Nov. 27, 1950 | 71 - Not Pumping |
| Dec. 6, 1950 | 69 - Not Pumping |
| Dec. 11, 1950 | 68 - Not Pumping |
| Dec. 19, 1950 | 67 - Not Pumping |
| Dec. 26, 1950 | 66 - Not Pumping |

RECEIVED
JAN 9 1951
STATE ENGINEER
SALEM, OREGON

5N/35-1E(1)
UMATILLA CO.

Water level from ground surface. Utah Canning Company, Milton-Freewater, Oregon well - PERMIT No. U-158, for the year 1951

| Date | Feet | Date | Feet |
|------|----------------------|-------|--------------------|
| 1/2 | 66 - Not Pumping | 7/12 | 107 - Pumping |
| 1/8 | 66 - " " | 7/13 | 102 - " " |
| 1/16 | 66 - " " | 7/14 | 105 - " " |
| 1/22 | 65 - " " | 7/15 | 103 - " (Last Day) |
| 1/29 | 67 - " " | 7/18 | 92 - Not Pumping |
| 2/5 | 68 - " " | 7/25 | 89 - " " |
| 2/13 | 71 - " " | 7/31 | 87 - " " |
| 2/20 | 73 - " " | 8/8 | 85 - " " |
| 2/28 | 74 - " " | 8/15 | 83 - " " |
| 3/5 | 76 - " " | 8/23 | 83 - " " |
| 3/12 | 76 - " " | 8/31 | 82 - " " |
| 3/19 | 76 - " " | 9/7 | 80 - " " |
| 3/26 | 74 - " " | 9/14 | 78 - " " |
| 4/3 | 62 - " " | 9/21 | 78 - " " |
| 4/10 | 63 - " " | 9/28 | 77 - " " |
| 4/17 | 64 - " " | 10/5 | 75 - " " |
| 4/23 | 64 - " " | 10/11 | 77 - " " |
| 4/30 | 63 - " " | 10/18 | 75 - " " |
| 5/8 | 63 - " " | 10/22 | 75 - " " |
| 5/14 | 61 - " " | 10/30 | 75 - " " |
| 5/23 | 63 - " " | 11/9 | 74 - " " |
| 6/4/ | 64 - Started Pumping | 11/16 | 74 - " " |
| 6/5 | 85 - Pumping | 11/18 | 74 - " " |
| 6/9 | 85 Not Pumping | 11/29 | 75 - " " |
| 6/11 | 88 - " " | 12/3 | 75 - " " |
| 6/15 | 84 - " " | 12/10 | 75 - " " |
| 6/17 | 95 - Pumping | 12/17 | 74 - " " |
| 6/18 | 98 - " " | 12/27 | 73 - " " |
| 6/19 | 100 - " " | 12/31 | 73 - " " |
| 6/20 | 100 - " " | | |
| 6/21 | 100 - " " | | |
| 6/22 | 102 - " " | | |
| 6/23 | 100 - " " | | |
| 6/24 | 105 - " " | | |
| 6/25 | 102 - " " | | |
| 6/26 | 108 - " " | | |
| 6/27 | 105 - " " | | |
| 6/28 | 105 - " " | | |
| 6/29 | 105 - " " | | |
| 6/30 | 107 - " " | | |
| 7/1 | 107 - " " | | |
| 7/2 | 107 - " " | | |
| 7/3 | 105 - " " | | |
| 7/4 | 105 - " " | | |
| 7/5 | 107 - " " | | |
| 7/6 | 109 - " " | | |
| 7/7 | 101 - " " | | |
| 7/8 | 107 - " " | | |
| 7/9 | 107 - " " | | |
| 7/10 | 103 - " " | | |
| 7/31 | 109 - " " | | |

RECEIVED
JAN 14 1952
STATE ENGINEER
SALEM, OREGON

5N/35-1E(1)
RECEIVED
 FEB 6 1954
 STATE ENGINEER
 SALEM, OREGON
 UMATILLA CO

Water level from ground surface. Utah Canning Company, Milton-Freewater Oregon - Well #1 - Permit No. U-158, for the year 1953.

| <u>1953</u> | <u>Ft.</u> | | <u>1953</u> | <u>Ft.</u> | |
|-------------|------------|-------------|-------------|------------|-------------|
| 1/8 | 74 | Not Pumping | 7/11 | 119 | Pumping |
| 1/15 | 75 | " " | 7/12 | 117 | " " |
| 1/22 | 77 | " " | 7/13 | 116 | " " |
| 1/26 | 77 | " " | 7/14 | 117 | " " |
| 2/2 | 79 | " " | 7/15 | 117 | " " |
| 2/16 | 78 | " " | 7/16 | 115 | " " |
| 2/23 | 81 | " " | 7/17 | 118 | " " |
| 3/2 | 83 | " " | 7/18 | 110 | " " |
| 3/9 | 79 | " " | 7/20 | 111 | " " |
| 3/16 | 79 | " " | 7/27 | 93 | Not Pumping |
| 3/23 | 78 | " " | 8/5 | 91 | " " |
| 3/30 | 78 | " " | 8/10 | 89 | " " |
| 4/6 | 78 | " " | 8/17 | 86 | " " |
| 4/27 | 73 | " " | 8/24 | 84 | " " |
| 5/4 | 73 | " " | 8/31 | 82 | " " |
| 5/11 | 77 | " " | 9/8 | 80 | " " |
| 5/18 | 81 | " " | 9/15 | 83 | " " |
| 5/25 | 83 | " " | 9/22 | 84 | " " |
| 6/2 | 76 | " " | 9/28 | 76 | " " |
| 6/8 | 74 | " " | 10/5 | 74 | " " |
| 6/15 | 78 | " " | 10/12 | 72 | " " |
| 6/22 | 83 | " " | 10/19 | 73 | " " |
| 6/30 | 110 | Pumping | 10/26 | 70 | " " |
| 7/1 | 115 | " " | 11/2 | 69 | " " |
| 7/2 | 112 | " " | 11/9 | 67 | " " |
| 7/3 | 115 | " " | 11/16 | 71 | " " |
| 7/4 | 113 | " " | 11/23 | 73 | " " |
| 7/5 | 114 | " " | 11/30 | 78 | " " |
| 7/6 | 112 | " " | 12/7 | 78 | " " |
| 7/7 | 114 | " " | 12/14 | 80 | " " |
| 7/8 | 114 | " " | 12/21 | 80 | " " |
| 7/9 | 114 | " " | 12/28 | 81 | " " |
| 7/10 | 115 | " " | | | |

RECEIVED

5N/35 -12 G(1)
UMATILLA

AUG 17 1944

Rogers Canning Co

STATE ENGINEER
SALEM, OREGON

Application No. U-157
Permit No. U-151
Well No. Milton #1

UMAT
3963

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report August 10, 1944

1. Location of well: SW¹ of the NW¹ of Section 12 Twp. 5 Rge. 35, W. M.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: ✓ 703 feet.
4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: same elevation feet.
5. Date of beginning drilling or digging February 5, 1944
6. Date well was completed April 20, 1944

LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | Thickness of stratum |
|-----------------------|----------------------------|----------------------|
| | At surface | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |
| | ft. | ft. |

Remarks: (See attached list)

WELL INFORMATION

8. Diameter of well 16 inches. Depth of well 702' 6" feet.
9. Depth at which water was first encountered 16 feet.
10. Water level when completed: 117 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: Caving at 48' and 182'

RESERVE

JUN 8 1951

STATE ENGINEER
SALEM, OREGON

Rogers Conning, Co

SN/35-12614

UMATILLA

Application No. U 380

Permit No. U 355

Well No. Milton #2

REPORT ON COMPLETION OF WELL

UMAT
3964

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report 18 June, 1951

1. Location of well: SW 1/4 NE 1/4 of Section 12 Twp. 5 Rge. 35 E, W. M.
2. Name of nearest natural surface stream Walla Walla River
3. Distance from well to that stream: 50 feet.
4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: 10 feet.
5. Date of beginning drilling or digging. 8 January 1951
6. Date well was completed 14 June 1951

LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | Thickness of stratum |
|-------------------------------|----------------------------|----------------------|
| Gravel | At surface | 84 ft. |
| Gravel and boulders | 34 ft. | 18, 10" ft. |
| Black basalt | 42, 10" ft. | 31, 9" ft. |
| Black basalt, gravel and clay | 74 ft. | 6 ft. |
| Black basalt | 80 ft. | 87 ft. |
| Red and brown basalt | 167 ft. | 15 ft. |
| Black basalt | 182 ft. | 216 ft. |
| Gray basalt | 398 ft. | 32 ft. |
| Black basalt | 430 ft. | 130 ft. |
| Remnants: Black basalt-broken | 560 | |

Remarks: First water crystals in rock 394' to 396'. Traveling stream of water at 484'. Washed outtings away. Traveling stream of water 524' to 528'. Traveling stream 552' to 560'. Cuttings washed away wherever traveling stream encountered.

- WELL INFORMATION
8. Diameter of well 16" inches. Depth of well 560 feet.
 9. Depth at which water was first encountered 283 feet.
 10. Water level when completed: 125 feet below ground surface.
 11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.: Water level at in well stood at 34' when drilling had reached 270'. Water level in well dropped to 120' below the surface of ground when well had been drilled to 283'. Water level in well dropped to 125' when drilling reached a depth of 297' and remained at that level until completion of drilling at a depth of 560'.

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filled with the

STATE ENGINEER, SALEM, OREGON, within 30 days from the of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print) Do not write above this line

RECEIVED
SEP 18 1968

UMAT
3899

State Well No. 5N/35-1AB
State Permit No. _____

STATE ENGINEER

(1) OWNER:

Name J. Frank Schmidt & Son Co.
Address 23000 S. E. Stark St.; Troutdale, Oregon 97060

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 13.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 356 ft. Gage 375
10" Diam. from 333 ft. to 562 ft. Gage 250

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used cutting torch
Size of perforations 3/8 in. by 4 in.
4 per ft. perforations from 442 ft. to 542 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 302' 2" ft. below land surface Date 6/27/68
Atmospheric pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 925 gal./min. with 25 ft. drawdown after 72 hrs.
805 " " 22 " " 48 "
708 " " 16 " " 24 "
Ballot test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water 66 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 0 to 60 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth 440
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County Umatilla Driller's well number _____
NW 1/4 NE 1/4 Section 1 T. 5N R. 35 E. W.M.
Bearing and distance from section or subdivision corner
2' W. of E. line and 20' N. of S. line of NW 1/4 of NE 1/4

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 660 ft. Depth of completed well 660 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

| MATERIAL | From | To | SWL |
|---------------------------------|------|-----|-----|
| Soil | 0 | 12 | |
| Small Gravel | 12 | 28 | |
| Cement Gravel | 28 | 60 | |
| Sand and Gravel | 60 | 82 | |
| Brown Clay and small Gravel | 82 | 127 | |
| Brown Clay, Gravel and Boulder | 127 | 203 | |
| Blue Clay | 203 | 288 | |
| Brown Clay and Boulders | 288 | 326 | |
| Light Green and Brown Clay | 326 | 347 | |
| Blue Basalt Rock | 347 | 435 | |
| Broken Blue Basalt Rock | 435 | 440 | |
| Hard Gray Basalt | 440 | 449 | |
| Honeycomb Blue Basalt (1st Wtr) | 449 | 455 | 280 |
| Broken Black Basalt | 455 | 550 | |
| Blue Basalt | 550 | 624 | |
| Honeycomb Black Basalt (Water) | 624 | 653 | 300 |
| Black Basalt | 653 | 660 | |

Work started 12 Feb 1968 Completed June 1968

Date well drilling machine moved off of well 2 July 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Thomas R. Ruther Date 17 Sept 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 138

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Thomas R. Ruther
(Person, firm or corporation) (Type or print)

Address 1421 Circle Drive; Walla Walla, Wash.

[Signed] Thomas R. Ruther
(Water Well Contractor)

Contractor's License No. 374 Date 17 Sept. 1968

5/35-1
Umatilla

UNITED STATES
DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY

GROUND WATER BRANCH
Box 3418 - 623 Post Office Building
Portland 8, Oregon

March 30, 1951

Mr. Robert L. Brunton, City Manager
City Hall
Milton-Freswater, Oregon

RECEIVED
APR 2 1951
STATE ENGINEER
SALEM, OREGON

Dear Mr. Brunton:

In regard to your March 23 inquiry for records bearing on your plan to secure more water from the wells of the former city of Freewater by increasing the pump capacity:

Of the two city wells, excluding the recent nonproductive "fault-zone" well, this office has some records on the younger "Main Street" well, but little data on the older "City Hall" well. Of the older well I could not even learn the depth, casing, diameter, or driller, though I have it on my list for additional canvassing. I believe Durand drilled it years ago and I have meant to ask him about it. It was equipped with a pump of 250-gallons-per-minute capacity when I saw it, but I could not determine its pumping water level and static water level from the pumpman or by entry into the well myself.

On the newer well we have a log taken from the driller's record. A copy is enclosed in case you do not have one. I did not get the static water level but from known static water levels of wells in that vicinity, I assumed it was somewhere near 40 feet during the winter months. A pumping test run at the time the well was finished in 1936 showed 750 gallon per minute with water level drawn down to 47 feet below the surface and 1,025 gallons per minute with water level drawn down to 68 feet below the surface. A pump of 850-gallons-per-minute capacity was on the well when I visited it 2 years ago. Though that observation may partially answer your question, it would probably be necessary to run pump tests to obtain the correctly designed pump for the greater yield you contemplate.

There is some interference, I understand, between your Main Street "younger" well and the Utah Canning Co. well 500± feet to the northeast. The logs of the wells are similar. The Utah Canning Co. well shows that the basalt contained water whose static level was only 15 feet below the surface until the zone at 468-528 feet depth was penetrated; at that time the static water level dropped to 41 feet from the surface. If such is the case in your well, some water may run from the higher strata down the well and out the lower zone. It is suggested that the amount of such change, if any in your well, should be determined as a

matter of planning for a new pump. This office has a well-current meter with which we can measure interchange; if you will notify us when the well is to be clear of pumping equipment. Such an interchange measurement is of value as data applying to well construction over the entire Columbia River basalt area of Oregon and Washington.

I hope this information will answer some of your questions.

Sincerely yours,

R. C. Newcomb
District Geologist

RCN:rls
Enclosure - 1 log

CC: Mr. Chas. E. Stricklin ✓

RECEIVED

UMAT 5128

len/35E-366

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.785)

JUL 8 1985

WATER RESOURCES DEPT SALEM, OREGON RELEASE TYPE OR PRINT IN INK

(for official use only)

(1) OWNER:

Name Fred K. v. P. Address P.O. Box 1540 City Milwau Freewater, OR State 97862

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(3) TYPE OF WELL:

Rotary Air [X] Driven [] Rotary Mud [] Dug [] Cable [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal [] Irrigation [] Thermal: Withdrawal [] ReInjection [] Other: Piezometric [] Grounding [] Test []

(5) CASING INSTALLED:

Steel Threaded [] Plastic Welded [X] 8" Diam. from 7 1/4" ft. to 58 1/4" ft. Gauge 0.250

LINER INSTALLED:

Steel Threaded [] Plastic Welded []

(6) PERFORATIONS:

Size of perforations in. by in. Perforated? [] Yes [X] No

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom?

(9) CONSTRUCTION:

Well seal—Material used Cement Well sealed from land surface to 3.0 ft. Diameter of well bore to bottom of seal 17 in. Diameter of well bore below seal 8 in. Amount of sealing material 15 sacks pounds

(10) LOCATION OF WELL by legal description:

County Umatilla NW 1/4 of Section 36 Township 6N Range 35 12 WM. Tax Lot Lot Block Subdivision MAILING ADDRESS OF WELL (or nearest address) SALEM

(11) WATER LEVEL of COMPLETED WELL:

Depth at which water was first found 78 ft. Static level 36 ft. below land surface. Date 5-30-85 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8" Depth drilled 102 ft. Depth of completed well 100 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Soil Gravel & Boulders (0-8), Gravel & Boulders (8-22), Clay Gravel & Boulders (22-55), Cement Gravel (55-102) with SWL 36.

Date work started 5-21-85 / completed 5-30-85 Date well drilling machine moved off of well 5-30 19 85

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19 _____

(bonded) Water Well Constructor Certification:

Bond _____ Issued by: _____ (Surety Company Name) On behalf of _____ (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:

(Signed) Clarence W. Sisson (Water Well Constructor) (Dated) 6-6-85

NOTICE TO WATER WELL CONSTRUCTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*4896-690

The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

(Do not write above this line)

RECEIVED

APR 20 1981

State Well No. 6N 35E-3660

State Permit No.

SALEM, OREGON

UMAT 6475

(1) OWNER:

Name Sam LeFore Address Rt.1 Box 174 East side Rd. Milton Freewater Oregon.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) CASING INSTALLED:

10" Diam. from 0 ft. to 40 ft. Gage 0250 8" Diam. from 20 ft. to 240 ft. Gage SCH 160

(6) PERFORATIONS:

Perforated? [X] Yes [] No. Type of perforator used Whole Saw Size of perforations 1 in. by 1 in. 500 perforations from 100 ft. to 240 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No Yield: 450 gal./min. with 26 ft. drawdown after 4 hrs. Baller test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Temperature of water 54.8 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Well sealed from land surface to 28 ft. Diameter of well bore to bottom of seal 12 in. Diameter of well bore below seal 10 in. Number of sacks of cement used in well seal 23 sacks How was cement grout placed? pumped

Was a drive shoe used? [X] Yes [] No Plugs Size: location ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off. Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Umitilla Driller's well number SW 1/4 NW 1/4 Section 36 T. 6 R. 35E W.M. Tax Lot 1400 RT 1B 154 East side Rd.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 80 ft. Static level 100 ft. below land surface. Date Jan 29-81 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10 Depth drilled 243 ft. Depth of completed well 240 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Brown loam top soil, Tan clay and bolders, loose and cavy, Brown hard pan with 2" to 4" rocks hard., Boulders 1 ft and larger in hard pan tan and brown in color., Yellow clay small gravel simi soft with a trace of sand in the clay., Blue clay muck, Yellow sandy hard pan porous and waterbearing., Dark brown clay and gravel, 1"-3" Soft., Grey clay Soft, Black basalt, Blue clay.

Work started 1-26-81 Completed 1-29-81 Date well drilling machine moved off of well 1-29-81

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date 1-29-81 (Drilling Machine Operator)

Drilling Machine Operator's License No. 1298

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Goral LaPorte Well Drilling (Person, firm or corporation) (Type or print) Address Rt 1 Box 191 M.F. Oregon

[Signed] (Water Well Contractor)

Contractor's License No. 736 Date 1-29-81

STATE ENGINEER
Salem, Oregon

UMAT
5157

Well Record

STATE WELL NO. 6N/35-36B
COUNTY Umatilla
APPLICATION NO. GR-3844

OWNER: Oland F. Hubbs
Ebev. L. Hurst

MAILING ADDRESS: Route 1, Box 39

LOCATION OF WELL: Owner's No. _____

CITY AND STATE: Milton-Freewater, Oregon

NW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 36 T. 6 N. ~~E.~~ R. 35 W. W.M.

Bearing and distance from section or subdivision

corner 660' E. & 1300' S. from N $\frac{1}{4}$ Cor. Sec. 36

| | | | |
|--|--|---|--|
| | | X | |
| | | | |
| | | | |
| | | | |

Section 36

Altitude at well _____

TYPE OF WELL: Dug 30' Date Constructed 1914

Depth drilled 258 ft. ^{Drilled 228'} Depth cased _____

CASING RECORD:

8 inch casing set from 30' to

FINISH:

Perforated

AQUIFERS:

WATER LEVEL:

12 feet below surface

PUMPING EQUIPMENT: Type Johnston turbine 5" H.P. 5
Capacity 450 G.P.M.

WELL TESTS:

Drawdown about 60 ft. after _____ hours 450 G.P.M.

Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Irrigation Temp. _____ °F. _____, 19____

SOURCE OF INFORMATION Wall Registration Statement Cert. #GR-3501

DRILLER or DIGGER _____

ADDITIONAL DATA:

Log _____ Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS:

STATE ENGINEER
Salem, Oregon



Well Record

GR- 1630

STATE WELL NO. 6N/35-36K
COUNTY Umatilla
APPLICATION NO. GR- 1596

OWNER: Willie M. Arnoldt


MAILING ADDRESS: Rt. 1, Box 167

LOCATION OF WELL: Owner's No. _____

CITY AND STATE: Milton-Freewater, Oregon

NW 1/4 SE 1/4 Sec. 36 T. 6 N. 35 E. R. 35 W. W.M.

Bearing and distance from section or subdivision corner 60' N. & 705' W. from SE cor. of NW 1/4 SE 1/4 of Section 36.



Section 36

Altitude at well 950'

TYPE OF WELL: Dug & Drilled Date Constructed 1920 - Prior to

Depth drilled 90' Depth cased 51'

CASING RECORD:

72" x 84" concrete curbing from 0 to 20 ft.
8" steel from 36 to 51 ft.

FINISH:

AQUIFERS:

WATER LEVEL:

15'

PUMPING EQUIPMENT: Type 4" turbine H.P. 5
Capacity 400 G.P.M.

WELL TESTS:

Drawdown 15 ft. after _____ hours 400 G.P.M.
Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Irrigation Temp. _____ °F. _____, 19____

SOURCE OF INFORMATION GR Record

DRILLER or DIGGER

ADDITIONAL DATA:

Log _____ Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS:

Log: Top soil 0 to 2 ft.
Cement gravel 2 to 90 ft.

Irrigation of 10 acres.

STATE ENGINEER
Salem, Oregon

UMAT
3915

Well Record

GR- 1451

STATE WELL NO. 5N/35-1F
COUNTY Umatilla
APPLICATION NO. GR- 1411

OWNER: Milton Nursery Company


MAILING ADDRESS: P. O. Box 1305

LOCATION OF WELL: Owner's No. _____

CITY AND STATE: Milton-Freewater, Oregon

SE 1/4 NW 1/4 Sec. 1 T. 5 N. 35 E. XX, R. 35 XX, W.M.

Bearing and distance from section or subdivision corner 620' E. & 496' N. from SW cor. of SE 1/4 NW 1/4 of Section 1.



Section 1

Altitude at well 1000'

TYPE OF WELL: Dug Date Constructed 1925

Depth drilled 30' Depth cased 10'

CASING RECORD:

6' x 6' cement curb

FINISH:

AQUIFERS:

Gravel

WATER LEVEL:

10'

PUMPING EQUIPMENT: Type Byron-Jackson 8" x 8" Cent.

H.P. 20

Capacity 400 G.P.M.

WELL TESTS:

Drawdown 20 ft. after _____ hours 400 G.P.M.

Drawdown _____ ft. after _____ hours _____ G.P.M.

USE OF WATER Irrigation Temp. _____ °F., 19.

SOURCE OF INFORMATION GR. Record

DRILLER or DIGGER _____

ADDITIONAL DATA:

Log _____ Water Level Measurements _____ Chemical Analysis _____ Aquifer Test _____

REMARKS:

Log: Gravel formation 0 to 30 ft.

Irrigation of 121.6 acres.

| DATE | FROM | TO | FORMATION | COMMENTS | SWL | GPM |
|--------------|--|-----|---------------------------------|--------------------------------------|--------------|-----|
| Jul 13, 1995 | 0 | 11 | SOIL | | | |
| | 11 | 21 | 1' GRAVEL | | | |
| | 21 | 46 | BROWN CLAY | | | |
| | 46 | 56 | 2" ROCK & BROWN CLAY | | | |
| | 56 | 61 | RED & BROWN CLAY | | | |
| Jul 20, 1995 | 61 | 116 | BROWN CLAY & GRAVEL | CAVED IN TO 110 83' OF 12" CASING | | |
| Jul 24, 1995 | 116 | 120 | GRAY CLAY & GRAVEL | STANDING OPEN TO 122' | | |
| Jul 25, 1995 | 120 | 126 | BROWN CLAY & GRAVEL | | | |
| Jul 25, 1995 | 126 | 130 | BLACK BASALT | | | |
| Jul 31, 1995 | 130 | 145 | BLACK BASALT | | | |
| | 145 | 152 | BROWN BASALT | SOFT | | |
| | 152 | 187 | BROKEN BROWN BASALT | | | |
| | 187 | 197 | BLACK BASALT | SCORIA | | |
| | 197 | 222 | BLACK BASALT | | | |
| | 222 | 240 | BROWN BASALT | | | |
| | 240 | 250 | BLACK BASALT | | | |
| 8/1-8/3 | | | | REPAIR RIG | | |
| Aug 4, 1995 | 250 | 280 | BLACK BASALT | SOFT | | |
| Aug 7, 1995 | 280 | 315 | BLACK BASALT | SOFT | | |
| | POSSIBLE PROBLEM @ 207 | | | | | |
| | 315 | 349 | GRAY BASALT | | | |
| Aug 8, 1995 | 349 | 355 | BROWN BASALT | SOFT | | 346 |
| Aug 14, 1995 | 355 | 368 | BLACK BASALT | CEMENT IN 8' FROM 282 TO 368 | | |
| | READY MIX M 22074 | | | | | |
| | 368 | 372 | BLACK BASALT | | | |
| | 372 | 376 | BLACK BASALT | SCORIA | | |
| Aug 16, 1995 | 376 | 385 | BLACK BASALT | | | |
| | 385 | 389 | BLACK BASALT | BROKEN | | |
| | 389 | 404 | BLACK BASALT | | | 18 |
| | 404 | 408 | RED BASALT | SOFT | | |
| | 408 | 413 | BLACK SCORIA & GREEN CLAY STONE | | | |
| | 413 | 424 | BLACK BASALT | | | 35 |
| | 424 | 438 | BLACK BASALT | CAVING | 68 F. | 75 |
| | 438 | 441 | BLACK BASALT | | | |
| | 441 | 479 | BLACK BASALT | BROKEN, CAVING | | H2O |
| | 479 | 523 | BLACK BASALT | | | H2O |
| Aug 17, 1995 | BRIDGE 381' TO 390', OPEN BELOW CEMENT FROM 390' TO VARIOUS LEVELS, 8 TIMES | | | | | |
| Jan 21, 1996 | 523 | 594 | BLACK BASALT | | | |
| | 594 | 598 | BLACK BASALT | | | |
| | 598 | 612 | BLACK | HARD | | |
| | 612 | 616 | BLACK | SOFT | POSSIBLE H2O | |
| | 616 | 630 | BLACK | HARD | | |
| | 630 | 690 | BLACK | BROKEN | POSSIBLE H2O | |
| | 690 | 706 | BLACK | | | |

RECEIVED

MAR 7 1996

WATER RESOURCES DEP
SALEM, OREGON

9-149
(Oct. 1938)

DEC 19 1963 NOTEBOOK SHEET 5N/36-18M(1)

Name Newcom, Seis, & Turner Date Dec 17, 1963

Current-metering deep wells near
Milton - Freewater

Milton-Freewater No. 7 (5/36-18N/or M1)

| | Depth (ft below land surface) | clicks/min | Vel (ft/sec) | Flow (gpm) (downward) |
|--------------------|-------------------------------|------------|--------------|-----------------------|
| Transverse down | 242 (turbulent) | 20(?) | .35(?) | |
| | 400 | 6 1/2 | .07 | 24.5 |
| | 500 | 5 | .05 | 17.5 |
| | 600 | 0 | | |
| | 700 | 0 | | |
| | 800 | 7 | .07 | 26.3 |
| Transverse up | 850 | 0 | | |
| | 700 | 0 | | |
| | 600 | 0 | | |
| | 500 | 0 | | |
| | 400 | 6 1/2 | .07 | 24.5 |
| | 300 | 0 | | |

Hole dia. is 12" ID. casing 0-190 ft., 12" per rock hole 190-882 ft.

Static water level 241 ft below top of 12" casing which is 2 ft above land surface, Dec. 17, 1963. Estimated 25 gpm cascading into well around bottom of 12" casing at 190 ft.

Conclusion: No movement of water in well except 25 gpm descending from 190 to 852+ ft. At most points velocity insufficient to turn meter.

5M/25-1260

LOG OF MATERIALS ENCOUNTERED

| Character of Material | Depth at which encountered | | Thickness of stratum |
|----------------------------------|----------------------------|--|----------------------|
| | At surface | | |
| Gravel | 21 ft. | | 21 ft. |
| Cement Gravel | 47 ft. | | to 47 ft. |
| Rock | 50 ft. | | to 50 ft. |
| Black Basalt | 57 ft. | | to 57 ft. |
| Gray Basalt | 65 ft. | | to 65 ft. |
| Black Basalt | 132 ft. | | to 132 ft. |
| Brown Basalt | 167 ft. | | to 167 ft. |
| Black Basalt | 182 ft. | | to 182 ft. |
| Brown & Black Basalt Honeycombed | 185 ft. | | to 185 ft. |
| Black Basalt | 203 ft. | | to 203 ft. |
| Brown & Black Basalt | 255 ft. | | to 255 ft. |
| Black Basalt | 395 ft. | | to 395 ft. |
| Gray Basalt | 401 ft. | | to 401 ft. |
| Black Basalt | 508 ft. | | to 508 ft. |
| Gray Basalt | 521 ft. | | to 521 ft. |
| Black Basalt | 536 ft. | | to 536 ft. |
| Gray Basalt | 569 ft. | | to 569 ft. |
| Black Basalt Honeycombed | 584 ft. | | to 584 ft. |
| Black Basalt | 622 ft. | | to 622 ft. |
| Gray Basalt | 639 ft. | | to 639 ft. |
| Black Basalt | | | to 702 ft 6" |

APPENDIX G

Walla Walla River Water Quality Data

| 1999 | Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) |
|------|------|-----------------|------------|--------------------------|---------------|-----------------------|-----|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|
| | 1125 | 4.3 | | 118 | 12.3 | 95.4 | 7.3 | 37 | 0.723 | 0.041 | 0.134 | 0.078 | 14 | 130 | 0.6 |
| | 0920 | 7.3 | | 235 | 10.5 | 88.8 | 7.3 | 7 | 0.496 | 0.010u | 0.098 | 0.055 | 4.6 | 25 | 0.4 |
| | 1005 | 10.8 | | 264 | 10.2 | 92.7 | 8.0 | 19 | 0.587 | 0.010u | 0.130 | 0.060 | 7.3 | 28 | 0.3 |
| | 1745 | 18.0 | 25 | 309 | 12.6 | 134.1 | 8.6 | 18 | 0.732 | 0.047 | 0.142 | 0.072 | 8.7 | 27 | 0.5 |
| | 1700 | 25.2 | 11 | 407 | 14.3 | 175.5 | 9.0 | 33 | 0.885 | 0.043 | 0.121 | 0.022 | 15 | 64 | 0.1 |
| | 1600 | 24.0 | 65 | 230 | 12.6 | 152.3 | 9.0 | 18 | 0.572 | 0.039 | 0.117 | 0.040 | 7.4 | 77 | 0.2 |
| | 1730 | 25.3 | 227 | 176 | 9.1 | 113.0 | 8.2 | 17 | 0.770 | 0.057 | 0.149 | 0.065 | 8.1 | 380 | 0.5 |
| | 0805 | 9.7 | 623 | 120 | 10.0 | 88.7 | 8.3 | 29 | 0.604 | 0.031 | 0.091 | 0.028 | 8.2 | 80 | 0.3 |
| | 1045 | 8.9 | 762 | 402 | 11.3 | 96.4 | 8.1 | 25 | 0.733 | 0.023 | 0.119 | 0.059 | 10 | 28 | 0.5 |
| | 0945 | 5.6 | 1100 | 103 | 11.9 | 95.9 | 7.4 | 134 | 0.906 | 0.027 | 0.164 | 0.087 | 34 | 80 | 0.8 |
| | 1730 | 3.4 | 688 | 117 | 12.3 | 94.2 | 8.0 | 95 | 1.340 | 0.023 | 0.217 | 0.092 | 28 | 150 | 1.2 |
| | 1005 | 4.0 | 704 | 138 | 11.8 | 90.5 | 7.4 | 46 | 1.040 | 0.038 | 0.129 | 0.086 | 16 | 39 | 0.9 |

result fails water quality criteria Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count

| 1998 | Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) |
|------|------|-----------------|------------|--------------------------|---------------|-----------------------|-----|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|
| | 0820 | 3.4 | 1060 | 103 | 12.2 | 90.9 | 7.2 | 69 | 1.040 | 0.033 | 0.139 | 0.067 | 32 | 77 | 0.7 |
| | 1750 | 7.6 | 58 | 237 | 12.9 | 108.1 | 8.6 | 16 | 0.584 | 0.010u | 0.056 | 0.027 | 14 | 28 | 0.3 |
| | 0940 | 10.8 | 35 | 268 | 10.8 | 98.7 | 7.8 | 15 | 0.574 | 0.190 | 0.028 | 0.033 | 9.6 | 40 | 0.4 |
| | 1745 | 22.9 | 37 | 376 | 12.0 | 142.4 | 8.5 | 36 | 0.858 | 0.010u | 0.115 | 0.061 | 24 | 140 | 0.3 |
| | 1715 | 26.2 | 32 | 348 | 11.5 | 144.1 | 8.8 | 27 | 0.921 | 0.010u | 0.130 | 0.083 | 15 | 250 | 0.5 |
| | 1535 | 23.8 | 48 | 373 | 12.6 | 150.3 | 8.8 | 28 | 0.865 | 0.010u | 0.110 | 0.035 | 14 | 1500 | 0.4 |
| | 1805 | 18.9 | 373 | 180 | 9.0 | 98.3 | 8.4 | 35 | 0.767 | 0.010u | 0.116 | 0.050 | 15 | 140 | 0.6 |
| | 1640 | 16.9 | 669 | 109 | 9.7 | 102.2 | 7.9 | 68j | 0.831 | 0.024 | 0.114 | 0.050 | 23 | 88 | 0.5 |

| Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) |
|----------|-----------------|------------|--------------------------|---------------|-----------------------|-----|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|
| 04/13/98 | 1530 | 448 | 170 | 11.4 | 100.8 | 8.2 | 19 | 0.879 | 0.010u | 0.094 | 0.053 | 11 | 49 | 0.8 |
| 03/01/98 | 1825 | 793 | 141 | 11.9 | 95.4 | 8.1 | 26 | 1.190 | 0.010u | 0.087 | 0.052 | 12 | 42 | 1.2 |
| 02/01/98 | 1650 | 1150 | 113 | 12.1 | 94.5 | 7.9 | 60 | 1.060 | 0.010 | 0.105 | 0.054 | 22 | 25 | 0.9 |
| 01/04/98 | 1500 | 655 | 143 | 12.6 | 93.0 | 7.7 | 34 | 1.100 | 0.010u | 0.169 | 0.060 | 16 | 27 | 0.9 |

Result fails water quality criteria Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count

| Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) |
|---------------|-----------------|------------|--------------------------|---------------|-----------------------|-----|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|
| 1997 (32A070) | | | | | | | | | | | | | | |
| 12/07/97 | 1810 | 371 | 196 | 12.2 | 91.4 | 8.0 | 10 | 1.510 | 0.025 | 0.110 | 0.078 | 5 | 28 | 1.5 |
| 11/02/97 | 1930 | 280 | 182 | 11.2 | 94.9 | 7.9 | 26 | 1.310 | 0.048 | 0.164 | 0.073 | 23 | 160 | 1.1 |
| 10/05/97 | 1540 | 112 | 331 | 12.4 | 121.3 | 8.5 | 16 | 0.967 | 0.010u | 0.146 | 0.063 | 7.1 | 31 | 0.7 |
| 09/08/97 | 0745 | 74 | 354 | 7.8 | 80.0 | 7.9 | 32 | 0.966 | 0.019 | 0.144 | 0.063 | 15 | 43 | 0.8 |
| 08/04/97 | 0705 | 55 | 370 | 6.5 | 76.5 | 8.0 | 17 | 0.924 | 0.010u | 0.107 | 0.049 | 8.8 | 210 | 0.7 |
| 07/07/97 | 0730 | 155 | 309 | 7.7 | 85.2 | 7.9 | 39 | 1.330 | 0.036 | 0.115 | 0.041 | 15 | 92 | 1.0 |
| 06/02/97 | 0750 | 890 | 96 | 8.9 | 88.1 | 7.4 | 1720 | 1.850 | 0.090 | 0.178j | 0.070 | 2700j | 2900 | 1.0 |
| 05/05/97 | 0705 | 1650 | 119 | 9.9 | 94.0 | 7.6 | 206 | 1.200 | 0.025 | 0.273 | 0.050 | 50 | 120 | 1.0 |
| 04/07/97 | 0710 | 950 | 176 | 11.2 | 96.9 | 7.4 | 101 | 2.370 | 0.010u | 0.440 | 0.059 | 20 | 14 | 2.1 |
| 03/03/97 | 0745 | 1610 | 127 | 12.0 | 94.3 | 7.6 | 626 | 2.440 | 0.027 | 0.433 | 0.073 | 400 | 240 | 1.8 |
| 02/03/97 | 0715 | 4050 | 80 | 12.2 | 94.0 | 7.6 | 2990 | 1.600 | 0.060 | 0.579j | 0.060 | 800 | 69 | 1.3 |
| 01/13/97 | 0705 | 1290 | 176j | 13.5 | 91.4 | 6.9 | 163 | 2.110 | 0.038 | 0.218 | 0.063 | 40 | 45 | 1.9 |

Result fails water quality criteria Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count

| Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) |
|---------------|-----------------|------------|--------------------------|---------------|-----------------------|-----|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|
| 1996 (32A070) | | | | | | | | | | | | | | |
| 12/02/96 | 0730 | 1210 | 118j | 12.3 | 95.4 | 7.7 | 113 | 1.160j | 0.034 | 0.164j | 0.060 | 50 | 630j | 0.7 |
| 11/04/96 | 0720 | 191 | 245 | 11.5 | 93.9 | 8.0 | 18 | 1.180 | 0.010u | 0.097 | 0.051 | 11 | 37 | 1.1 |
| 10/07/96 | 0740 | 36 | 354 | 9.3 | 91.3 | 8.5 | 20 | 1.060 | 0.010u | 0.119 | 0.050 | 14 | 110 | 0.6 |

| Time | 1950 | 20.5 | 30 | 449 | 11.9 | 133.1 | 9.0 | 58 | 0.867 | 0.010u | 0.124 | 0.016 | 27 | 280 | 0.4 |
|----------|------|------|------|-----|------|-------|-----|-------|-------|--------|--------|-------|-------|-----|-----|
| 09/08/96 | | | | | | | | | | | | | | | |
| 08/11/96 | 1905 | 24.0 | 22 | 485 | 15.4 | 183.7 | 9.2 | 47 | 0.704 | 0.012 | 0.106 | 0.012 | 15 | 80 | |
| 07/16/96 | 1320 | 22.3 | 56 | 504 | 10.0 | 116.6 | 8.4 | 29 | 1.210 | 0.013 | 0.092 | 0.024 | 14 | 89s | 0.5 |
| 06/09/96 | 2140 | 21.0 | 256 | 263 | 9.7 | 109.0 | 9.2 | 35 | 0.959 | 0.012 | 0.069 | 0.018 | 11 | 33 | 0.7 |
| 05/12/96 | 2040 | 15.3 | 591 | 211 | 9.6 | 96.3 | 8.0 | 46 | 1.980 | 0.010u | 0.104 | 0.053 | 18 | 84s | 1.9 |
| 04/16/96 | 1630 | 13.8 | 875 | 173 | 10.1 | 100.2 | 8.2 | 51 | 1.680 | 0.010u | 0.068 | 0.043 | 15 | 110 | 1.5 |
| 03/12/96 | 1730 | 9.9 | 2690 | 103 | 14.1 | 126.0 | 7.6 | 9200j | 3.480 | 0.268 | 0.223j | 0.086 | 9500j | | 1.3 |
| 01/15/96 | 1820 | 8.1 | 1150 | 113 | 11.2 | 96.2 | 8.0 | 131 | 0.962 | 0.033 | 0.176 | 0.060 | 35 | 100 | 0.7 |

result fails water quality criteria Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count

| Time | 1995 (32A070) | Temp-erature (C) | Flow (CFS) | Conduc-tivity (umhos/ 25c) | Oxygen (mg/L) | Oxygen Satura-tion (%) | pH | Sus-pended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbi-dity (NTU) | Fecal Coliforms (colonies/ 100ml) | Nitrate- Nitrite (mg/L) |
|----------|---------------|------------------|------------|----------------------------|---------------|------------------------|-----|--------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|------------------|-----------------------------------|-------------------------|
| 11/14/95 | 1335 | 12.0 | 302 | 101 | 10.9 | 100.2 | 7.9 | 122 | 0.865 | 0.020 | 0.207 | 0.062 | 60 | 150s | 0.5 |
| 10/10/95 | 1455 | 12.8 | 58 | 267 | 9.7 | 92.7 | 7.9 | 105 | 1.210 | 0.053 | 0.048 | 0.106 | 120 | | 0.8 |
| 09/11/95 | 1150 | 21.1 | 11 | 353 | 8.3 | 92.0 | 8.1 | 32 | 0.733 | 0.018 | 0.210 | 0.069 | 11 | 51 | 0.3 |
| 08/14/95 | 1245 | 20.4 | 29 | 500 | 9.4 | 103.8 | 8.3 | 14 | 0.889 | 0.026 | 0.190 | 0.088 | 4.5 | 23 | 0.6 |
| 07/10/95 | 1550 | 24.7 | 90 | 273 | 8.9 | 107.5 | 8.1 | 35 | 1.020 | 0.025 | 0.165 | 0.076 | 27 | 210 | 0.5 |
| 06/12/95 | 1400 | 22.1 | 158 | 210 | 11.2 | 128.1 | 8.9 | 14 | 0.645 | 0.022 | 0.080 | 0.033 | 5.5 | 96 | 0.2 |
| 05/08/95 | 1440 | 11.6 | 1700 | 104 | 10.3 | 96.0 | 7.9 | 211 | 0.676 | 0.010u | 0.176 | 0.044 | 65 | 250 | 0.5 |
| 04/10/95 | 1335 | 9.3 | 989 | 112 | 11.1 | 97.2 | 8.0 | 125 | 1.070 | 0.026 | 0.145 | 0.054 | 35 | 220 | 0.8 |
| 03/12/95 | 1650 | 9.2 | 1820 | 91 | 11.1 | 97.6 | 7.6 | 409 | 0.964 | 0.010u | 0.414 | 0.054 | 150 | 140 | 0.8 |
| 02/13/95 | 1540 | 3.2 | 989 | 167 | 13.5 | 102.2 | 7.6 | 77 | 1.260 | 0.036 | 0.142 | 0.059 | 23 | 53 | 1.2 |
| 01/02/95 | 1535 | 0.6 | 732 | 112 | 13.9 | 95.9 | 7.6 | 34 | 0.990 | 0.031 | 0.098 | 0.066 | 12 | 63 | 0.9 |

result fails water quality criteria Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count

| Time | 1994 (32A070) | Temp-erature (C) | Flow (CFS) | Conduc-tivity (umhos/ 25c) | Oxygen (mg/L) | Oxygen Satura-tion (%) | pH | Sus-pended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbi-dity (NTU) | Fecal Coliforms (colonies/ 100ml) | Nitrate- Nitrite (mg/L) |
|----------|---------------|------------------|------------|----------------------------|---------------|------------------------|----|--------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|------------------|-----------------------------------|-------------------------|
| 09/08/96 | | | | | | | | | | | | | | | |
| 08/11/96 | | | | | | | | | | | | | | | |
| 07/16/96 | | | | | | | | | | | | | | | |
| 06/09/96 | | | | | | | | | | | | | | | |
| 05/12/96 | | | | | | | | | | | | | | | |
| 04/16/96 | | | | | | | | | | | | | | | |
| 03/12/96 | | | | | | | | | | | | | | | |
| 01/15/96 | | | | | | | | | | | | | | | |

| | | | | | | | | | | | | | | | |
|----------|------|------|-----|-----|------|-------|-----|-----|-------|--------|-------|--------|-----|-----|-----|
| 12/12/94 | 1440 | 2.0 | 460 | 138 | 12.7 | 92.8 | 7.6 | 22 | 1.184 | 0.049 | 0.113 | 0.091 | 12 | 36 | 0.9 |
| 11/20/94 | 1500 | 3.7 | 293 | 160 | 12.4 | 94.1 | 8.0 | 17 | 1.234 | 0.015 | 0.100 | 0.074 | 11 | 34 | 0.9 |
| 10/03/94 | 1620 | 15.1 | 7.7 | 747 | 11.5 | 115.1 | 8.5 | 10 | 1.340 | 0.018 | 0.055 | 0.010k | 6 | 66 | 1.0 |
| 09/12/94 | 1330 | 17.4 | 2.1 | 757 | 11.5 | 120.7 | 8.7 | 6 | 0.668 | 0.036 | 0.038 | 0.018 | 4.7 | 32 | 0.3 |
| 08/08/94 | 1810 | 23.9 | 3.5 | 726 | 10.9 | 131.2 | 8.9 | 15 | 0.914 | 0.021 | 0.088 | 0.034 | 8.9 | 24 | 0.6 |
| 07/11/94 | 1545 | 26.9 | 12 | 456 | 9.9 | 124.8 | 8.2 | 24 | 1.100 | 0.045 | 0.159 | 0.072 | 17 | 89 | 0.7 |
| 06/13/94 | 1320 | 19.9 | 46 | 285 | 10.4 | 116.1 | 8.4 | 24 | 0.569 | 0.010k | 0.079 | 0.052 | 10 | 200 | 0.4 |
| 05/09/94 | 1420 | 21.4 | 228 | 159 | 8.8 | 100.3 | 8.2 | 31 | 0.637 | 0.040 | 0.119 | 0.087 | 11 | 120 | 0.4 |
| 04/11/94 | 1640 | 11.5 | 566 | 118 | 11.1 | 102.1 | 8.1 | 34 | 0.633 | 0.010k | 0.117 | 0.060 | 11 | 120 | 0.4 |
| 03/14/94 | 1420 | 8.1 | 566 | 135 | 11.2 | 95.6 | 7.9 | 88 | 1.040 | 0.024 | 0.155 | 0.078 | 22 | 48 | 0.8 |
| 02/14/94 | 1615 | 5.0 | 288 | 185 | 12.6 | 99.3 | 7.9 | 19 | 1.370 | 0.016 | 0.121 | 0.093 | 7.6 | 8 | 1.1 |
| 01/09/94 | 1555 | 5.8 | 835 | 122 | 11.6 | 93.4 | 7.8 | 112 | 1.140 | 0.067 | 0.158 | 0.076 | 46 | 71 | 0.8 |

Result fails water quality criteria Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count:

| Year | Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) |
|----------|----------|-----------------|------------|--------------------------|---------------|-----------------------|-----|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|
| 1993 | (32A070) | | | | | | | | | | | | | | |
| 12/13/93 | 1640 | 4.4 | 268 | 171 | 11.9 | 93.3 | 8.1 | 26 | 1.230 | 0.035 | 0.139 | 0.110j | 12 | | 1.0 |
| 11/07/93 | 1555 | 4.9 | 61 | 254 | 14.1 | 110.8 | 8.4 | 8 | 0.686 | 0.011 | 0.062 | 0.041 | 5.4 | 8 | 0.5 |
| 10/11/93 | 1430 | 13.9 | 24 | 346 | 11.5 | 112.0 | 8.4 | 48 | 1.050 | 0.030 | 0.096 | 0.065 | 15 | 72 | 0.8 |
| 09/06/93 | 1320 | 22.4 | 21 | 425 | 9.6 | 111.2 | 8.6 | 33 | | 0.018 | 0.120 | 0.072 | 21 | 68 | 0.5 |
| 08/02/93 | 1315 | 23.6 | 39 | 340 | 9.8 | 115.5 | 8.5 | 24 | | 0.010k | 0.101 | 0.072 | 4.7 | 54 | 0.3 |
| 07/05/93 | 1330 | 20.8 | 57 | 286 | 10.4 | 116.7 | 8.4 | 26 | | 0.021 | 0.077 | 0.048 | 7 | 140 | 0.4 |
| 06/07/93 | 1340 | 18.1 | 398 | 178 | 10.1 | 107.2 | 8.0 | 94 | | 0.057 | 0.127 | 0.081 | 21 | 270 | 0.7 |
| 05/03/93 | 1405 | 9.8 | 1950 | 85 | 10.7 | 95.7 | 7.7 | 356 | | 0.068 | 0.232 | 0.051 | 40 | 230x | 0.4 |
| 04/05/93 | 1255 | 6.8 | 1950 | 80 | 11.4 | 94.2 | 8.1 | 480 | | 0.017 | 0.184 | 0.056 | 50 | 200 | 0.5 |
| 03/01/93 | 1310 | 1.2 | 382 | 161 | 14.0 | 98.6 | 8.2 | 16 | | 0.021 | 0.099 | 0.081 | 5.7 | 1 | 1.2 |

| 02/01/93 | | 1315 | 4.5 | 755 | 133 | 12.4 | 95.0 | 8.2 | 129 | 0.063 | 0.174 | 0.085 | 30 | 96 | 1.2 |
|---|-----------------|------------|--------------------------|---------------|-----------------------|------|-------------------------|----------------------------------|-------------------------|-------------------------|-------------------------------------|-----------------|----------------------------------|------------------------|-----|
| Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count result fails water quality criteria | | | | | | | | | | | | | | | |
| Time | Temperature (C) | Flow (CFS) | Conductivity (umhos/25c) | Oxygen (mg/L) | Oxygen Saturation (%) | pH | Suspended Solids (mg/L) | Total Persulfate Nitrogen (mg/L) | Ammonia Nitrogen (mg/L) | Total Phosphorus (mg/L) | Dissolved Soluble Phosphorus (mg/L) | Turbidity (NTU) | Fecal Coliforms (colonies/100ml) | Nitrate-Nitrite (mg/L) | |
| 1992 (52A070) | | | | | | | | | | | | | | | |
| 12/01/92 | 1300 | 3.6 | 403 | 155 | 12.6 | 94.8 | 7.8 | 43 | 0.043 | 0.152 | 0.105 | 16 | 38 | 0.8 | |
| 11/02/92 | 1315 | 10.3 | 78 | 214 | 10.5 | 93.1 | 7.9 | 72 | 0.024 | 0.016 | 0.056 | 29 | 150 | 0.2 | |
| 10/05/92 | 1300 | 14.1 | 11 | 287 | 8.9 | 86.2 | 8.0 | 80 | 0.063 | 0.188 | 0.126 | 50 | 480 | 0.9 | |
| Data qualifiers: u, j - estimated value k - actual value known to be less s - spreader x - high background count result fails water quality criteria | | | | | | | | | | | | | | | |

Washington State Department of Ecology
 Please send comments to siba461@ecy.wa.gov



WASHINGTON STATE
DEPT. OF ECOLOGY

Conditions & Trends / River and Stream WQ Monitoring

: Station 32A070

AMBIENT MONITORING DATA

Station 32A070

Water Quality Data Summary - Metals

Last updated 28-May-1998

| 1997 (32A070) | Mercury (micrograms/ Liter) | Cadmium (micrograms/ Liter) | Zinc (micrograms/ Liter) | Lead (micrograms/ Liter) | Chromium (micrograms/ Liter) | Copper (micrograms/ Liter) | Nickel (micrograms/ Liter) | Hardness** (milligrams/ Liter) |
|--|-----------------------------------|-----------------------------------|--------------------------------|--------------------------------|------------------------------------|----------------------------------|----------------------------------|--------------------------------------|
| 08/04/1997 | | 0.020u | 0.580 | 0.060 | | 1.570 | 1.250 | 150 |
| 06/02/1997 | | 0.020u | 0.660 | 0.150 | | 1.140 | 0.824 | 95 |
| 04/07/1997 | | 0.020u | 0.950 | 1.380 | | 1.120 | 0.650 | 68 |
| 02/03/1997 | | 0.030u | 1.000 | 0.200 | | 0.795 | 0.390 | 100 |
| *Data qualifiers: u, j - estimated value k - actual value known to be less p - too numerous to count v - contamination in the blank x - high background count | | | | | | | | |
| 1996 (32A070) | Mercury (micrograms/ Liter) | Cadmium (micrograms/ Liter) | Zinc (micrograms/ Liter) | Lead (micrograms/ Liter) | Chromium (micrograms/ Liter) | Copper (micrograms/ Liter) | Nickel (micrograms/ Liter) | Hardness** (milligrams/ Liter) |
| 12/02/1996 | | 0.014 | 1.000 | 0.030u | | 0.560 | 0.340 | 49 |
| 10/07/1996 | | 0.027 | 1.400j | 0.101 | | 1.270 | 1.040 | 138 |
| *Data qualifiers: u, j - estimated value k - actual value known to be less p - too numerous to count v - contamination in the blank x - high background count | | | | | | | | |

** Hardness (salt concentration) is factored into the water quality criteria for all of the metals except mercury.

Washington State Department of Ecology

Please send comments to stba461@ecy.wa.gov

(3) Class B (good).

(a) General characteristic. Water quality of this class shall meet or exceed the requirements for most uses.

(b) Characteristic uses. Characteristic uses shall include, but not be limited to, the following:

(i) Water supply (industrial and agricultural).

(ii) Stock watering.

(iii) Fish and shellfish:

Salmonid migration, rearing, and harvesting.

Other fish migration, rearing, spawning, and harvesting.

Clam, oyster, and mussel rearing and spawning.

Crustaceans and other shellfish (crabs, shrimp, crayfish, scallops, etc.) rearing, spawning, and harvesting.

(iv) Wildlife habitat.

(v) Recreation (secondary contact recreation, sport fishing, boating, and aesthetic enjoyment).

(vi) Commerce and navigation.

(c) Water quality criteria:

(i) Fecal coliform organisms:

(A) Freshwater - fecal coliform organism levels shall both not exceed a geometric mean value of 200 colonies/100 mL, and not have more than 10 percent of all samples obtained for calculating the geometric mean value exceeding 400 colonies/100 mL.

(B) Marine water - fecal coliform organism levels shall both not exceed a geometric mean value of 100 colonies/100 mL, and not have more than 10 percent of all samples obtained for calculating the geometric mean value exceeding 200 colonies/100 mL.

(ii) Dissolved oxygen:

(A) Freshwater - dissolved oxygen shall exceed 6.5 mg/L.

(B) Marine water - dissolved oxygen shall exceed 5.0 mg/L. When natural conditions, such as upwelling, occur, causing the dissolved oxygen to be depressed near or below 5.0 mg/L, natural dissolved oxygen levels may be degraded by up to 0.2 mg/L by human-caused activities.

(iii) Total dissolved gas shall not exceed 110 percent of saturation at any point of sample collection.

(iv) Temperature shall not exceed 21.0° C (freshwater) or 19.0° C (marine water) due to human activities. When natural conditions exceed 21.0° C (freshwater) and 19.0° C (marine water), no temperature increases will be allowed which will raise the receiving water temperature by greater than 0.3° C.

Incremental temperature increases resulting from point source activities shall not, at any time, exceed $t=34/(T+9)$ (freshwater) or $t=16/(T)$ (marine water). Incremental temperature increases resulting from nonpoint source activities shall not exceed 2.8° C.

For purposes hereof, "t" represents the maximum permissible temperature increase measured at a mixing zone boundary; and "T" represents the background temperature as measured at a point or points unaffected by the discharge and representative of the highest ambient water temperature in the vicinity of the discharge.

(v) pH shall be within the range of 6.5 to 8.5 (freshwater) and 7.0 to 8.5 (marine water) with a human-caused variation within the above range of less than 0.5 units.


(vi) Turbidity shall not exceed 10 NTU over background turbidity when the background turbidity is 50 NTU or less, or have more than a 20 percent increase in turbidity when the background turbidity is more than 50 NTU.

(vii) Toxic, radioactive, or deleterious material concentrations shall be below those which have the potential either singularly or cumulatively to adversely affect characteristic water uses, cause acute or chronic conditions to the most sensitive biota dependent upon those waters, or adversely affect public health, as determined by the department (see WAC 173-201A-040 and 173-201A-050).


(viii) Aesthetic values shall not be reduced by dissolved, suspended, floating, or submerged matter not attributed to natural causes, so as to affect water use or taint the flesh of edible species.

APPENDIX H

Reservoir Inspection Information




Remarks Not to Scale Res. Has Cathodic Protection Coal tar coating in good condition
Ladder in good condition Picked up Broken anode By Ladder
Will arra above water line, coating in "Bad" shape peeling & separation.



LIQUIL ENGINEERING CORPORATION WATER RESERVOIR WORKSHEET



Job Number 970R0101A Water District City of Milton Freewater Date 1-6-97
 Manager Howard Mess Tank North Res Maintenance Team Jeff Trevor & Bill
 Tank: Diameter/Height 90' x 40' Sq. Ft. 6359 Gallons 2 Millions
 Construction Steel Bottom Contour Flat Walls Straight Water Depth 38'
 Sediment: Type Light silt / small rocks Avg. Depth 1/8" Calculated Cu. Yds. N/A
 Built in 1960



TO : Howard Moss
FROM : Steve Bidwell



FILE
1996 RESERVOIR
CLEANING

Monday 1-6-97

Started cleaning north Reservoir a 2 million gallon storage tank, the city hired a underwater diving crew, Omega Vision Inc. I feel this was a very effective operation from a water supervisor's stand point - the crew was able to completely clean (2) Reservoir north 2 mi. & south 1 mi. in (2) days while the complete water system was on line - no well pumps to shut down no draining of storage tanks, no valving to shut off & turn on, the tanks, I feel - very professionally cleaned as the video shows the north tank had approx 1/8" of sediment on the floor of the tank, the Vacuum system the crew had worked extremely well it was 36" wide with a water turbine power nylon brush, it seemed to do an excellent job, the tank overall looked to be in very good shape, there were a few little rust spots, as the video shows, but nothing of real concern, the tank had (9) support columns all in good shape there was (1) one welded seam that had approx 12-13" of rust, but was superficial no real pitting of any depth, there will be a final inspection after cleaning is done

Tuesday 1-7-97


Aqua Vision Inc. started cleaning the South Reservoir, the bottom of this storage tank had also about $1/8$ " of sediment but was different in texture than the north tank, seemed to be more sandy especially around fill pipe, where debris was about 1" thick, very dark in color -

I also noticed (1) one of the anodes used for corrosion protection had fallen from the ceiling to the bottom of the tank, which knocked off some of the coating & is starting to rust, a spot approx 2" around there where some pin holes also in this tank, but again nothing of real significance this tank had (6) six support columns they also were in good shape, I have some sketches of the tank coatings, problem areas, supports, entry's so forth, also (2) valves

Steve Birkwell
water/shed supervisor

APPENDIX I

Umatilla Basin Program - OAR 690-507



The Oregon Administrative Rules contain OARs filed through November 14, 2008

WATER RESOURCES DEPARTMENT

DIVISION 507

UMATILLA BASIN PROGRAM

690-507-0010

Definitions

The following meanings apply to the terms as used in these rules for the Umatilla Basin Program. Other rules of the Department may define these words differently:

- (1) "Classification" or "Classified" means the allowed and preferred beneficial use(s) of a given surface or ground water source for which future appropriations of water shall be permitted.
- (2) "Commission" means the Water Resources Commission.
- (3) "Department" means the Oregon Water Resources Department.
- (4) "Director" means the Water Resources Director.
- (5) "Minimum Perennial Streamflow" or "Minimum Streamflow" means an administrative rule that establishes a flow necessary to support aquatic life, or recreation or minimize pollution. The rule includes a priority date and specifies streamflow levels for all or any period of the year. It establishes priority for instream use over future appropriations and identifies flow objectives for future management in streams where shortages occur.
- (6) "Statutorily Exempt Ground Water Uses" means those uses for which no ground water application, permit, or certificate is required under ORS 537.545. These uses are for:
 - (a) Stockwatering purposes;
 - (b) Watering any lawn or noncommercial garden not exceeding one-half acre in area;
 - (c) Watering the grounds, three acres in size or less, or schools that have less than 100 students and that are located in cities with a population of less than 10,000;
 - (d) Single or group domestic purpose in an amount not exceeding 15,000 gallons a day;
 - (e) Down-hole heat exchange purposes; or

- (f) Any single industrial or commercial purpose in an amount not exceeding 5,000 gallons a day.
- (7) "Subbasin" means any subarea of a basin defined by surface drainage patterns such as the drainage basin of any tributary, or the area draining to any point on a river or draining between two points on a river.
- (8) "Umatilla Basin" means the area comprised by the Walla Walla River, Wildhorse Creek, Upper Umatilla River, Birch and McKay Creeks, Columbia-Umatilla Plateau, Butter Creek, and Willow Creek subbasins as shown on Water Resources Department map number 7.6.
- (9) "Withdrawal" or "Withdrawn" means an order of the Commission, or State Engineer or a Legislative act prohibiting all new appropriations for particular uses from a source for part or all of the year. A withdrawal can be set for a prescribed length of time or indefinitely until modified by the Commission.

Stat. Auth.: ORS 536 & ORS 537

Stats. Implemented:

Hist.: WRB 26, f. 3-2-64; WRD 1-1981, f. & cert. ef. 4-20-81; WRD 10-1985, f. & cert. ef. 9-3-85; WRD 13, f. & cert. ef. 12-18-85; WRD 14-1985, f. & cert. ef. 12-20-85; WRD 1-1986, RF. & cert. ef. 2-20-86; WRD 1-1987, f. & cert. ef. 2-27-87; WRD 8-1988, f. & cert. ef. 7-5-88; WRD 9-1990, f. & cert. ef. 6-25-90; Administrative Renumbering 1-1993, Renumbered from 690-080-0070

690-507-0020

Policies

- (1) All rights to the surface waters of the Umatilla River and its tributaries initiated after September 28, 1987, shall be subordinate to permitted appropriations for the purpose of artificial ground water recharge established before that date.
- (2) To support present and proposed basin resource developments, no out-of-basin or out-of-state appropriations of water shall be made or granted by any state agency or public corporation of the state for the waters of the Umatilla River Basin.
- (3) Rights to use water for industrial or mining purposes granted by any state agency shall be issued only on condition that any effluent or return flows from such uses shall not interfere with other beneficial uses of water.
- (4) Future permits for consumptive water use shall be issued only on condition that efficient water use techniques or water conservation measures are proposed in the application. Failure to implement the proposed measures shall be a violation of the terms of the permit.
- (5) Municipal water supplies, interstate cooperation in water management, instream needs, out-of-stream needs, water quality and watershed management are issues of concern in the Umatilla River Basin. The Commission's policies on these issues are as follows:
- (a) Municipal water supply: In addressing the issue of municipal water supply in the Umatilla River Basin, it shall be the Commission's policy to:
- (A) Assist cities with limited financial resources secure needed capital to develop, expand and improve municipal water supplies;
- (B) Promote and aid municipal water conservation and encourage cities to plan for water service emergencies;
- (C) Encourage the use of artificial ground water recharge to supplement city ground water supplies and help reduce water level declines in the basalt ground water reservoir;
- (D) Encourage and promote the concept of regional municipal water supply systems and preserve the options for proposed systems;
- (E) Promote and support the purchase and transfer of water rights to municipal use;

(F) Promote the continued viability of municipal water systems reliant on the basalt ground water reservoir.

(b) Interstate cooperation on water management: In addressing the issue of interstate cooperation on water management, it shall be the Commission's policy to:

(A) Coordinate and cooperate with the state of Washington in managing the water resources of the Walla Walla subbasin to the extent judicial decisions, stipulations and statutory authority allow;

(B) Open negotiations with the Washington Department of Ecology by 1990.

(c) Instream needs: In addressing the issue of instream needs, it shall be the Commission's policy to:

(A) Support the anadromous fish production goals of the Northwest Power Planning Council, Oregon Department of Fish and wildlife and Confederated Tribes of the Umatilla Indian Reservation for the Umatilla River Basin;

(B) Protect and enhance instream values by limiting new uses of water from heavily appropriated streams and managing interconnected surface and ground water conjunctively;

(C) Support and encourage watershed and riparian zone projects which improve instream habitat and water quantity and quality, and which provide multiple water resources benefits.

(d) Out-of-stream use: In addressing the issue of out-of-stream use, it shall be the Commission's policy to:

(A) Require conservation and efficient water use;

(B) Control growth of water demand by limiting new irrigation appropriations on selected streams to stored or conserved water;

(C) Support the efficient use of surplus surface and ground water to supplement declining ground water levels through artificial ground water recharge;

(D) Support development of multipurpose surface storage consistent with policies in paragraphs (A), (B), and (C) of this subsection.

(e) Water quality: In addressing the issue of water quality, it shall be the Commission's policy to:

(A) Encourage and promote a formal ground water quality monitoring program to ensure safe municipal and domestic ground water supplies;

(B) Encourage development of management plans for ground water aquifers susceptible to contamination;

(C) Support surface water quality standards to satisfy selected subbasin beneficial water uses identified in this basin program;

(D) Encourage and promote control of nonpoint and point sources of water pollution.

(f) Watershed management: In addressing the issue of watershed management, it shall be the Commission's policy to:

(A) Encourage and promote improvements in water quality, quantity and related resources through agency-public cooperation and education about the benefits of watershed management;

(B) Encourage public and private landowners and managers to employ best management practices to benefit water quality and quantity;

(C) Encourage and support the retirement of highly erodible cropland as a means to enhance water quality and improve runoff patterns;

(D) Encourage and support riparian and stream channel enhancement as a means of improving flow distribution, water quality and related resource values.

Stat. Auth.: ORS 536 & ORS 537

Stats. Implemented:

Hist.: WRB 26, f. 3-2-64; WRD 1-1981, f. & cert. ef. 4-20-81; WRD 10-1985, f. & cert. ef. 9-3-85; WRD 13, f. & cert. ef. 12-18-85; WRD 14-1985, f. & cert. ef. 12-20-85; WRD 1-1986, RF. & cert. ef. 2-20-86; WRD 1-1987, f. & cert. ef. 2-27-87; WRD 8-1988, f. & cert. ef. 7-5-88; WRD 9-1990, f. & cert. ef. 6-25-90; Administrative Renumbering 1-1993, Renumbered from 690-080-0070

690-507-0030

Walla Walla River Subbasin

(1) Objectives: In developing a program for the management, use and control of the surface and ground water resources of the Walla Walla subbasin, the Commission has the following objectives:

- (a) Develop interstate cooperation with Washington in the management of surface and ground water and related resources;
- (b) Protect instream values in selected streams by closing them to future appropriations or limiting new appropriations to selected nonirrigation uses;
- (c) Preserve the opportunity for future upstream storage for all beneficial uses;
- (d) Permit artificial ground water recharge to offset declining ground water levels and supplement existing ground water uses;
- (e) Protect municipal ground water supplies;
- (f) Prevent new appropriations from causing ground water/ surface water interference.

(2) Surface Water: Appropriation and use of surface water in the Walla Walla River subbasin shall comply with the following provisions:

(a) The unappropriated waters of the Walla Walla River and tributaries from and including the Little Walla Walla Diversion to the state border are withdrawn from further appropriation. This withdrawal does not apply to domestic, livestock, fish and wildlife uses or water released from storage. Frost protection between March 1 and May 15, up to a cumulative total of 35 cfs of permits and rights with priority dates after December 2, 1985, is also exempt from this withdrawal. This withdrawal was established by the Commission on January 17, 1986;

(b) The waters of Dugger Creek and tributaries, being entirely appropriated, are withdrawn from further appropriation. The purpose of the withdrawal is to avoid conflict between new uses and existing rights and administrative problems in the distribution of water resulting from new appropriations. The withdrawal was ordered by the State Engineer on August 12, 1933;

(c) Classification: Permits to use surface water may be issued only for the following classified uses:

(A) The surface waters of the Walla Walla River subbasin generally, are classified for domestic, livestock, irrigation, municipal, industrial, power development (subject to limitations of OAR Chapter 690, Division 51), mining, fish life, wildlife, recreation, pollution abatement, artificial ground water recharge, and public instream uses only;

(B) The surface waters of the Walla Walla River and tributaries upstream from the Little Walla Walla diversion are classified for domestic, livestock, irrigation of noncommercial lawn and garden not to exceed 1/2 acre, municipal, mining, fish life, wildlife, recreation, pollution abatement, artificial ground water recharge and public instream uses only;

(C) Subject to the rights and priorities existing on June 24, 1988, and established minimum perennial streamflows, 40,000

acre-feet of the annual yield of the Walla Walla River upstream from the Little Walla Walla diversion is further classified for all beneficial uses in conjunction with storage. All natural flow rights issued on the Walla Walla River and its tributaries upstream from the Little Walla Walla diversion after June 24, 1988, shall be subordinate to this classification. Any storage project built under this classification shall include provisions for municipal, fish and wildlife, and recreation uses acceptable to the Commission;

(D) The surface waters of Mill Creek and tributaries are classified for domestic, livestock, irrigation of noncommercial lawn and garden not to exceed 1/2 acre, fish life, wildlife, pollution abatement, artificial ground water recharge and public instream uses only.

(E) The surface waters of Couse and Pine Creeks and tributaries are classified for domestic, livestock, irrigation or noncommercial lawn and garden not to exceed 1/2 acre, fish life, wildlife, pollution abatement, artificial ground water recharge and public instream uses only.

(d) Storage: Surface waters legally stored and legally released may be used for any beneficial purpose;

(e) Artificial ground water recharge: Use of surface water for ground water recharge shall be subject to the following conditions:

(A) Recharged water used under a secondary permit for irrigation may only provide supplemental water to lands with existing irrigation rights or permits on June 24, 1988;

(B) Diversion of surface water for recharge for irrigation under a secondary permit shall not exceed 3.375 acre feet per acre to be irrigated;

(C) If the recharged water is to be used for municipal or industrial purposes under a secondary permit, the applicant shall demonstrate to the satisfaction of the Commission that it has an active water conservation program; and

(D) Water shall be recharged only between December 1 and May 15.

(f) Minimum perennial streamflows: Minimum streamflows may be established to support aquatic life, minimize pollution or maintain recreation values:

(A) To support aquatic life in accordance with Section 3, Chapter 796, Oregon Laws 1983, no appropriation of water shall be made or granted by any state agency or public corporation of the state for waters of the Walla Walla River and tributaries when flows are below the levels specified in **Table 1**. This limitation shall not apply to domestic and livestock use or to waters legally stored or released from storage; and

(B) To support aquatic life, no appropriations of water except for domestic and livestock uses or waters legally stored or released from storage shall be made or granted by any state agency or public corporation of the state when flows are below the specified levels for the streams listed in **Table 1** with priority dates of 3-31-88.

(3) Ground Water: Appropriation and use of ground water in the Walla Walla River subbasin shall comply with the following provisions:

(a) Classification: Permits to use ground water may be issued only for the following classified uses:

(A) The ground water resources of the Walla Walla River subbasin are classified for statutorily exempt ground water uses (see definition), irrigation, municipal, industrial, power development, low temperature geothermal, mining, fish life, wildlife, recreation, pollution abatement, and artificial ground water recharge; and

(B) Ground water from the basalt reservoir in a five-mile radius around any municipal well of the cities of Athena, Helix, Milton-Freewater, and Weston is classified for municipal, group domestic and statutorily exempt ground water uses (see definition) only. Other uses may be permitted if it is documented that a barrier to ground water movement separates a proposed well from municipal wells and there will be no interference with municipal wells. Applications for other uses of ground water within a five-mile radius of a municipal well shall automatically be referred to the Commission for review and consideration of public interest unless the affected city affirms that is in favor of the proposed appropriation. This

classification applies only when the affected city(ies) have a full-time conservation program in effect.

(b) Permits issued to appropriate ground waters that may be hydraulically connected with surface water shall be specially conditioned. The condition shall specify that when exercise of the permit unduly interferes with surface water, the permit will be regulated in favor of the surface water source.

Stat. Auth.: ORS 536 & ORS 537

Stats. Implemented:

Hist.: WRB 26, f. 3-2-64; WRD 1-1981, f. & cert. ef. 4-20-81; WRD 10-1985, f. & cert. ef. 9-3-85; WRD 13, f. & cert. ef. 12-18-85; WRD 14-1985, f. & cert. ef. 12-20-85; WRD 1-1986, RF. & cert. ef. 2-20-86; WRD 1-1987, f. & cert. ef. 2-27-87; WRD 8-1988, f. & cert. ef. 7-5-88; WRD 9-1990, f. & cert. ef. 6-25-90; Administrative Renumbering 1-1993, Renumbered from 690-080-0070

~~690-507-0040~~

~~Wildhorse Creek Subbasin~~

~~(1) Objectives: In developing a program for the management, use and control of the surface and ground water resources of the Wildhorse Creek subbasin, the Commission has the following objectives:~~

~~(a) Protect instream values by closing streams to future appropriations during the low-flow season and limiting future appropriations during the high-flow season to selected nonirrigation or nonconsumptive uses;~~

~~(b) Permit artificial ground water recharge to offset declining ground water levels and supplement existing ground water uses;~~

~~(c) Protect municipal ground water supplies;~~

~~(d) Prevent new appropriations from causing ground water/surface water interference;~~

~~(e) Support efforts to reduce nonpoint source sediment loads in subbasin streams.~~

~~(2) Surface Water: Appropriation and use of surface water in the Wildhorse Creek subbasin shall comply with the following provisions:~~

~~(a) Wildhorse Creek and tributaries are withdrawn from further appropriation of unappropriated waters during the period June 1 through October 31 each year. The withdrawal does not apply to domestic, livestock, fish and wildlife uses or water released from storage. This action was taken by the Commission on December 2, 1985;~~

~~(b) Classification: Permits to use the surface waters of Wildhorse Creek and tributaries may be issued only for domestic, livestock, irrigation of noncommercial lawn and garden not to exceed 1/2 acre, power development (subject to the limitations of OAR Chapter 690, Division 51), mining, fish life, wildlife, recreation, pollution abatement, artificial ground water recharge and public instream uses during the period November 1 through May 31 each year. This classification rescinds the Commission's order of December 2, 1985, withdrawing the Umatilla River and tributaries from further appropriation from November 1 through May 31 each year until December 31, 1988.~~

~~(c) Storage: Surface water legally stored during the period November 1 through May 31 and legally released may be used for any beneficial purpose;~~

~~(d) Artificial ground water recharge: Use of surface water for ground water recharge shall be subject to the following conditions:~~

~~(A) Recharged water used under a secondary permit for irrigation may only provide supplemental water to lands with existing irrigation rights or permits on June 24, 1988;~~

~~(B) Diversion of surface water for recharge for irrigation under a secondary permit shall not exceed 2.25 acre feet per acre to~~

The remainder of OAR 690-507-0010 has not been included because it does not pertain to the City of Milton-Freewater.


CITY OF MILTON-FREEWATER

RESOLUTION NO. 2194

**A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF MILTON-FREEWATER
ADOPTING THE UPDATED WATER SYSTEM MASTER PLAN
AS REQUIRED BY THE
OREGON HEALTH DIVISION**

BE IT RESOLVED by the City Council of the City of Milton-Freewater that the City of Milton-Freewater Water Master Plan, such plan as was approved by the Oregon State Water Resources Department and Oregon Health Division is hereby formally approved.

PASSED by the Council and **APPROVED** by the Mayor this 13th day of December 2010.



Lewis S. Key, Mayor

CITY OF MILTON-FREEWATER, OREGON

WATER SYSTEM MASTER PLAN

2009



RENEWS 12-31-09
SIGNED

Adopted by City Council
12/13/10 Resolution #2194
L. Skadman

Anderson-Perry & Associates, Inc.

Civil Engineers

La Grande, Oregon
Walla Walla, Washington

City of Milton-Freewater

FACT SHEET

| | | |
|---|--|----------------------------------|
| MEETING DATE: December 13, 2010 | AGENDA LOCATION: <i>Business Items</i> | ITEM NUMBER: <i>4D</i> |
|---|--|----------------------------------|

DATE: December 3, 2010

TO: Honorable Mayor and City Council

FROM: Dave Bradshaw, Public Works Superintendent *DB*

THROUGH: Linda Hall, City Manager *L Hall*

ISSUE: Update of City of Milton-Freewater Water System Master Plan

BACKGROUND: The City is required by the Oregon Health Division to adopt a Water System Master Plan. This cumbersome mandate came to the City over a decade ago and much work and time and money has been expended upon it over the years. Work on the original plan was begun during the year 1999 and took our staff and consultant firm a decade to complete due to the huge number of required elements and data collection and analysis required to be in the plan.

Ironically enough, by the time we received the approval of the first plan, work was already underway to update it and keep it current according to State regulations.

The draft of the update and complete plan was presented to the City Council in March of 2009 by our consultant, Brad Baird of Anderson-Perry & Associates.

We then submitted the updated plan to the Oregon Health Division who have now completed their review and approval of the Water System Master Plan. We are now asking Council to formally approve the plan.

Since it has been a substantial amount of time since the plan was last presented to you, we are re-supplying the Council with copies of the Master Plan, although no changes have been made to it since it was last presented to you in 2009.

BUDGET IMPACT: Not significant: The elements of the plan are already being complied with and monitored as required by our drinking-water permit.

RECOMMENDATION: A motion by Resolution No. _____ Adopting The City of Milton-Freewater's Water System Master Plan.

City of Milton-Freewater

City Council Meeting Agenda

December 13, 2010
Albee Room of City Library
8 SW 8th Avenue
7:00 p.m.

1. OPENING

- A. Roll Call
- B. Invocation by Councilor Humbert
- C. Pledge of Allegiance

2. CONSENT CALENDAR ITEMS:

Sponsor(s)/Requesting Parties

- A. APPROVAL of Council Minutes, October 25, 2010* Leanne Steadman
- B. APPROVAL of Accounts Payable, Oct. 20 – Nov. 2, 2010* Leanne Steadman
- C. APPROVAL of Accounts Payable, Nov. 3 – Nov. 16, 2010 Leanne Steadman
- D. APPROVAL of Accounts Payable, Nov. 17 – Dec. 7, 2010 Leanne Steadman
- E. APPROVAL of Liquor License Request from The Bank & Grill Catering Company Leanne Steadman
- F. RESOLUTION NO. 2191, Acceptance of the Umatilla County Abstract Votes from the General Election of November 2, 2010 Leanne Steadman

3. PRESENTATIONS:

- A. RECOGNITION – December 2010 Employee(s) of the Month
Shane Wright and Daniel Verkist both Public Works Utility Workers Sam Hopkins-Hubbard

4. BUSINESS ITEMS:

- A. ACCEPTANCE OF BRONZE STATUE – “Skateboard Boy”
Statue was donated by Chuck & Jean Nelson of Skylite Gallery located in Walla Walla, Washington* Linda Hall
- B. RESOLUTION NO. 2192, Transfer Funds Due to Unforeseen Revenues and Expenditures Dave Richmond
- C. RESOLUTION NO. 2193, Adoption of a Base Fine Schedule for Violations of the City Animal Code Doug Boedigheimer
- D. RESOLUTION NO. 2194, Final Adoption of the Water System Master Plan Dave Bradshaw
- E. RESOLUTION NO. 2195, Adoption of the Updated Water Management and Conservation Plan Dave Bradshaw

5. OPPORTUNITY FOR CITIZENS TO APPROACH THE COUNCIL WITH ISSUES NOT ON THIS AGENDA

Note: Citizens wishing to make comments should be recognized by the Mayor, speak at the microphone, state their name and address, and limit their remarks to 5 minutes in length.

6. MANAGER'S REPORT

7. COUNCIL ANNOUNCEMENTS

8. FINAL ADJOURNMENT

Note: Location of the Council Meeting is handicapped accessible. If you will need any special accommodations to attend or participate in the meeting, please call 938-8233 (TTD 938-5511) between the hours of 7:00 a.m. and 4:00 p.m. Monday through Friday. As per Resolution No. 1699 dated July 13, 1998, certain City Council meetings are recorded.

*ITEMS CARRIED OVER FROM NOVEMBER 8, 2010 COUNCIL MEETING DUE TO A LACK OF A QUORUM AT THE MEETING



Mailed 12/14/10 KS

File

**CITY OF
MILTON-FREEWATER**
P.O. Box 6 • 501 Lamb • Milton-Freewater, OR 97862

December 14, 2010

Oregon Health Division
Drinking Water Program
Attn: Bill Goss
700 SE Emigrant, Suite 200
Pendleton, OR 97801

RE: City of Milton-Freewater Water System Master Plan

Dear Bill,

A copy of the resolution adopting the Water System Master Plan is attached for your records.

Please don't hesitate to contact me at 541-938-8270 if you have any questions.

Sincerely,

Krista Sheridan
Public Works Assistant/Project Aide

Enc (2)

cc: Brad Baird, Anderson-Perry & Associates, Inc.


CITY OF MILTON-FREEWATER

RESOLUTION NO. 2194

**A RESOLUTION OF THE CITY COUNCIL OF THE CITY OF MILTON-FREEWATER
ADOPTING THE UPDATED WATER SYSTEM MASTER PLAN
AS REQUIRED BY THE
OREGON HEALTH DIVISION**

BE IT RESOLVED by the City Council of the City of Milton-Freewater that the City of Milton-Freewater Water Master Plan, such plan as was approved by the Oregon State Water Resources Department and Oregon Health Division is hereby formally approved.

PASSED by the Council and **APPROVED** by the Mayor this 13th day of December 2010.



Lewis S. Key, Mayor